


BRIAN COWAN, MPH, LEHS
Health Officer/Executive Director



September 25, 2024

Weber County Planning Commission
2380 Washington Blvd.
Ogden, UT 84401

RE: Subdivision **Determination**
M and M Ranch, 2 lots
Parcel #19-010-0032
Soil log #15633

The soil and percolation information for the above-referenced lot has been reviewed. Culinary water will be provided by Bona Vista Water Improvement District, an approved water system. **A letter from the water supplier is required prior to issuance of a permit.**

DESIGN REQUIREMENTS

Lot 1 & 2: Documented ground water tables not to exceed 24 inches, fall within the range of acceptability for the utilization of an At-Grade Wastewater Disposal System as a means of wastewater disposal. Maximum trench depth is limited to 0 inches. The absorption system is to be designed using a maximum loading rate of 0.40 gal/sq. ft. /day as required for Silty Clay Loam blocky structure soil.


Plans for the construction of any wastewater disposal system are to be prepared by a Utah State certified individual and submitted to this office for review prior to the issuance of a Wastewater Disposal permit.

The following items are required for a formal **subdivision review**; application, receipt of the appropriate fee, and a full sized copy of the subdivision plats showing the location of exploration pits and percolation tests as well as the documented soil horizons and percolation rates. A subdivision review will not occur until all items are submitted. Mylars submitted for signature without this information will be returned.

Each on-site individual wastewater disposal system must be installed in accordance with R317-4, Utah Administrative Code, Individual Wastewater Disposal Systems and Weber-Morgan District Health Department Rules. Final approval will be given only after an on-site inspection of the completed project and prior to the accomplishment of any backfilling.

Please be advised that the conditions of this letter are valid for a period of 18 months. At that time, the site will be re-evaluated in relation to rules in effect at that time.

Sincerely,


Summer Day, LEHS, Program Manager
Environmental Health Division
801-399-7160

EDUCATE | ENGAGE | EMPOWER

phone: 801-399-7100 | fax: 801-399-7110 | 477 23rd Street, Ogden, UT 84401 | www.webermorganhealth.org