

A Form 26-6395 Completed

2

WEBER-MORGAN DISTRICT HEALTH DEPARTMENT
DIVISION OF ENVIRONMENTAL SANITATION
2570 Grant Avenue, Ogden, Utah 84401

Permit Number 78-100
Fee Paid \$10.00

Part I - Individual Sewage Disposal System Application

Date 5-1-78
Construction Address 2151 E UAZS S City or Town Uintah
Subdivision Shadow Oaks Lot Number 9
Owner or Applicant Tom Hayes Phone 766-0321
Mailing Address 1051 E. 825 N., E. Layton Zip Code 84041
Contractors Hayes Construction Mortgage Sponsor N.A.

HEALTH DEPARTMENT USE ONLY

Part II - Code Requirements

Lot Plan Provided X Secondary Treatment: Drainfield (X) Seepage Pit ()
Number of Bedrooms 3 Basement Yes Septic Tank Capacity 900 Gallons
Total Absorption Area: 852 Square Feet Drainfield Square Feet Wall Area
Water Table 5' Percolation Rate 40 MPI
Remarks No Land Parcel Serial Number on Land Use Permit. Bottoms of drainfields not to
go into the original ground more than 48".

Approved By WMK

Part III - Individual Sewage Disposal Record

Installed Absorption Area: 840 Square Feet Drainfield Square Feet Wall Area
Installed Septic Tank Capacity 900 Gallons Date of Final Approval/Rejection 8-11-78

SEE REVERSE FOR INSPECTOR'S SKETCH