



# Weber Fire District

## Plan Review

**Date:** January 12, 2015

**Project Name:** Clint Bybee Subdivision

**Project Address:** 1280 S 2900 W, Unincorporated County

**Contractor/Contact:** Clinton Bybee 801-663-4670 | clintonbybee14@icloud.com

**Fees:**

Property Type	Schedule Rates	Square Foot Rate	Square Feet or Number of Res. Units	Total
Type	Rate	Rate/ Sq Ft	Sq Ft or # of Units	Total
Plan Review	1-30 lot subdivision			\$50.00
				\$0.00
				\$0.00
				\$0.00
			<b>Total Due</b>	<b>\$50.00</b>

**FEE NOTICE:**

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: **Weber Fire District.**

**REVIEW STATUS: APPROVED**

**NOTES: This is an existing property with an existing home. The subdivision is being created in order to create a legal lot for the existing property. No new construction is taking place on the property.**

**SPECIFIC COMMENTS:**

1. Provide an address marker on the building.

**General Requirements:**

- Roads and bridges shall be designed, constructed and maintained to support an imposed load of 75,000 lbs.
- All roads shall be designed, constructed, surfaced and maintained so as to provide an all-weather driving surface.
- Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for height, width and imposed loads as permanent roads.
- All required fire hydrants and water systems shall be installed, approved and fully functional prior to any combustible construction.
- Fire department apparatus access is required for each lot.



# Weber Fire District

## Plan Review

Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all applicable codes and standards. Any change or revision of this plan will render this review void and will require submittal of the new or revised layout for fire department review.

Reviewed by: Brandon Thueson  
Fire Marshal

cc: File