

WEBER-MORGAN DISTRICT HEALTH DEPARTMENT
DIVISION OF ENVIRONMENTAL SANITATION
2570 Grant Avenue, Ogden, Utah 84401

Permit Number 77-47
Fee Paid \$10.00

Part I - Individual Sewage Disposal System Application

Date 3-14-77
Construction Address Approx. 3700 E. 3600 N. City or Town Liberty
Subdivision Liberty Meadows Lot Number 13
Owner or Applicant Lynn C. Satterthwaite Phone 782-6458
Mailing Address 150 E. 700 N. Zip Code 84404
Contractors L & L Construction Mortgage Sponsor NA

HEALTH DEPARTMENT USE ONLY

Part II - Code Requirements

Plot Plan Provided X Secondary Treatment: Drainfield (X) Seepage Pit ()
Number of Bedrooms 3 Basement Yes Septic Tank Capacity 900 Gallons
Total Absorption Area: 750 Square Feet Drainfield _____ Square Feet Wall Area
Water Table 48" Percolation Rate 30 Min/In
Remarks Drainfields are not to go into the original ground more than 36 inches.

Approved By WMK



Part III - Individual Sewage Disposal Record

Installed Absorption Area: 783 Square Feet Drainfield _____ Square Feet Wall Area
Installed Septic Tank Capacity 900 Gallons Date of Final Approval/Rejection 3-14-77

SEE REVERSE FOR INSPECTOR'S SKETCH

Construction Address Approx. 3700 E. 3600 N. City or Town Liberty
 Subdivision Liberty Meadows Lot Number 13
 Owner or Applicant Lynn C. Satterthwaite

INSPECTOR'S SKETCH



Wm. Decker
 Registered Sanitarian