

A

R

W ENGINEERS

Structural Calculations

For

Uintah Reservoir #3 Rebuild

Job Number: 15068

March 13, 2015



Prepared by
ARW Engineers
1594 West Park Circle
Ogden, Utah 84404

DESIGN CRITERIASNOW LOAD (PER SNOW LOAD STUDY)

ELEV. = 5,178 ft

WEBER COUNTY $A_o = 4.5$ $P_o = 43$ $A = 5.178$ $S = 63$

$$P_g = (P_o^2 + S^2(A - A_o)^2)^{1/2}$$

$$P_g = (43^2 + 63^2(5.178 - 4.5)^2)^{1/2} = 61 \text{ psf}$$

$$P_g = 61 \text{ psf}$$

$$\underline{\underline{SL = 61 \text{ psf}}}$$

USE ROOF LIVE LOAD = 100 psf

$$\underline{\underline{LR = 100 \text{ psf}}} \quad \checkmark \text{ CONTROLS OVER SNOW}$$

SEISMIC PARAMETERS

SITE LOCATION - 2545 JACQUELINE DR., OGDEN UT

LAT $\rightarrow 41.163^\circ$ LONG $\rightarrow 111.918^\circ$ PER USGS \rightarrow $S_s = 1.261g$ $S_{ms} = 1.261g$ $S_{ds} = 0.941g$ $S_1 = 0.473g$ $S_{m1} = 0.722g$ $S_{d1} = 0.481g$ SOIL PARAMETERS

REPORT BY GEOSTRATA #1065-001

NET BEARING = 4,000 psf

ACTIVE = 31 pcf

AT-REST = 49 pcf

SEISMIC ACTIVE = 52 pcf (INVERTED TRIANGLE)

FRICTION = 0.49

DESIGN CRITERIA (CONT'D)

ENVIRONMENTAL DURABILITY FACTOR

FOR HOOP STRESSES: (TENSION)

LIQUID $\Rightarrow \gamma = 1.4 \quad \therefore S_d = \frac{0.9(60 \text{ ksi})}{1.4(20 \text{ ksi})} = 1.93 \quad \underline{\underline{S_d = 1.93}}$
LIQUID

SOIL $\Rightarrow \gamma = 1.6 \quad \therefore S_d = \frac{0.9(60 \text{ ksi})}{1.6(20 \text{ ksi})} = 1.69 \quad \underline{\underline{S_d = 1.0}}$
SOIL

SOIL CREATES COMP. FORCES IN HOOP \therefore USE $S_{d \text{ SOIL}} = 1.0$


FLEXURAL STRESSES:

LIQUID $\Rightarrow \gamma = 1.4 \quad \therefore S_{d \text{ LIQUID}} = 1.93$
 $F_s = 20 \text{ ksi (CONSERVATIVE)}$

SOIL $\Rightarrow \gamma = 1.6 \quad \therefore S_{d \text{ SOIL}} = 1.69$

TANK LAYOUT

TANK = 16' TALL
 1' FREEBOARD



USGS Design Maps Summary Report

User-Specified Input

Report Title Uintah Highlands Reservoir #3
 Mon March 2, 2015 16:26:41 UTC

Building Code Reference Document ASCE 7-10 Standard
 (which utilizes USGS hazard data available in 2008)

Site Coordinates 41.163°N, 111.918°W

Site Soil Classification Site Class D - "Stiff Soil"



Risk Category IV (e.g. essential facilities)



USGS-Provided Output

$S_S = 1.261 \text{ g}$	$S_{MS} = 1.261 \text{ g}$	$S_{DS} = 0.841 \text{ g}$
$S_1 = 0.473 \text{ g}$	$S_{M1} = 0.722 \text{ g}$	$S_{D1} = 0.481 \text{ g}$

For information on how the S_S and S_1 values above have been calculated from probabilistic (risk-targeted) and deterministic ground motions in the direction of maximum horizontal response, please return to the application and select the "2009 NEHRP" building code reference document.



For PGA_M , T_L , C_{RS} , and C_{R1} values, please [view the detailed report](#).



Google earth



Project Name Uintah Highlands Reservoir #3
 Project # 15068
 Prepared By ZCH
 Date 3/4/2015

Program Authors: TAB & DOC
 Last Revised: 10/20/2010
 Reviewed By: TAB



Circular Concrete Tanks without Prestressing

(Based on the 1993 PCA Document)

Design Criteria

f'_c	4000 psi
D_{tank}	48 ft
H_{tank}	16 ft
t_{wall}	12 in
Fluid Pressure	62.4 pcf
Soil Pressure	50 pcf
E_s	29000000 psi
E_c	3823676.24 psi
n	7.6
Surcharge	100 pcf
Soil on Lid	1 ft
Load Factor	
$F_{liquid\ pressure}$	1.4
$F_{soil\ pressure}$	1.6
Environmental	
Durability Factor	
Flexure (liquid)	1.03
Tension (liquid)	1.03
Flexure (soil)	1.60
Compression (soil)	1
H^2/Dt	5.33

Estimation of Tank Wall Thickness

Limit Ring Tension Stress in Concrete Wall from 7% to 12% of f'_c

For given t and H^2/Dt , with a hinged base/free top (Table A-5)

Max Coefficient= 0.624 (Table A-5)

w_u 169 pcf

T_{max} 40422 lbs.

$T_{unfactored}$ 14960 lbs.

$A_{s(reqd)}$ 0.75 in²

$A_{s(used)}$ 0.58 in² OK

$F_{(conc)}$ 150 psi

Compression Check

F'_c	313
0.33 f'_c	1485
OK	

This equates to 3.34 % of f'_c

Wall thickness is OK

The Following Load Cases were used in Analysis:

- Load Case #1: Full of Water, No Lid, No Backfill
- Load Case #2: Empty, No Lid, w/Backfill
- Load Case #3: Empty, w/Lid, w/Backfill
- Load Case #4: Full of Water, w/Lid, Ignore Backfill

Load Case #1-Full of Water, No Lid, No Backfill

Assume Free Top/Hinged Base (Tables A-5 and A-7)

Effects of Possible outward movement will be handled by designing the entire portion of the wall for the maximum Ring Tension and Moment

Ring Force=(A-5 Coef.) w_uHR $w_uHR=$ 64744.2432

Moment =(A-7 Coef.) w_uH^3 $w_uH^3=$ 690605.2608

	A-5 Coef.	RF (#)	A-7 Coef.	Moment (#-ft/ft)
Top	-0.009	-583	0	0
0.1H	0.110	7143	0.0000	0
0.2H	0.231	14956	0.0001	46
0.3H	0.352	22768	0.0005	322
0.4H	0.467	30236	0.0013	921
0.5H	0.563	36473	0.0029	2003
0.6H	0.624	40422	0.0051	3522
0.7H	0.618	40034	0.0074	5110
0.8H	0.518	33516	0.0089	6123
0.9H	0.305	19747	0.0075	5157
Bottom	0.000	0	0	0

Project Name Uintah Highlands Reservoir #3
 Project # 15068
 Prepared By ZCH
 Date 3/4/2015

Program Authors: TAB & DOC
 Last Revised: 1/19/2006
 Reviewed By: TMD



Load Case #2-Empty, No Lid, w/ Backfill

Use Durability Coefficients as Noted Previous

Soil Over Lid= 1 ft
 ρ 100

Ring Force=(A-5 Coef.) w_u HR+(A-6 Coef.) ρ R

w_u HR= -59290
 ρ R= -7411.2

Moment=(A-7 Coef.) $(w_u h^3 + \rho h^2)$

$w_u h^3 + \rho h^2 = -623002$

	A-5 Coef	RF (#)	A-6 Coef.	RF (#)	Total RF (#)	A-7 Coef.	Moment (#-ft/ft)
Top	-0.009	534	0.991	-7344.4992	-6811	0	0
0.1H	0.110	-6542	1.010	-7487.7824	-14029	0.0000	0
0.2H	0.231	-13696	1.031	-7640.9472	-21337	0.0001	-42
0.3H	0.352	-20850	1.052	-7794.112	-28644	0.0005	-291
0.4H	0.467	-27688	1.067	-7907.7504	-35596	0.0013	-831
0.5H	0.563	-33400	1.063	-7880.576	-41280	0.0029	-1807
0.6H	0.624	-37016	1.024	-7591.5392	-44608	0.0051	-3177
0.7H	0.618	-36661	0.918	-6805.952	-43467	0.0074	-4610
0.8H	0.518	-30692	0.718	-5318.7712	-36011	0.0089	-5524
0.9H	0.305	-18083	0.405	-3001.536	-21085	0.0075	-4652
Bottom	0.000	0	0.000	0	0	0	0

Load Case #3-Empty, w/Lid, w/Backfill

Apply a shear force (V) @ top of wall to make Ring Tension = 0 @ top of Wall

When top of tank is free, Ring Force (LC#2) = -6811 #

At top of wall (0.0H) from table A-8, Coefficient= -8.49 #

Therefore, the shear force (V) required to produce zero ring force at the top of the tank=
 (Coef. A-8 @ 0.0H)(VR/H)=(Ring Force from LC#2)

Therefore

V= -535 #
 VR/H= -803 #

Delta_{RF}=Change in Ring Force Due to V applied @ the top of wall

Delta_{RF}=(A-8 Coef.)(VR/H)

Find the change in moment (Delta_{mom}) due to the V applied @ top.

If S_D for moment is less than S_D for compression, then V is reduced by (S_{Dm}/S_{Dc})

Delta_{mom}=(A-9 Coef.)VH

VH= -8560

	A-8 Coef.	Delta _{RF} (#)	LC#2 RF (#)	Total RF (#)	A-9 Coef.	Delta _{mom} (#-ft/ft)	LC #2 Moment (#-ft/ft)	Total Moment (#-ft/ft)
Top	-8.487	6811	-6811	0	0	0	0	0
0.1H	-5.050	4053	-14029	-9977	0.0633	-542	0	-542
0.2H	-2.390	1918	-21337	-19419	0.0753	-645	-42	-686
0.3H	-0.693	556	-28644	-28088	0.0633	-542	-291	-833
0.4H	0.187	-150	-35596	-35746	0.0433	-371	-831	-1202
0.5H	0.510	-409	-41280	-41690	0.0247	-211	-1807	-2018
0.6H	0.510	-409	-44608	-45017	0.0107	-91	-3177	-3269
0.7H	0.363	-292	-43467	-43758	0.0020	-17	-4610	-4627
0.8H	0.190	-152	-36011	-36164	-0.0030	26	-5524	-5498
0.9H	0.043	-35	-21085	-21120	-0.0063	54	-4652	-4598
Bottom	0.000	0	0	0	-0.0093	80	0	80

Project Name Uintah Highlands Reservoir #3
 Project # 15068
 Prepared By ZCH
 Date 3/4/2015

Program Authors TAB & DOC
 Last Revised 1/19/2006
 Reviewed By TMD



Load Case #4-Full of Water, w/Lid, ignore Backfill

Add the effects of shear @ the top of the tank to LC #1

At the top of the wall - Coefficient from Table A-8= -8.49 #

(Coef. A-8 @ 0.0H)(VR/H) = (Ring Force from LC#1)

V= -46 #
 VR/H= -69 # (For Ring Force)
 VH= -732 # (For Moment)


	A-8 Coef.	Delta _{RF} (#)	LC#1 RF (#)	Total RF (#)	A-9 Coef.	Delta _{mom} (#-ft/ft)	LC#1 Moment (#-ft/ft)	Total Moment (#-ft/ft)
Top	-8.49	583	-583	0	0	0	0	0
0.1H	-5.05	347	7143	7490	0.063	-46	0	-46
0.2H	-2.39	164	14956	15120	0.075	-55	46	-9
0.3H	-0.69	48	22768	22816	0.063	-46	322	276
0.4H	0.19	-13	30236	30223	0.043	-32	921	889
0.5H	0.51	-35	36473	36438	0.025	-18	2003	1985
0.6H	0.51	-35	40422	40387	0.011	-8	3522	3514
0.7H	0.36	-25	40034	40009	0.002	-1	5110	5109
0.8H	0.19	-13	33516	33503	-0.003	2	6123	6126
0.9H	0.04	-3	19747	19744	-0.006	5	5157	5161
Bottom	0	0	0	0	-0.009	7	0	7

Envelope of Ring Forces

	LC#1	LC#2	LC#3	LC#4	Max	Min
Top	-583	-6811	0	0	0	-6811
0.1H	7143	-14029	-9977	7490	7490	-14029
0.2H	14956	-21337	-19419	15120	15120	-21337
0.3H	22768	-28644	-28088	22816	22816	-28644
0.4H	30236	-35596	-35746	30223	30236	-35746
0.5H	36473	-41280	-41690	36438	36473	-41690
0.6H	40422	-44608	-45017	40387	40422	-45017
0.7H	40034	-43467	-43758	40009	40034	-43758
0.8H	33516	-36011	-36164	33503	33516	-36164
0.9H	19747	-21085	-21120	19744	19747	-21120
Bottom	0	0	0	0	0	0

CONTROLS

	Tension	Compression
Bottom	0	0
0.9H	20	-21
0.8H	34	-36
0.7H	40	-44
0.6H	40	-45
0.5H	36	-42
0.4H	30	-36
0.3H	23	-29
0.2H	15	-21
0.1H	7	-14
Top	0	-7



Project Name Uintah Highlands Reservoir #3
 Project # 15068
 Prepared By ZCH
 Date 3/4/2015


Program Authors: TAB & DOC
 Last Revised: 1/19/2006
 Reviewed By: TMD



Envelope of Moments


	LC#1	LC#2	LC#3	LC#4	Max	Min
Top	0	0	0	0	0	0
0.1H	0	0	-542	-46	0	-542
0.2H	46	-42	-686	-9	46	-686
0.3H	322	-291	-833	276	322	-833
0.4H	921	-831	-1202	889	921	-1202
0.5H	2003	-1807	-2018	1985	2003	-2018
0.6H	3522	-3177	-3269	3514	3522	-3269
0.7H	5110	-4610	-4627	5109	5110	-4627
0.8H	6123	-5524	-5498	6126	6126	-5524
0.9H	5157	-4652	-4598	5161	5161	-4652
Bottom	0	0	80	7	80	0

	Tension O.F.	Tension I.F.
Bottom	0	0
0.9H	5	-5
0.8H	5	-6
0.7H	5	-5
0.6H	4	-3
0.5H	2	-2
0.4H	1	-1
0.3H	0	-1
0.2H	0	-1
0.1H	0	-1
Top	0	0



WALL DESIGN

* SEE SPREADSHEET FOR MAX TENSION AND COMPRESSION CHECK

RING STEEL (HORIZONTAL BARS)Max Ring Force \Rightarrow Bottom 10' of Wall = 40.4 K \therefore USE (2) #6 @ 12" O.C. (SEE SPREADSHEET)

TOP 6' OF WALL = 30.2K @ 0.4H

$$A_{sREQ'D} = \frac{30.2K}{0.9(60KSI)} = 0.56 \text{ in}^2/\text{ft}$$

 \therefore USE (2) #5 @ 12" O.C. (0.62 in²/ft)

CHECK MIN. SHRINKAGE STEEL:


$$A_{smin} = 0.005(12" \times 12") = 0.72 \text{ in}^2/\text{ft}$$

 \therefore USE (2) #6 @ 12" O.C. ENTIRE HEIGHT OF WALL

Wall Design (cont'd)

MOMENT REINF. (VERT. BARS)

MAX MOMENT = 6 K-FT (+ AND - BENDING)



$f'_c = 4,500 \text{ psi}$

$d = 9.5 \text{ in}$

$b = 12 \text{ in}$

$M_u = \frac{6000(16-9.5)(12)}{0.9(12)(9.5)^2} = 73.87$

$\rho = \frac{0.85(4.5)}{60} \left(1 - \sqrt{1 - \frac{2(73.87)}{0.85(4,500)}} \right)$

$\rho = 0.0012 \checkmark$

$\rho_{min} \Rightarrow \text{TEMP. SHRINKAGE} = 0.003$

$A_{smin} = 0.003(12)(12)$

$A_{smin} = 0.43 \text{ in}^2/\text{ft (BOTH SIDES)}$

A_{smin} BASED ON FLEXURE:

$A_{smin} = \frac{3\sqrt{4,500}}{60,000} (12)(9.5) = 0.38 \text{ in}^2/\text{ft}$
ONE FACE OF WALL

\therefore FLEXURE CONTROLS

$A_{SREQ'D} = 0.38 \text{ in}^2/\text{ft}$ EACH WALL FACE

\therefore USE #6 @ 12" OC. EA. FACE

SHEAR STRENGTH OF WALL

WALL CAPACITY $\Rightarrow \phi V_c = 0.75(2)\sqrt{4,500}(12 \text{ in})(9.5 \text{ in}) = 11.5 \text{ K}$

$\phi V_c = 11.5 \text{ K}$

$V_{max \text{ in wall}} = 0.121(1.6)(62.4 \text{ pcf})(16^3) = 3.1 \text{ K} < 11.5 \text{ K}$

↑
COEFF. PCA TABLE A-12

\therefore WALL SHEAR STRENGTH IS GOOD \checkmark



CONCRETE LAP SPLICE TABLE

05-Mar-15
10:21 AM

JOB TITLE: Uintah Highlands Reservoir #3
BUILDING LOCATION: Uintah, UT

JOB #: 15068
PREPARED BY: ZCH

CONCRETE DEVELOPMENT AND LAP SPLICE DESIGN TABLE

BASED ON CHAPTER 12 OF THE 2011 ACI 318
Author: Matt McBride

Version: June 17, 2013

Concrete Properties

- $\psi_s = 1.0$ For horizontal reinforcement placed such that more than 12 in. of fresh concrete is cast below the development length or splice (i.e. Top Splice) = 1.3 - Otherwise = 1.0
- $\psi_w = 1.0$ For Epoxy-coated bars or wires with cover less than $3db$, or clear spacing less than $6db = 1.5$ - For all other Epoxy-coated bars or wires = 1.2 - Otherwise = 1.0
- $\lambda = 1.0$ When Light-weight Aggregate Concrete is used = 0.75 - Otherwise = 1.0
- $\psi_s = 1.0$ For No. 6 smaller bars and deformed wires = 0.8 - Otherwise = 1.0

Rebar Properties
 $f_y = 60000$ psi

CONCRETE REINFORCING DEVELOPMENT & SPLICE LENGTHS																																			
Bar Location	Concrete		BAR SIZE																																
	Type	Strength	#3			#4			#5			#6			#7			#8			#9			#10			#11			#14			#18		
			l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}			
Vert. Wall Bars, Fill on Metal Deck	NWC	3000 psi	17	22	8	22	29	8	28	36	10	33	43	12	48	62	13	55	72	15	62	81	17	69		19	76		30	96	38	124	49		
Horiz. Wall Bars, Footing Top Bars	NWC	3000 psi	17	22	8	22	29	8	28	36	10	33	43	12	48	62	13	55	72	15	62	81	17	69		19	76		30	96	38	124	49		
Beam Bottom Bars, Column Bars	NWC	3000 psi	17	22	8	22	29	11	28	36	14	33	43	16	48	62	19	55	72	22	62	81	25	69		27	76		30	96	38	124	49		
Footing Bottom Bars	NWC	3000 psi	12	16	8	14	18	8	17	22	10	20	26	12	29	38	13	33	43	15	37	48	17	42		19	46		30						
Beam Top Bars	NWC	3000 psi	22	29	8	29	38	11	36	47	14	43	56	16	63	82	19	72	94	22	81	105	25	90		27	98		30	125	38	161	49		
Slab on Grade	NWC	3000 psi	12	16	8	14	18	8	17	22	10	20	26	12	32	42	13	42	55	15	53	69	17	69		19	76		30						

CONCRETE REINFORCING DEVELOPMENT & SPLICE LENGTHS																																			
Bar Location	Concrete		BAR SIZE																																
	Type	Strength	#3			#4			#5			#6			#7			#8			#9			#10			#11			#14			#18		
			l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}			
Vert. Wall Bars, Fill on Metal Deck	NWC	4000 psi	15	20	7	19	25	7	24	31	8	29	38	10	42	55	12	48	62	13	54	70	15	60		17	66		26	84	33	107	43		
Horiz. Wall Bars, Footing Top Bars	NWC	4000 psi	15	20	7	19	25	7	24	31	8	29	38	10	42	55	12	48	62	13	54	70	15	60		17	66		26	84	33	107	43		
Beam Bottom Bars, Column Bars	NWC	4000 psi	15	20	7	19	25	9	24	31	12	29	38	14	42	55	17	48	62	19	54	70	21	60		24	66		26	84	33	107	43		
Footing Bottom Bars	NWC	4000 psi	12	16	7	12	16	7	15	20	8	18	23	10	25	33	12	29	38	13	33	43	15	36		17	40		26						
Beam Top Bars	NWC	4000 psi	19	25	7	25	33	9	31	40	12	37	48	14	54	70	17	62	81	19	70	91	21	78		24	85		26	108	33	139	43		
Slab on Grade	NWC	4000 psi	12	16	7	12	16	7	15	20	8	18	23	10	28	36	12	36	47	13	46	60	15	60		17	66		26						

CONCRETE REINFORCING DEVELOPMENT & SPLICE LENGTHS																																			
Bar Location	Concrete		BAR SIZE																																
	Type	Strength	#3			#4			#5			#6			#7			#8			#9			#10			#11			#14			#18		
			l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}			
Vert. Wall Bars, Fill on Metal Deck	NWC	4500 psi	14	18	7	18	23	6	23	30	8	27	35	9	40	52	11	45	59	13	51	66	14	56		16	62		25	79	31	101	40		
Horiz. Wall Bars, Footing Top Bars	NWC	4500 psi	14	18	7	18	23	6	23	30	8	27	35	9	40	52	11	45	59	13	51	66	14	56		16	62		25	79	31	101	40		
Beam Bottom Bars, Column Bars	NWC	4500 psi	14	18	7	18	23	9	23	30	11	27	35	13	40	52	16	45	59	18	51	66	20	56		22	62		25	79	31	101	40		
Footing Bottom Bars	NWC	4500 psi	12	16	7	12	16	6	14	18	8	17	22	9	24	31	11	27	35	13	31	40	14	34		16	37		25						
Beam Top Bars	NWC	4500 psi	18	23	7	24	31	9	30	39	11	35	46	13	51	66	16	59	77	18	66	86	20	73		22	80		25	102	31	131	40		
Slab on Grade	NWC	4500 psi	12	16	7	12	16	6	14	18	8	17	22	9	27	35	11	34	44	13	44	57	14	56		16	62		25						

CONCRETE REINFORCING DEVELOPMENT & SPLICE LENGTHS																																			
Bar Location	Concrete		BAR SIZE																																
	Type	Strength	#3			#4			#5			#6			#7			#8			#9			#10			#11			#14			#18		
			l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}	l_d	l_s	l_{dn}			
Vert. Wall Bars, Fill on Metal Deck	NWC	5000 psi	13	17	6	17	22	6	22	29	7	26	34	9	38	49	10	43	56	12	48		13	54		15	59		23	75	30	96	38		
Horiz. Wall Bars, Footing Top Bars	NWC	5000 psi	13	17	6	17	22	6	22	29	7	26	34	9	38	49	10	43	56	12	48		13	54		15	59		23	75	30	96	38		
Beam Bottom Bars, Column Bars	NWC	5000 psi	13	17	6	17	22	8	22	29	11	26	34	13	38	49	15	43	56	17	48		19	54		21	59		23	75	30	96	38		
Footing Bottom Bars	NWC	5000 psi	12	16	6	12	16	6	13	17	7	16	21	9	23	30	10	26	34	12	29		13	32		15	36		23						
Beam Top Bars	NWC	5000 psi	17	22	6	23	30	8	28	36	11	34	44	13	49	64	15	56	73	17	63		19	69		21	76		23	97	30	125	38		
Slab on Grade	NWC	5000 psi	12	16	6	12	16	6	13	17	7	16	21	9	25	33	10	32	42	12	41		13	54		15	59		23						

TANK LIDDEAD LOAD

ASSUME 10" THICK SLAB + 18" Ø COLUMN

$$DL = 150 \text{ psf} (10''/12) + 15 \text{ psf} = 140 \text{ psf}$$

LID DESIGN

$$\text{FACTORED LOAD ON THE LID} \Rightarrow U = 1.2(140 \text{ psf}) + 1.6(100 \text{ psf}) = 328 \text{ psf}$$

LOAD ON CENTER COLUMN \Rightarrow

$$c/d = 8'/48' = 0.167 \quad (\text{ASSUME A DROP PANEL LENGTH OF } 8')$$

FOR TABLE A-13, LOAD COEF. = 1.463

$$\text{LOAD} = 328 \text{ psf} (24')^2 (1.463) = 276.4 \text{ K}$$

$$\text{COLUMN LOAD} = 276.4 \text{ K} \checkmark$$

$$\text{LOAD DIRECTLY APPLIED ABOVE DROP PANEL} = \pi (8')^2 / 4 (328 \text{ psf}) = 16.5 \text{ K}$$

$$\text{SHEAR AT FACE OF COLUMN} = V_{\text{COLUMN}} = 276.4 \text{ K}$$

$$\text{SHEAR AT FACE OF DROP PANEL} = V_{\text{DROP PANEL}} = 276.4 \text{ K} - 16.5 \text{ K} = 260 \text{ K}$$

SHEAR CAPACITY:


$$\text{@ COLUMN} \Rightarrow b_o = \pi (30 \text{ in} + 13.5) = 105.2 \text{ in}$$

TRY 6" DROP PANEL

$$\phi V_c = 4 \sqrt{4,500} (105.2 \text{ in})(13.5)(0.75) = 286 \text{ K} > 276.4 \text{ K} \checkmark \text{ GOOD}$$

$$\text{@ DROP PANEL} \Rightarrow b_o = \pi (46 \text{ in} + 7.5) = 326 \text{ in}$$

$$\phi V_c = \left(\frac{40(7.5)}{326} + 2 \right) \sqrt{4,500} (326 \text{ in})(7.5 \text{ in})(0.75) = 359 \text{ K} > 260 \text{ K} \checkmark \text{ GOOD}$$

 \therefore TRY

TANK LID (CONT'D)

RADIAL MOMENTS (TABLE A-18) SEE ATTACHED TABLE FOR COEF. + MOMENT CALC.

$$c/d = 20/24 = 0.83 \therefore \text{USE } 0.05$$

$$pR^2 = 328 \text{ psf} (24')^2 = 188,928 \text{ ft-lb/ft}$$

NEGATIVE MOMENT (TOP BARS):

MAX OCCURS AT FACE OF COLUMN $= M_u = 69,110 \text{ lb-ft}$

$$R_n = 12(69,110 \text{ lb-ft}) / 0.9(12" \times 3.5")^2 = 421.3$$

$$\rho = \frac{0.85(4.5)}{60} \left(1 - \sqrt{1 - \frac{2(421.3)}{0.85(4,500)}} \right) = 0.0075$$

$$\rho_{\text{max}} \text{ FOR } \phi = 0.9 = 0.319(0.83) \left(\frac{4.5}{60} \right) = 0.019 > 0.0129 \therefore \text{OK.}$$

$$A_s \text{ REQ'D} = 0.0075(12" \times 3.5") = 1.22 \text{ in}^2/\text{ft}$$

$$\text{TOTAL } A_s = 1.7(\pi)(1.22 \text{ in}^2/\text{ft}) = 6.49 \text{ in}^2$$

CHECK MOMENT AT FACE OF DROP PANEL:

$$4/24 = 0.167 \therefore \text{USE } 0.15 \therefore M_u = 12,091 \text{ lb-ft}$$

$$R_n = 12(12,091 \text{ lb-ft}) / 0.9(12" \times 7.5")^2 = 239$$

$$\rho = \frac{0.85(4.5)}{60} \left(1 - \sqrt{1 - \frac{2(239)}{0.85(4,500)}} \right) = 0.0041$$

$$A_s \text{ REQ'D} = 0.0041(12" \times 7.5") = 0.37 \text{ in}^2/\text{ft}$$

$$\text{TOTAL } A_s = 8'(\pi)(0.37 \text{ in}^2/\text{ft}) = 9.29 \text{ in}^2$$

$$\text{USE (20) \#7 BARS } A_s = 12 \text{ in}^2$$

$$A_{s \text{ min}} \text{ FOR FLEXURE} = \frac{200(8' \times 12)(\pi \times 7.5)}{60,000} = 7.54 \text{ in}^2$$

\therefore USE (20) #7 BARS (TOP OF SLAB)

SLAB INFLECTION POINT $\approx 0.25(24) = 6'-0"$

\therefore RUN TOP BARS 40" PAST 6'-0" SAY 11' FROM CENTER

40" \nearrow
+1.5'

TANK LID (CONT'D)

RADIAL MOMENTS (CONT'D)

POSITIVE MOMENT: (BOTTOM BARS)

MAX MOMENT PER SEGMENT OCCURS @ 0.7R. $0.7(24) = 16.8'$

$\therefore M_u = 10,700 \text{ lb-ft}$

$R_n = 12(10,700 \text{ lb-ft}) / 0.9(12')(7.5')^2 = 211$

$\rho = \frac{0.85(4.5)}{60} \left(1 - \sqrt{1 - \frac{2(211)}{0.85(4,500)}} \right) = 0.0036$

$A_{s \text{ req'd}} = 0.0036(12')(7.5') = 0.33 \text{ in}^2/\text{ft}$

TOTAL $A_s = 33.6(\pi)(0.33 \text{ in}^2/\text{ft}) = 35.8 \text{ in}^2$ ✓ CONTROLS

$A_{s \text{ min FOR FLEXURE}} = \frac{200}{60,000} (33.6)(12)(\pi)(7.5) = 31.6 \text{ in}^2$

TRY #6 BARS $\rightarrow 35.8 \text{ in}^2 / 0.44 \text{ in}^2/\text{BAR} = 82 \text{ BARS}$

BAR SPACING @ $33.6(\pi) / 82 = 15''$

USE (82) #6 BARS

TANGENTIAL MOMENTS

NEGATIVE REINF. @ DROP PANEL: (TOP STEEL)

$M_u = 24,126 \text{ lb-ft}$

$R_n = 12(24,126 \text{ lb-ft}) / 0.9(12')(12.5')^2 = 171$

$\rho = \frac{0.85(4.5)}{60} \left(1 - \sqrt{1 - \frac{2(171)}{0.85(4,500)}} \right) = 0.0029$

$A_{s \text{ req'd}} = 0.0029(12')(13.5') = 0.473 \text{ in}^2/\text{ft}$

$A_{s \text{ min}} = \frac{200}{60,000} (12')(13.5') = 0.54 \text{ in}^2/\text{ft}$

USE #7 @ 12" o.c. EXTEND 5'-0" INTO LID

TANK LID (CONT'D)TANGENTIAL MOMENTS (CONT'D)

NEGATIVE REINF. @ TOP SLAB: (TOP STEEL)

WORST CASE MOMENT OCCURS @ 0.2R (4.8) $M_0 = 14.85 \text{ K-FT}$

$$R_n = 12(14,850 \text{ lb-ft}) / 0.9(12" \times 6.5")^2 = 390.5$$

$$\rho = \frac{0.85(4.5)}{60} \left(1 - \sqrt{1 - \frac{2(391)}{0.85(4,500)}} \right) = 0.0069$$

$$A_{s \text{ req'd}} = 0.0069(12")(6.5") = 0.537 \text{ in}^2/\text{FE}$$

 \therefore USE #7 @ 12" O.C.

EXTEND REINFORCING $0.5(24) + 2' = 14'-0"$
 \uparrow
 INFLECTION POINT

POSITIVE REINF. @ TOP SLAB: (BOTTOM STEEL)

WORST CASE MOMENT = $M_0 = 4,742 \text{ K-FT}$

$$R_n = 12(4,742 \text{ lb-ft}) / 0.9(12")^2(6.5")^2 = 125$$

$$\rho = \frac{0.85(4.5)}{60} \left(1 - \sqrt{1 - \frac{2(125)}{0.85(4,500)}} \right) = 0.0021$$

$$A_{s \text{ req'd}} = 0.0021(12")(6.5") = 0.165 \text{ in}^2/\text{FE}$$

$$A_{s \text{ min}} = \frac{200}{60,000}(12")(6.5") = 0.26 \text{ in}^2/\text{FE} \checkmark \text{ CONTROLS}$$

 \therefore USE #5 @ 12" O.C.

188928 ft-lb/ft = pR²

Tank Lid Moments

Point	Radial Coefficient	Radial Moment	Radial Moment Per Segment	Tangential Coefficient	Tangential Moment
0.05	-0.3658	-69110	-3455	-0.0731	-13811
0.1	-0.1388	-26223	-2622	-0.1277	-24126
0.15	-0.064	-12091	-1814	-0.104	-19649
0.2	-0.0221	-4175	-835	-0.0786	-14850
0.25	0.0058	1096	274	-0.0569	-10750
0.3	0.0255	4818	1445	-0.0391	-7387
0.4	0.0501	9465	3786	-0.0121	-2286
0.5	0.0614	11600	5800	0.0061	1152
0.6	0.0629	11884	7130	0.0175	3306
0.7	0.0566	10693	7485	0.0234	4421
0.8	0.0437	8256	6605	0.0251	4742
0.9	0.0247	4667	4200	0.0228	4308
1	0	0	0	0.0168	3174

COLUMN DESIGNLOADS

LOAD ON COLUMN USES PCA TABLE A-13 COEFF = 1.463

$$P_1 \Rightarrow \begin{cases} \text{DEAD LOAD} = 140 \text{ psf} (24')^2 (1.463) = 118 \text{ K} \\ \text{SNOW LOAD} = 100 \text{ psf} (24')^2 (1.463) = 84.3 \text{ K} \\ \text{VERT. SEISMIC} = 0.2 (0.841) (118 \text{ K}) = 19.8 \text{ K} \end{cases}$$

$$H = \pi (1.0) (6.24 \text{ pcf}) (10' / \pi) + 0.4 (0.841) (1.25) (\pi (1.67')^2 / 4) (150 \text{ pcf}) = 135 \text{ pcf}$$

WEIGHT OF WATER
PER PCA SEISMIC MANUAL
SEL. 5.3

WEIGHT OF COLUMN

USE 18" Ø COLUMN W/ (8) #6 BARSFIND TRANSVERSE REINF. \Rightarrow PER ACI 308 CH. 21.4.4

$$\rho_s = 0.12 (4,500) / 60,000 = 0.009$$

$$\text{SPACING} \Rightarrow 15' / 4 = 4.5 \text{ in}$$

$$6 (\#6) = 4.5 \text{ in}$$

$$S_x = 4 + \left(\frac{14 - 14}{3} \right) = 4 \text{ in} \checkmark \text{ CONTROLS}$$

$$\text{PER 10.9.3 } \rho_s \Rightarrow A_g = \pi (18'')^2 / 4 = 254 \text{ in}^2$$

$$A_{ch} = \pi (14'')^2 / 4 = 154 \text{ in}^2$$

$$\rho_s = 0.45 \left(\frac{254}{154} - 1 \right) \frac{4.5}{60} = 0.022 \checkmark \text{ CONTROLS}$$

$$\text{REQ'D PITCH OF \#3 SPIRAL} = 0.022 = \frac{0.11 (\pi) (13.625)}{154 (S)}$$

$$S_{REQ'D} = 1.39 \text{ in}$$

$$\text{REQ'D PITCH OF \#4 SPIRAL} = 0.022 = \frac{0.20 (\pi) (13.50)}{154 (S)}$$

$$S_{REQ'D} = 2.5 \text{ in} \checkmark$$

$$\text{SPACING OF \#3 HOOPS} = 0.009 = \frac{0.11 (\pi) (13.625)}{154 (S)} = 3.39 \text{ in}$$

USE #4 SPIRAL W/ 2.5" PITCH

OR #3 HOOPS @ 3" O.C.

Title Block Line 1
 You can changes this area
 using the "Settings" menu item
 and then using the "Printing &
 Title Block" selection.
 Title Block Line 6

Project Title:
 Engineer:
 Project Descr:

Project ID:

Printed: 3/14/2016 9:15:44

Concrete Column

Projects 2015\15068 - Uintah 200K Gal Reservoir #3 Rebuild\Engineering\Calculations\Other\15068 uintah res#3.ecb
 ENERCALC, INC. 1983-2015, Build:6.15.2.17, Ver:6.15.2.17

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Typical Center Column

Code References

Calculations per ACI 318-05, IBC 2006, CBC 2007, ASCE 7-05
 Load Combinations Used: 2006 IBC & ASCE 7-05

General Information

f_c : Concrete 28 day strength = 4.50 ksi
 E = 3,823.68 ksi
 Density = 145.0 pcf
 β = 0.8250
 f_y - Main Rebar = 60.0 ksi
 E - Main Rebar = 29,000.0 ksi
 Allow. Reinforcing Limits *ASTM A615 Bars Used*
 Min. Reinf. = 1.0 %
 Max. Reinf. = 8.0 %


Load Combination: 2006 IBC & ASCE 7-05

Overall Column Height = 16.50 ft
 End Fixity Top & Bottom Pinned
 Brace condition for deflection (buckling) along columns:
 X-X (width) axis:
 Unbraced Length for X-X Axis buckling = 16.50 ft, $K = 1.0$
 Y-Y (depth) axis:
 Unbraced Length for X-X Axis buckling = 16.50 ft, $K = 1.0$

Column Cross Section

Column Dimensions: 18.0in Diameter, Column Edge to Rebar Edge
 Cover = 2.0in

Column Reinforcing: 8.0 - #6 bars



Applied Loads

Entered loads are factored per load combinations specified by user.

Column self weight included: 4,227.90 lbs * Dead Load Factor

AXIAL LOADS . . .

Axial Load at 16.50 ft above base, $X_{ecc} = 3.0in$, $Y_{ecc} = 3.0in$, $D = 118.0$, $S = 84.30$, $E = 19.80$ k

BENDING LOADS . . .

Lat. Uniform Load creating M_{x-x} , $E = 0.1380$ k/ft

DESIGN SUMMARY

Load Combination +1.20D+0.50L+1.60S
 Location of max. above base 16.389 ft
Maximum Stress Ratio **0.698 : 1**
 $Ratio = (P_u^2 + M_u^2)^{.5} / (\phi P_n^2 + \phi M_n^2)^{.5}$
 $P_u = 281.553$ k $\phi * P_n = 402.015$ k
 $M_{u-x} = -68.656$ k-ft $\phi * M_{n-x} = -98.312$ k-ft
 $M_{u-y} = -68.656$ k-ft $\phi * M_{n-y} = 98.312$ k-ft
 M_u Angle = 45.0 deg
 M_u at Angle = 97.094 k-ft ϕM_n at Angle = 139.203 k-ft

P_n & M_n values located at P_u - M_u vector intersection with capacity curve

Column Capacities . . .

P_{nmax} : Nominal Max. Compressive Axial Capacity 1,171.08 k
 P_{nmin} : Nominal Min. Tension Axial Capacity -211.20 k
 ϕP_n , max: Usable Compressive Axial Capacity 696.79 k
 ϕP_n , min: Usable Tension Axial Capacity -147.840 k

Maximum SERVICE Load Reactions . .

Top along Y-Y 3.065 k Bottom along Y-Y 3.065 k
 Top along X-X 3.501 k Bottom along X-X 3.065 k

Maximum SERVICE Load Deflections . . .

Along Y-Y -0.07814 in at 9.634 ft above base
 for load combination: +D+S
 Along X-X -0.07814 in at 9.634 ft above base
 for load combination: +D+S

General Section Information . $\phi = 0.70$ $\beta = 0.8250$ $\theta = 0.850$

ρ : % Reinforcing 1.383 % Rebar % Ok
 Reinforcing Area 3.520 in²
 Concrete Area 254.469 in²

Title Block Line 1
 You can change this area
 using the "Settings" menu item
 and then using the "Printing &
 Title Block" selection.
 Title Block Line 6

Project Title:
 Engineer:
 Project Descr:

Project ID:

Printed: 3/14/2015 9:30:41

Concrete Column

Projects 2015\15068 - Uintah 200K Gal Reservoir #3 Rebuild\Engineering\Calculations\Other\15068 uintah res#3.ec6
 ENERCALC, INC. 1983-2015, Build:6.15.2.17, Ver:6.15.2.17

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Typical Center Column

Governing Load Combination Results

Governing Factored Load Combination	Moment Source		Dist. from base ft	Axial Load k			Bending Analysis					k-ft		Utilization Ratio
	X-X	Y-Y		Pu	$\phi * Pn$	δx	$\delta x * Mu_x$	δy	$\delta y * Mu_y$	Alpha (deg)	δMu	ϕMn		
+1.40D	Actual	Actual	16.39	171.12	409.80	1.000	-41.02	1.000	-41.02	45.000	58.02	138.48	0.419	
+1.20D+0.50Lr+1.60L+1.60H	Actual	Actual	16.39	146.67	409.80	1.000	-35.16	1.000	-35.16	45.000	49.73	138.48	0.359	
+1.20D+0.50L+0.50S+1.60H	Actual	Actual	16.39	188.82	405.87	1.000	-45.63	1.000	-45.63	45.000	64.53	138.85	0.465	
+1.20D+1.60Lr+0.50L	Actual	Actual	16.39	146.67	409.80	1.000	-35.16	1.000	-35.16	45.000	49.73	138.48	0.359	
+1.20D+1.60Lr+0.50L+0.80W	Actual	Actual	16.39	146.67	409.80	1.000	-35.16	1.000	-35.16	45.000	49.73	138.48	0.359	
+1.20D+0.50L+1.60S	Actual	Actual	16.39	281.55	402.01	1.000	-68.66	1.000	-68.66	45.000	97.09	139.20	0.698	
+1.20D+0.50L+1.60S+0.80W	Actual	Actual	16.39	281.55	402.01	1.000	-68.66	1.000	-68.66	45.000	97.09	139.20	0.698	
+1.20D+0.50Lr+0.50L+1.60W	Actual	Actual	16.39	146.67	409.80	1.000	-35.16	1.000	-35.16	45.000	49.73	138.48	0.359	
+1.20D+0.50L+0.50S+1.60W	Actual	Actual	16.39	188.82	405.87	1.000	-45.63	1.000	-45.63	45.000	64.53	138.85	0.465	
+1.20D+0.50L+0.20S+E	Actual	Actual	16.39	183.33	405.87	1.246	-54.98	1.000	-44.27	45.000	70.58	138.85	0.505	
+0.90D+1.60W+1.60H	Actual	Actual	16.39	110.01	409.80	1.000	-26.37	1.000	-26.37	45.000	37.30	138.48	0.269	
+0.90D+E+1.60H	Actual	Actual	16.39	129.81	405.87	1.162	-36.22	1.000	-31.29	45.000	47.86	138.85	0.343	

Note: Only non-zero reactions are listed.

Maximum Reactions

Load Combination	Reaction along X-X Axis		Reaction along Y-Y Axis		Axial Reaction @ Base
	@ Base	@ Top	@ Base	@ Top	
D Only	1.788	1.788 k	1.788	1.788 k	118.000 k
+D+L	1.788	1.788 k	1.788	1.788 k	118.000 k
+D+Lr	1.788	1.788 k	1.788	1.788 k	118.000 k
+D+S	3.065	3.065 k	3.065	3.065 k	202.300 k
+D+0.750Lr+0.750L	1.788	1.788 k	1.788	1.788 k	118.000 k
+D+0.750L+0.750S	2.746	2.746 k	2.746	2.746 k	181.225 k
+D+W	1.788	1.788 k	1.788	1.788 k	118.000 k
+D+0.70E	1.201	2.795 k	1.998	1.998 k	131.860 k
+D+0.750Lr+0.750L+0.750W	1.788	1.788 k	1.788	1.788 k	118.000 k
+D+0.750L+0.750S+0.750W	2.746	2.746 k	2.746	2.746 k	181.225 k
+D+0.750Lr+0.750L+0.5250E	1.348	2.543 k	1.945	1.945 k	128.395 k
+D+0.750L+0.750S+0.5250E	2.306	3.501 k	2.903	2.903 k	191.620 k
+0.60D+W	1.073	1.073 k	1.073	1.073 k	70.800 k
+0.60D+0.70E	0.486	2.080 k	1.283	1.283 k	84.660 k
D Only	1.788	1.788 k	1.788	1.788 k	118.000 k
Lr Only		k		k	k
L Only		k		k	k
S Only	1.277	1.277 k	1.277	1.277 k	84.300 k
W Only		k		k	k
E Only	0.839	1.439 k	0.300	0.300 k	19.800 k
H Only		k		k	k

Maximum Deflections for Load Combinations

Load Combination	Max. X-X Deflection		Max. Y-Y Deflection	
	Distance	Distance	Distance	Distance
D Only	-0.0456 in	9.634 ft	-0.046 in	9.634 ft
+D+L	-0.0456 in	9.634 ft	-0.046 in	9.634 ft
+D+Lr	-0.0456 in	9.634 ft	-0.046 in	9.634 ft
+D+S	-0.0781 in	9.634 ft	-0.078 in	9.634 ft
+D+0.750Lr+0.750L	-0.0456 in	9.634 ft	-0.046 in	9.634 ft
+D+0.750L+0.750S	-0.0700 in	9.634 ft	-0.070 in	9.634 ft
+D+W	-0.0456 in	9.634 ft	-0.046 in	9.634 ft
+D+0.70E	-0.0509 in	9.634 ft	-0.043 in	9.856 ft
+D+0.750Lr+0.750L+0.750W	-0.0456 in	9.634 ft	-0.046 in	9.634 ft
+D+0.750L+0.750S+0.750W	-0.0700 in	9.634 ft	-0.070 in	9.634 ft
+D+0.750Lr+0.750L+0.5250E	-0.0496 in	9.634 ft	-0.044 in	9.745 ft
+D+0.750L+0.750S+0.5250E	-0.0740 in	9.634 ft	-0.068 in	9.745 ft
+0.60D+W	-0.0273 in	9.634 ft	-0.027 in	9.634 ft
+0.60D+0.70E	-0.0327 in	9.634 ft	-0.025 in	10.077 ft
D Only	-0.0456 in	9.634 ft	-0.046 in	9.634 ft
Lr Only	0.0000 in	0.000 ft	0.000 in	0.000 ft
L Only	0.0000 in	0.000 ft	0.000 in	0.000 ft
S Only	-0.0326 in	9.634 ft	-0.033 in	9.634 ft

Title Block Line 1
 You can change this area
 using the "Settings" menu item
 and then using the "Printing &
 Title Block" selection.
 Title Block Line 6

Project Title:
 Engineer:
 Project Descr:

Project ID:

Printed: 9 MAR 2015, 9:35AM

Concrete Column

Projects 2015\15068 - Uintah 200K Gal Reservoir #3 Rebuild\Engineering\Calculations\Other\15068 uintah res#3.ec6
 ENERCALC, INC. 1983-2015, Build:6.15.2.17, Ver:6.15.2.17

Lic. #: KW-06002489


Licensee: ARW ENGINEERS

Description: Typical Center Column

Maximum Deflections for Load Combinations

Load Combination	Max. X-X Deflection	Distance	Max. Y-Y Deflection	Distance
W Only	0.0000 in	0.000 ft	0.000 in	0.000 ft
E Only	-0.0076 in	9.634 ft	0.005 in	6.866 ft
H Only	0.0000 in	0.000 ft	0.000 in	0.000 ft


Sketches



Interaction Diagrams


Concrete Column P-M Interaction Diagram

Phi * Mn @ Alpha (k-ft)



Concrete Column P-M Interaction Diagram

Phi * Mn @ Alpha (k-R)



Title Block Line 1
 You can change this area
 using the "Settings" menu item
 and then using the "Printing &
 Title Block" selection.
 Title Block Line 6

Project Title:
 Engineer:
 Project Descr:

Project ID:

Printed: 9 MAR 2015 9:35AM





Concrete Column

jects 2015\15068 - Uintah 200K Gal Reservoir #3 Rebuild\Engineering\Calculations\Other\15068 uintah res#3.ec6
 ENERCALC, INC. 1983-2015, Build:6.15.2.17, Ver:6.15.2.17

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Typical Center Column



Title Block Line 1
 You can changes this area
 using the "Settings" menu item
 and then using the "Printing &
 Title Block" selection.
 Title Block Line 6

Project Title:
 Engineer:
 Project Descr:

Project ID:

Printed: 9/18/2015 9:35AM

Concrete Column

jects 2015\15068 - Uintah 200K Gal Reservoir #3 Rebuild\Engineering\Calculations\Other\15068 uintah res#3.ec6
 ENERCALC, INC. 1983-2015, Build:6.15.2.17, Ver:6.15.2.17


Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Typical Center Column


Concrete Column P-M Interaction Diagram

Phi * Mn @ Alpha (k-ft)



Concrete Column P-M Interaction Diagram

Phi * Mn @ Alpha (k-ft)



Title Block Line 1
 You can change this area
 using the "Settings" menu item
 and then using the "Printing &
 Title Block" selection.
 Title Block Line 6

Project Title:
 Engineer:
 Project Descr:

Project ID:

General Footing

Projects 2015\15068 - Uintah 200K Gal Reservoir #3 Rebuild\Engineering\Calculations\Other\15068 uintah res#3.ec6
 ENERCALC, INC. 1983-2015, Build:6.15.2.17, Ver:6.15.2.17

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Center Column Footing

DESIGN SUMMARY

Design OK

	Min. Ratio	Item	Applied	Capacity	Governing Load Combination
PASS	0.8643	Soil Bearing	3,457 ksf	4.0 ksf	+D+S+H about Z-Z axis
PASS	n/a	Overturing - X-X	0.0 k-ft	0.0 k-ft	No Overturing
PASS	n/a	Overturing - Z-Z	0.0 k-ft	0.0 k-ft	No Overturing
PASS	n/a	Sliding - X-X	0.0 k	0.0 k	No Sliding
PASS	n/a	Sliding - Z-Z	0.0 k	0.0 k	No Sliding
PASS	n/a	Uplift	0.0 k	0.0 k	No Uplift
PASS	0.6622	Z Flexure (+X)	35,310 k-ft	53,323 k-ft	+1.20D+0.50L+1.60S+1.60H
PASS	0.6622	Z Flexure (-X)	35,310 k-ft	53,323 k-ft	+1.20D+0.50L+1.60S+1.60H
PASS	0.6622	X Flexure (+Z)	35,310 k-ft	53,323 k-ft	+1.20D+0.50L+1.60S+1.60H
PASS	0.6622	X Flexure (-Z)	35,310 k-ft	53,323 k-ft	+1.20D+0.50L+1.60S+1.60H
PASS	0.02158	1-way Shear (+X)	68,658 psi	3,181.98 psi	+1.20D+0.50L+1.60S+1.60H
PASS	0.02158	1-way Shear (-X)	68,658 psi	3,181.98 psi	+1.20D+0.50L+1.60S+1.60H
PASS	0.02158	1-way Shear (+Z)	68,658 psi	3,181.98 psi	+1.20D+0.50L+1.60S+1.60H
PASS	0.02158	1-way Shear (-Z)	68,658 psi	3,181.98 psi	+1.20D+0.50L+1.60S+1.60H
PASS	0.04795	2-way Punching	305,148 psi	6,363.96 psi	+1.20D+0.50L+1.60S+1.60H

Detailed Results

Soil Bearing

Rotation Axis & Load Combination...	Gross Allowable	Xecc	Zecc	Bottom, -Z	Actual Soil Bearing Stress			Actual / Allowable Ratio
					Top, +Z	Left, -X	Right, +X	
X-X, +D+H	4.0	n/a	0.0	2.139	2.139	n/a	n/a	0.535
X-X, +D+L+H	4.0	n/a	0.0	2.139	2.139	n/a	n/a	0.535
X-X, +D+Lr+H	4.0	n/a	0.0	2.139	2.139	n/a	n/a	0.535
X-X, +D+S+H	4.0	n/a	0.0	3.457	3.457	n/a	n/a	0.864
X-X, +D+0.750Lr+0.750L+H	4.0	n/a	0.0	2.139	2.139	n/a	n/a	0.535
X-X, +D+0.750L+0.750S+H	4.0	n/a	0.0	3.127	3.127	n/a	n/a	0.782
X-X, +D+0.60W+H	4.0	n/a	0.0	2.139	2.139	n/a	n/a	0.535
X-X, +D+0.70E+H	4.0	n/a	0.0	2.356	2.356	n/a	n/a	0.589
X-X, +D+0.750Lr+0.750L+0.450W+H	4.0	n/a	0.0	2.139	2.139	n/a	n/a	0.535
X-X, +D+0.750L+0.750S+0.450W+H	4.0	n/a	0.0	3.127	3.127	n/a	n/a	0.782
X-X, +D+0.750L+0.750S+0.5250E+H	4.0	n/a	0.0	3.290	3.290	n/a	n/a	0.823
X-X, +0.60D+0.60W+0.60H	4.0	n/a	0.0	1.284	1.284	n/a	n/a	0.321
X-X, +0.60D+0.70E+0.60H	4.0	n/a	0.0	1.50	1.50	n/a	n/a	0.375
Z-Z, +D+H	4.0	0.0	n/a	n/a	n/a	2.139	2.139	0.535
Z-Z, +D+L+H	4.0	0.0	n/a	n/a	n/a	2.139	2.139	0.535
Z-Z, +D+Lr+H	4.0	0.0	n/a	n/a	n/a	2.139	2.139	0.535
Z-Z, +D+S+H	4.0	0.0	n/a	n/a	n/a	3.457	3.457	0.864
Z-Z, +D+0.750Lr+0.750L+H	4.0	0.0	n/a	n/a	n/a	2.139	2.139	0.535
Z-Z, +D+0.750L+0.750S+H	4.0	0.0	n/a	n/a	n/a	3.127	3.127	0.782
Z-Z, +D+0.60W+H	4.0	0.0	n/a	n/a	n/a	2.139	2.139	0.535
Z-Z, +D+0.70E+H	4.0	0.0	n/a	n/a	n/a	2.356	2.356	0.589
Z-Z, +D+0.750Lr+0.750L+0.450W+H	4.0	0.0	n/a	n/a	n/a	2.139	2.139	0.535
Z-Z, +D+0.750L+0.750S+0.450W+H	4.0	0.0	n/a	n/a	n/a	3.127	3.127	0.782
Z-Z, +D+0.750L+0.750S+0.5250E+H	4.0	0.0	n/a	n/a	n/a	3.290	3.290	0.823
Z-Z, +0.60D+0.60W+0.60H	4.0	0.0	n/a	n/a	n/a	1.284	1.284	0.321
Z-Z, +0.60D+0.70E+0.60H	4.0	0.0	n/a	n/a	n/a	1.50	1.50	0.375

Overturing Stability

Rotation Axis & Load Combination...	Overturing Moment	Resisting Moment	Stability Ratio	Status
--	-------------------	------------------	-----------------	--------

Footing Has NO Overturing

Sliding Stability

All units k

Force Application Axis Load Combination...	Sliding Force	Resisting Force	Sliding SafetyRatio	Status
---	---------------	-----------------	---------------------	--------

Footing Has NO Sliding

Title Block Line 1
 You can changes this area
 using the "Settings" menu item
 and then using the "Printing &
 Title Block" selection.
 Title Block Line 6

Project Title:
 Engineer:
 Project Descr:

Project ID:

General Footing

jects 2015\15068 - Uintah 200K Gal Reservoir #3 Rebuild\Engineering\Calculations\Other\15068 uintah res#3.ec6
 ENERCALC, INC. 1983-2015, Build:6.15.2.17, Ver:6.15.2.17

Lic. #: KW-06002489

Licensee : ARW ENGINEERS

Description : Center Column Footing

Footing Flexure

Flexure Axis & Load Combination	Mu k-ft	Which Side ?	Tension @ Bot or Top ?	As Req'd in^2	Gvrn. As in^2	Actual As in^2	Phi*Mn k-ft	Status
X-X, +1.40D+1.60H	21.525	+Z	Bottom	0.4251910932713	Min ACI 10.5	0.790	53.323	OK
X-X, +1.40D+1.60H	21.525	-Z	Bottom	0.4251910932713	Min ACI 10.5	0.790	53.323	OK

Title Block Line 1
 You can changes this area
 using the "Settings" menu item
 and then using the "Printing &
 Title Block" selection.
 Title Block Line 6

Project Title:
 Engineer:
 Project Descr:

Project ID:

General Footing

Projects 2015\15068 - Uintah 200K Gal Reservoir #3 Rebuild\Engineering\Calculations\Other\15068 uintah res#3.ec6
 ENERCALC, INC. 1983-2015, Build:6.15.2.17, Ver:6.15.2.17

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Center Column Footing

Footing Flexure

Flexure Axis & Load Combination	Mu k-ft	Which Side ?	Tension @ Bot or Top ?	As Req'd in ²	Gvrn. As in ²	Actual As in ²	Phi*Mn k-ft	Status
X-X, +1.20D+0.50Lr+1.60L+1.60H	18.450	+Z	Bottom	0.3888	Min Temp %	0.790	53.323	OK
X-X, +1.20D+0.50Lr+1.60L+1.60H	18.450	-Z	Bottom	0.3888	Min Temp %	0.790	53.323	OK
X-X, +1.20D+1.60L+0.50S+1.60H	23.719	+Z	Bottom	0.4685256922545	Min ACI 10.5	0.790	53.323	OK
X-X, +1.20D+1.60L+0.50S+1.60H	23.719	-Z	Bottom	0.4685256922545	Min ACI 10.5	0.790	53.323	OK
X-X, +1.20D+1.60Lr+0.50L+1.60H	18.450	+Z	Bottom	0.3888	Min Temp %	0.790	53.323	OK
X-X, +1.20D+1.60Lr+0.50L+1.60H	18.450	-Z	Bottom	0.3888	Min Temp %	0.790	53.323	OK
X-X, +1.20D+1.60Lr+0.50W+1.60H	18.450	+Z	Bottom	0.3888	Min Temp %	0.790	53.323	OK
X-X, +1.20D+1.60Lr+0.50W+1.60H	18.450	-Z	Bottom	0.3888	Min Temp %	0.790	53.323	OK
X-X, +1.20D+0.50L+1.60S+1.60H	35.310	+Z	Bottom	0.6974973802601	Min ACI 10.5	0.790	53.323	OK
X-X, +1.20D+0.50L+1.60S+1.60H	35.310	-Z	Bottom	0.6974973802601	Min ACI 10.5	0.790	53.323	OK
X-X, +1.20D+1.60S+0.50W+1.60H	35.310	+Z	Bottom	0.6974973802601	Min ACI 10.5	0.790	53.323	OK
X-X, +1.20D+1.60S+0.50W+1.60H	35.310	-Z	Bottom	0.6974973802601	Min ACI 10.5	0.790	53.323	OK
X-X, +1.20D+0.50Lr+0.50L+W+1.60H	18.450	+Z	Bottom	0.3888	Min Temp %	0.790	53.323	OK
X-X, +1.20D+0.50Lr+0.50L+W+1.60H	18.450	-Z	Bottom	0.3888	Min Temp %	0.790	53.323	OK
X-X, +1.20D+0.50L+0.50S+W+1.60H	23.719	+Z	Bottom	0.4685256922545	Min ACI 10.5	0.790	53.323	OK
X-X, +1.20D+0.50L+0.50S+W+1.60H	23.719	-Z	Bottom	0.4685256922545	Min ACI 10.5	0.790	53.323	OK
X-X, +1.20D+0.50L+0.20S+E+1.60H	23.033	+Z	Bottom	0.4549697275861	Min ACI 10.5	0.790	53.323	OK
X-X, +1.20D+0.50L+0.20S+E+1.60H	23.033	-Z	Bottom	0.4549697275861	Min ACI 10.5	0.790	53.323	OK
X-X, +0.90D+W+0.90H	13.838	+Z	Bottom	0.3888	Min Temp %	0.790	53.323	OK
X-X, +0.90D+W+0.90H	13.838	-Z	Bottom	0.3888	Min Temp %	0.790	53.323	OK
X-X, +0.90D+E+0.90H	16.313	+Z	Bottom	0.3888	Min Temp %	0.790	53.323	OK
X-X, +0.90D+E+0.90H	16.313	-Z	Bottom	0.3888	Min Temp %	0.790	53.323	OK
Z-Z, +1.40D+1.60H	21.525	-X	Bottom	0.4251910932713	Min ACI 10.5	0.790	53.323	OK
Z-Z, +1.40D+1.60H	21.525	+X	Bottom	0.4251910932713	Min ACI 10.5	0.790	53.323	OK
Z-Z, +1.20D+0.50Lr+1.60L+1.60H	18.450	-X	Bottom	0.3888	Min Temp %	0.790	53.323	OK
Z-Z, +1.20D+0.50Lr+1.60L+1.60H	18.450	+X	Bottom	0.3888	Min Temp %	0.790	53.323	OK
Z-Z, +1.20D+1.60L+0.50S+1.60H	23.719	-X	Bottom	0.4685256922545	Min ACI 10.5	0.790	53.323	OK
Z-Z, +1.20D+1.60L+0.50S+1.60H	23.719	+X	Bottom	0.4685256922545	Min ACI 10.5	0.790	53.323	OK
Z-Z, +1.20D+1.60Lr+0.50L+1.60H	18.450	-X	Bottom	0.3888	Min Temp %	0.790	53.323	OK
Z-Z, +1.20D+1.60Lr+0.50L+1.60H	18.450	+X	Bottom	0.3888	Min Temp %	0.790	53.323	OK
Z-Z, +1.20D+1.60Lr+0.50W+1.60H	18.450	-X	Bottom	0.3888	Min Temp %	0.790	53.323	OK
Z-Z, +1.20D+1.60Lr+0.50W+1.60H	18.450	+X	Bottom	0.3888	Min Temp %	0.790	53.323	OK
Z-Z, +1.20D+0.50L+1.60S+1.60H	35.310	-X	Bottom	0.6974973802601	Min ACI 10.5	0.790	53.323	OK
Z-Z, +1.20D+0.50L+1.60S+1.60H	35.310	+X	Bottom	0.6974973802601	Min ACI 10.5	0.790	53.323	OK
Z-Z, +1.20D+1.60S+0.50W+1.60H	35.310	-X	Bottom	0.6974973802601	Min ACI 10.5	0.790	53.323	OK
Z-Z, +1.20D+1.60S+0.50W+1.60H	35.310	+X	Bottom	0.6974973802601	Min ACI 10.5	0.790	53.323	OK
Z-Z, +1.20D+0.50Lr+0.50L+W+1.60H	18.450	-X	Bottom	0.3888	Min Temp %	0.790	53.323	OK
Z-Z, +1.20D+0.50Lr+0.50L+W+1.60H	18.450	+X	Bottom	0.3888	Min Temp %	0.790	53.323	OK
Z-Z, +1.20D+0.50L+0.50S+W+1.60H	23.719	-X	Bottom	0.4685256922545	Min ACI 10.5	0.790	53.323	OK
Z-Z, +1.20D+0.50L+0.50S+W+1.60H	23.719	+X	Bottom	0.4685256922545	Min ACI 10.5	0.790	53.323	OK
Z-Z, +1.20D+0.50L+0.20S+E+1.60H	23.033	-X	Bottom	0.4549697275861	Min ACI 10.5	0.790	53.323	OK
Z-Z, +1.20D+0.50L+0.20S+E+1.60H	23.033	+X	Bottom	0.4549697275861	Min ACI 10.5	0.790	53.323	OK
Z-Z, +0.90D+W+0.90H	13.838	-X	Bottom	0.3888	Min Temp %	0.790	53.323	OK
Z-Z, +0.90D+W+0.90H	13.838	+X	Bottom	0.3888	Min Temp %	0.790	53.323	OK
Z-Z, +0.90D+E+0.90H	16.313	-X	Bottom	0.3888	Min Temp %	0.790	53.323	OK
Z-Z, +0.90D+E+0.90H	16.313	+X	Bottom	0.3888	Min Temp %	0.790	53.323	OK

One Way Shear

Load Combination...	Vu @ -X	Vu @ +X	Vu @ -Z	Vu @ +Z	Vu:Max	Phi Vn	Vu / Phi*Vn	Status
+1.40D+1.60H	41.854 psi	41.854 psi	41.854 psi	41.854 psi	41.854 psi	3 psi	0.01315	OK
+1.20D+0.50Lr+1.60L+1.60H	35.875 psi	35.875 psi	35.875 psi	35.875 psi	35.875 psi	3 psi	0.01127	OK
+1.20D+1.60L+0.50S+1.60H	46.12 psi	46.12 psi	46.12 psi	46.12 psi	46.12 psi	3 psi	0.01449	OK
+1.20D+1.60Lr+0.50L+1.60H	35.875 psi	35.875 psi	35.875 psi	35.875 psi	35.875 psi	3 psi	0.01127	OK
+1.20D+1.60Lr+0.50W+1.60H	35.875 psi	35.875 psi	35.875 psi	35.875 psi	35.875 psi	3 psi	0.01127	OK
+1.20D+0.50L+1.60S+1.60H	68.658 psi	68.658 psi	68.658 psi	68.658 psi	68.658 psi	3 psi	0.02158	OK
+1.20D+1.60S+0.50W+1.60H	68.658 psi	68.658 psi	68.658 psi	68.658 psi	68.658 psi	3 psi	0.02158	OK
+1.20D+0.50Lr+0.50L+W+1.60H	35.875 psi	35.875 psi	35.875 psi	35.875 psi	35.875 psi	3 psi	0.01127	OK
+1.20D+0.50L+0.50S+W+1.60H	46.12 psi	46.12 psi	46.12 psi	46.12 psi	46.12 psi	3 psi	0.01449	OK
+1.20D+0.50L+0.20S+E+1.60H	44.785 psi	44.785 psi	44.785 psi	44.785 psi	44.785 psi	3 psi	0.01408	OK
+0.90D+W+0.90H	26.906 psi	26.906 psi	26.906 psi	26.906 psi	26.906 psi	3 psi	0.008456	OK
+0.90D+E+0.90H	31.719 psi	31.719 psi	31.719 psi	31.719 psi	31.719 psi	3 psi	0.009968	OK

Title Block Line 1
 You can changes this area
 using the "Settings" menu item
 and then using the "Printing &
 Title Block" selection.
 Title Block Line 6

Project Title:
 Engineer:
 Project Descr:

Project ID:

Printed: 11/14/2016 8:42AM

jects 2015\15068 - Uintah 200K Gal Reservoir #3 Rebuild\Engineering\Calculations\Other\15068 uintah res#3.ec6
 ENERCALC, INC. 1983-2015, Build:6.15.2.17, Ver:6.15.2.17

General Footing

Lic. # : KW-06002489


Licensee : ARW ENGINEERS

Description : Center Column Footing

Punching Shear

All units k

Load Combination...	Vu	Phi*Vn	Vu / Phi*Vn	Status
+1.40D+1.60H	186.019 psi	6 psi	0.02923	OK
+1.20D+0.50Lr+1.60L+1.60H	159.444 psi	6 psi	0.02505	OK
+1.20D+1.60L+0.50S+1.60H	204.977 psi	6 psi	0.03221	OK
+1.20D+1.60Lr+0.50L+1.60H	159.444 psi	6 psi	0.02505	OK
+1.20D+1.60Lr+0.50W+1.60H	159.444 psi	6 psi	0.02505	OK
+1.20D+0.50L+1.60S+1.60H	305.148 psi	6 psi	0.04795	OK
+1.20D+1.60S+0.50W+1.60H	305.148 psi	6 psi	0.04795	OK
+1.20D+0.50Lr+0.50L+W+1.60H	159.444 psi	6 psi	0.02505	OK
+1.20D+0.50L+0.50S+W+1.60H	204.977 psi	6 psi	0.03221	OK
+1.20D+0.50L+0.20S+E+1.60H	199.046 psi	6 psi	0.03128	OK
+0.90D+W+0.90H	119.583 psi	6 psi	0.01879	OK
+0.90D+E+0.90H	140.972 psi	6 psi	0.02215	OK

CONTINUOUS WALL FOOTING

$$\text{LID LOADS} \Rightarrow \text{DL} = 140 \text{ psf}(25')(1/2) = 1,750 \text{ PLF}$$

$$\text{SL} = 100 \text{ psf}(25')(1/2) = 1,250 \text{ PLF}$$

$$\text{WALL WEIGHT} \Rightarrow \text{DL} = 150 \text{ psf}(16.83') = 2,525 \text{ PLF}$$

$$\text{TOTAL LOADS} \Rightarrow \text{DL} = 1,750 + 2,525 = 4,275 \text{ PLF}$$

$$\text{SL} = 1,250 \text{ PLF}$$

USE 3'-0" x 16" FOOTING W/ #6 BARS @ 2" oc. EA WAY

Title Block Line 1
 You can change this area
 using the "Settings" menu item
 and then using the "Printing &
 Title Block" selection.
 Title Block Line 6

Project Title:
 Engineer:
 Project Descr:

Project ID:

Printed: 11 MAR 2015, 3:42PM

Wall Footing

Projects 2015\15068 - Uintah 200K Gal Reservoir #3 Rebuild\Engineering\Calculations\Other\15068 uintah res#3.ec6
 ENERCALC, INC. 1983-2015, Build:6.15.2.17, Ver:6.15.2.17

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Typical Wall Footing

Code References

Calculations per ACI 318-05, IBC 2006, CBC 2007, ASCE 7-05
 Load Combinations Used: ASCE 7-10

General Information

Material Properties

f_c : Concrete 28 day strength	=	4,500.0 ksi
f_y : Rebar Yield	=	60.0 ksi
E_c : Concrete Elastic Modulus	=	3,122.0 ksi
Concrete Density	=	145.0 pcf
ϕ Values Flexure	=	0.90
Shear	=	0.750

Analysis Settings

Min Steel % Bending Reinf.	=	
Min Allow % Temp Reinf.	=	0.00180
Min. Overturning Safety Factor	=	1.0 : 1
Min. Sliding Safety Factor	=	1.0 : 1
AutoCalc Footing Weight as DL	:	No

Soil Design Values

Allowable Soil Bearing	=	4.0 ksf
Increase Bearing By Footing Weight	=	No
Soil Passive Resistance (for Sliding)	=	250.0 pcf
Soil/Concrete Friction Coeff.	=	0.30

Increases based on footing Depth

Reference Depth below Surface	=	0.0 ft
Allow. Pressure Increase per foot of depth when base footing is below	=	0.0 ksf
	=	0.0 ft

Increases based on footing Width

Allow. Pressure Increase per foot of width when footing is wider than	=	0.0 ksf
	=	0.0 ft


Dimensions

Footing Width	=	3.0 ft
Wall Thickness	=	12.0 in
Wall center offset from center of footing	=	0 in

Footing Thickness	=	16.0 in
Rebar Centerline to Edge of Concrete.. at Bottom of footing	=	3.0 in

Reinforcing

Bars along X-X Axis	=	12.00
Bar spacing	=	# 6
Reinforcing Bar Size	=	



Applied Loads

	D	Lr	L	S	W	E	H
P: Column Load	=	4.280	0.0	0.0	1.250	0.0	0.0 k
OB: Overburden	=	0.0	0.0	0.0	0.0	0.0	0.0 ksf
V-x	=	0.0	0.0	0.0	0.0	0.0	0.0 k
M-zz	=	0.0	0.0	0.0	0.0	0.0	0.0 k-ft
Vx applied	=	0.0 in above top of footing					

DESIGN SUMMARY

Design OK

	Min. Ratio	Item	Applied	Capacity	Governing Load Combination
PASS	0.4608	Soil Bearing	1.843 ksf	4.0 ksf	+D+S+H
PASS	n/a	Overturning - Z-Z	0.0 k-ft	0.0 k-ft	No Overturning
PASS	n/a	Sliding - X-X	0.0 k	0.0 k	No Sliding
PASS	n/a	Uplift	0.0 k	0.0 k	No Uplift
PASS	0.04621	Z Flexure (+X)	1.189 k-ft	25.739 k-ft	+1.20D+0.50L+1.60S+1
PASS	0.02494	Z Flexure (-X)	0.6420 k-ft	25.739 k-ft	+0.90D+E+0.90H
PASS	n/a	1-way Shear (+X)	0.0 psi	3,181.98 psi	n/a
PASS	0.0	1-way Shear (-X)	0.0 psi	0.0 psi	n/a

Title Block Line 1
 You can change this area
 using the "Settings" menu item
 and then using the "Printing &
 Title Block" selection.
 Title Block Line 6

Project Title:
 Engineer:
 Project Descr:

Project ID:

Printed: 11-MAR-2015 3:45PM

Projects 2015\15088 - Uintah 200K Gal Reservoir #3 Rebuild\Engineering\Calculations\Other\15088 uintah res#3.ecd

ENERCALC, INC. 1983-2015, Build:6.15.2.17, Ver:6.15.2.17

Wall Footing

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Typical Wall Footing

Detailed Results

Soil Bearing

Rotation Axis & Load Combination...	Gross Allowable	Xecc	Zecc	+Z	Actual Soil Bearing Stress			Actual / Allowable Ratio
					+Z	-X	-X	
.+D+H	4.0 ksf	0.0 in			1.427 ksf	1.427 ksf	0.357	
.+D+L+H	4.0 ksf	0.0 in			1.427 ksf	1.427 ksf	0.357	
.+D+Lr+H	4.0 ksf	0.0 in			1.427 ksf	1.427 ksf	0.357	
.+D+S+H	4.0 ksf	0.0 in			1.843 ksf	1.843 ksf	0.461	
.+D+0.750Lr+0.750L+H	4.0 ksf	0.0 in			1.427 ksf	1.427 ksf	0.357	
.+D+0.750L+0.750S+H	4.0 ksf	0.0 in			1.739 ksf	1.739 ksf	0.435	
.+D+0.60W+H	4.0 ksf	0.0 in			1.427 ksf	1.427 ksf	0.357	
.+D+0.70E+H	4.0 ksf	0.0 in			1.427 ksf	1.427 ksf	0.357	
.+D+0.750Lr+0.750L+0.450W+H	4.0 ksf	0.0 in			1.427 ksf	1.427 ksf	0.357	
.+D+0.750L+0.750S+0.450W+H	4.0 ksf	0.0 in			1.739 ksf	1.739 ksf	0.435	
.+D+0.750L+0.750S+0.5250E+H	4.0 ksf	0.0 in			1.739 ksf	1.739 ksf	0.435	
.+0.60D+0.60W+0.60H	4.0 ksf	0.0 in			0.8560 ksf	0.8560 ksf	0.214	
.+0.60D+0.70E+0.60H	4.0 ksf	0.0 in			0.8560 ksf	0.8560 ksf	0.214	

Units: k-ft

Overturning Stability

Rotation Axis & Load Combination...	Overturning Moment	Resisting Moment	Stability Ratio	Status
-------------------------------------	--------------------	------------------	-----------------	--------

Footing Has NO Overturning

Sliding Stability

Force Application Axis Load Combination...	Sliding Force	Resisting Force	Sliding Safety Ratio	Status
--	---------------	-----------------	----------------------	--------

Footing Has NO Sliding

Footing Flexure

Flexure Axis & Load Combination	Mu k-ft	Which Side ?	Tension @ Bot. or Top ?	As Req'd in^2	Gvrn. As in^2	Actual As in^2	Phi*Mn k-ft	Status
.+1.40D+1.60H	0.9987	-X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.40D+1.60H	0.9987	+X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+0.50Lr+1.60L+1.60H	0.856	-X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+0.50Lr+1.60L+1.60H	0.856	+X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+1.60L+0.50S+1.60H	0.9602	-X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+1.60L+0.50S+1.60H	0.9602	+X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+1.60Lr+0.50L+1.60H	0.856	-X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+1.60Lr+0.50L+1.60H	0.856	+X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+1.60Lr+0.50W+1.60H	0.856	-X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+1.60Lr+0.50W+1.60H	0.856	+X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+0.50L+1.60S+1.60H	1.189	-X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+0.50L+1.60S+1.60H	1.189	+X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+1.60S+0.50W+1.60H	1.189	-X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+1.60S+0.50W+1.60H	1.189	+X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+0.50Lr+0.50L+W+1.60H	0.856	-X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+0.50Lr+0.50L+W+1.60H	0.856	+X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+0.50L+0.50S+W+1.60H	0.9602	-X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+0.50L+0.50S+W+1.60H	0.9602	+X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+0.50L+0.20S+E+1.60H	0.8977	-X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+1.20D+0.50L+0.20S+E+1.60H	0.8977	+X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+0.90D+W+0.90H	0.642	-X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+0.90D+W+0.90H	0.642	+X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+0.90D+E+0.90H	0.642	-X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK
.+0.90D+E+0.90H	0.642	+X	Bottom	0.3456	Min Tempo %	0.44	25.739	OK

Units: k

One Way Shear

Load Combination...	Vu @ -X	Vu @ +X	Vu:Max	Phi Vn	Vu / Phi*Vn	Status
.+1.40D+1.60H	0 psi	0 psi	0 psi	3 psi	0	OK
.+1.20D+0.50Lr+1.60L+1.60H	0 psi	0 psi	0 psi	3 psi	0	OK
.+1.20D+1.60L+0.50S+1.60H	0 psi	0 psi	0 psi	3 psi	0	OK
.+1.20D+1.60Lr+0.50L+1.60H	0 psi	0 psi	0 psi	3 psi	0	OK
.+1.20D+1.60Lr+0.50W+1.60H	0 psi	0 psi	0 psi	3 psi	0	OK
.+1.20D+0.50L+1.60S+1.60H	0 psi	0 psi	0 psi	3 psi	0	OK
.+1.20D+1.60S+0.50W+1.60H	0 psi	0 psi	0 psi	3 psi	0	OK

Title Block Line 1
You can changes this area
using the "Settings" menu item
and then using the "Printing &
Title Block" selection.
Title Block Line 6

Project Title:
Engineer:
Project Descr:

Project ID:

Printed: 11 MAR 2015 9:48AM

Wall Footing

jects 2015\15068 - Uintah 200K Gal Reservoir #3 Rebuild\Engineering\Calculations\Other\15068 uintah res#3.ec6
ENERCALC, INC. 1983-2015, Build:5.15.2.17, Ver:6.15.2.17

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Typical Wall Footing

+1.20D+0.50Lr+0.50L+W+1.60H	0 psi	0 psi	0 psi	3 psi	0	OK
+1.20D+0.50L+0.50S+W+1.60H	0 psi	0 psi	0 psi	3 psi	0	OK
+1.20D+0.50L+0.20S+E+1.60H	0 psi	0 psi	0 psi	3 psi	0	OK

Title Block Line 1
 You can changes this area
 using the *Settings* menu item
 and then using the *Printing &
 Title Block* selection.
 Title Block Line 6

Project Title:
 Engineer:
 Project Descr:

Project ID:

Printed: 11/11/2015 2:43:11

Wall Footing

jects 2015\15068 - Uintah 200K Gal Reservoir #3 Rebuild\Engineering\Calculations\Other\15068 uintah res#3.ec6
 ENERCALC, INC. 1983-2015. Build:6.15.2.17. Ver:6.15.2.17

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Typical Wall Footing

One Way Shear



Units: k

Load Combination...	Vu @ -X	Vu @ +X	Vu:Max	Phi Vn	Vu / Phi*Vn	Status
+0.90D+W+0.90H	0 psi	0 psi	0 psi	3 psi	0	OK
+0.90D+E+0.90H	0 psi	0 psi	0 psi	3 psi	0	OK

CHECK SEISMIC FORCES ON EMPTY TANK

* SEE ATTACHED SPREADSHEET FOR ADDITIONAL INFORMATION.

SOIL FORCES ON WALL

EQUIVALENT TO
(FOR INPUT IN SEISMIC SPREADSHEET)

$$M_{max} = 21.975 \text{ K-FT} @ 8.160'$$

EQUIV. W

$$21.975 \text{ K-FT} = 0.128(W)(16') \Rightarrow W = 10.68 \text{ K} \quad W = WL(1/2)$$

$$W = \frac{10.68 \text{ K}(z)}{16} = 1,335 \text{ psf}$$

$$\text{EQUIV. SOIL PRESSURE} = \frac{1,335 \text{ psf}}{16'} = 83 \text{ psf}$$

SEE SPREADSHEET: \Rightarrow RING FORCES ARE GOOD

CHECK MAX MOMENT IN WALL = 9 K-FT (WALL HAS #6 @ 12" OC.)

$$\phi M_n \Rightarrow a = \frac{0.44(60 \text{ ksi})}{0.85(4.5)(12)} = 0.575 \text{ in} \quad \phi M_n = 0.9(0.44)(60)\left(9.5 - \frac{0.575}{2}\right) = 218.9 \text{ K-in}$$

$$18.2 \text{ K-ft}$$

$$> 9 \text{ K-ft}$$

 \therefore WALL IS GOOD. ✓

Project Name Uintah Highlands Reservoir #3
 Project # 15068
 Prepared By ZCH
 Date 3/11/2015

Program Authors: TAB & DOC
 Last Revised: 10/20/2010
 Reviewed By: TAB



Circular Concrete Tanks without Prestressing

(Based on the 1993 PCA Document)

Design Criteria

f_c	4500 psi
D_{tank}	45 ft
H_{tank}	10 ft
t_{wall}	12 in
Fluid Pressure	62.4 pcf
Soil Pressure	83 pcf
E_s	29000000 psi
E_c	3823676.24 psi
n	7.6
Surcharge	100 pcf
Soil on Lid	1 ft
Load Factor	
$F_{liquid\ pressure}$	1.4
$F_{soil\ pressure}$	1.5
Environmental	
Durability Factor	
Flexure (liquid)	1.93
Tension (liquid)	1.93
Flexure (soil)	1.03
Compression (soil)	1
H^2/Dt	5.33

Estimation of Tank Wall Thickness

Limit Ring Tension Stress in Concrete Wall from 7% to 12% of f_c

For given t and H^2/Dt , with a hinged base/free top (Table A-5)

Max Coefficient= 0.624 (Table A-5)

w_u 169 pcf

T_{max} 40422 lbs

$T_{unfactored}$ 14960 lbs

$A_{s(reqd)}$ 0.75 in²

$A_{s(used)}$ 0.88 in²

OK

$F_{(soils)}$ 150 psi

This equates to 3.34 % of f_c

Wall thickness is OK

Compression Check	
F_c	482
0.33 f_c	1485
OK	

The Following Load Cases were used in Analysis:

- Load Case #1: Full of Water, No Lid, No Backfill
- Load Case #2: Empty, No Lid, w/Backfill
- Load Case #3: Empty, w/Lid, w/Backfill
- Load Case #4: Full of Water, w/Lid, Ignore Backfill

Load Case #1-Full of Water, No Lid, No Backfill

Assume Free Top/Hinged Base (Tables A-5 and A-7)

Effects of Possible outward movement will be handled by designing the entire portion of the wall for the maximum Ring Tension and Moment

Ring Force=(A-5 Coef.) w_uHR $w_uHR= 64744.2432$

Moment =(A-7 Coef.) w_uH^3 $w_uH^3= 690605.2608$

	A-5 Coef.	RF (#)	A-7 Coef.	Moment (#-ft/ft)
Top	-0.009	-583	0	0
0.1H	0.110	7143	0.0000	0
0.2H	0.231	14956	0.0001	46
0.3H	0.352	22768	0.0005	322
0.4H	0.467	30236	0.0013	921
0.5H	0.563	36473	0.0029	2003
0.6H	0.624	40422	0.0051	3522
0.7H	0.618	40034	0.0074	5110
0.8H	0.518	33516	0.0089	6123
0.9H	0.305	19747	0.0075	5157
Bottom	0.000	0	0	0

Project Name Uintah Highlands Reservoir #3
 Project # 15068
 Prepared By ZCH
 Date 3/11/2015

Program Authors: TAB & DOC
 Last Revised 1/19/2006
 Reviewed By TMD



Load Case #2-Empty, No Lid, w/ Backfill

Use Durability Coefficients as Noted Previous

Soil Over Lid= 1 ft
 ρ 100

Ring Force=(A-5 Coef.) w_{HR} +(A-6 Coef.) ρR
 w_{HR} = -98421
 ρR = -7411.2

Moment=(A-7 Coef.) $(w_{HR}h^3+\rho h^2)$
 $w_{HR}h^3+\rho h^2$ = -988496

	A-5 Coef	RF (#)	A-6 Coef.	RF (#)	Total RF (#)	A-7 Coef.	Moment (#-ft/ft)
Top	-0.009	886	0.991	-7344.4992	-6459	0	0
0.1H	0.110	-10859	1.010	-7487.7824	-18347	0.0000	0
0.2H	0.231	-22735	1.031	-7640.9472	-30376	0.0001	-66
0.3H	0.352	-34611	1.052	-7794.112	-42405	0.0005	-461
0.4H	0.467	-45962	1.067	-7907.7504	-53870	0.0013	-1318
0.5H	0.563	-55444	1.063	-7880.576	-63324	0.0029	-2867
0.6H	0.624	-61447	1.024	-7591.5392	-69039	0.0051	-5041
0.7H	0.618	-60857	0.918	-6805.952	-67663	0.0074	-7315
0.8H	0.518	-50949	0.718	-5318.7712	-56268	0.0089	-8765
0.9H	0.305	-30018	0.405	-3001.536	-33020	0.0075	-7381
Bottom	0.000	0	0.000	0	0	0	0

Load Case #3-Empty, w/Lid, w/Backfill

Apply a shear force (V) @ top of wall to make Ring Tension = 0 @ top of Wall

When top of tank is free, Ring Force (LC#2) = -6459 #

At top of wall (0.0H) from table A-8, Coefficient= -8.49 #

Therefore, the shear force (V) required to produce zero ring force at the top of the tank=
 (Coef. A-8 @ 0.0H)(VR/H)=(Ring Force from LC#2)

Therefore

V= -507 #
 VR/H= -761 #

Delta_{RF}=Change in Ring Force Due to V applied @ the top of wall

Delta_{RF}=(A-8 Coef.)(VR/H)

Find the change in moment (Delta_{mom}) due to the V applied @ top.

If S_D for moment is less than S_D for compression, then V is reduced by (S_{DM}/S_{DC})

Delta_{mom}=(A-9 Coef.)VH
 VH= -8118

	A-8 Coef.	Delta _{RF} (#)	LC#2 RF (#)	Total RF (#)	A-9 Coef.	Delta _{mom} (#-ft/ft)	LC #2 Moment (#-ft/ft)	Total Moment (#-ft/ft)
Top	-8.487	6459	-6459	0	0	0	0	0
0.1H	-5.050	3843	-18347	-14504	0.0633	-514	0	-514
0.2H	-2.390	1819	-30376	-28557	0.0753	-612	-66	-677
0.3H	-0.693	528	-42405	-41878	0.0633	-514	-461	-975
0.4H	0.187	-142	-53870	-54012	0.0433	-352	-1318	-1670
0.5H	0.510	-388	-63324	-63712	0.0247	-200	-2867	-3067
0.6H	0.510	-388	-69039	-69427	0.0107	-87	-5041	-5128
0.7H	0.363	-277	-67663	-67939	0.0020	-16	-7315	-7331
0.8H	0.190	-145	-56268	-56413	-0.0030	24	-8765	-8740
0.9H	0.043	-33	-33020	-33053	-0.0063	51	-7381	-7329
Bottom	0.000	0	0	0	-0.0093	76	0	76

Project Name Uintah Highlands Reservoir #3
 Project # 15068
 Prepared By ZCH
 Date 3/11/2015

Program Authors: TAB & DOC
 Last Revised 1/19/2006
 Reviewed By: TMD



Load Case #4-Full of Water, w/Lid, ignore Backfill

Add the effects of shear @ the top of the tank to LC #1

At the top of the wall - Coefficient from Table A-8= -8.49 #

(Coef. A-8 @ 0.0H)(VR/H) = (Ring Force from LC#1)


V= -46 #
 VR/H= -69 # (For Ring Force)
 VH= -732 # (For Moment)

	A-8 Coef.	Delta _{RF} (#)	LC#1 RF (#)	Total RF (#)	A-9 Coef.	Delta _{mom} (#-ft/ft)	LC#1 Moment (#-ft/ft)	Total Moment (#-ft/ft)
Top	-8.49	583	-583	0	0	0	0	0
0.1H	-5.05	347	7143	7490	0.063	-46	0	-46
0.2H	-2.39	164	14956	15120	0.075	-55	46	-9
0.3H	-0.69	48	22768	22816	0.063	-46	322	276
0.4H	0.19	-13	30236	30223	0.043	-32	921	889
0.5H	0.51	-35	36473	36438	0.025	-18	2003	1985
0.6H	0.51	-35	40422	40387	0.011	-8	3522	3514
0.7H	0.36	-25	40034	40009	0.002	-1	5110	5109
0.8H	0.19	-13	33516	33503	-0.003	2	6123	6126
0.9H	0.04	-3	19747	19744	-0.006	5	5157	5161
Bottom	0	0	0	0	-0.009	7	0	7

Envelope of Ring Forces

	LC#1	LC#2	LC#3	LC#4	Max	Min
Top	-583	-6459	0	0	0	-6459
0.1H	7143	-18347	-14504	7490	7490	-18347
0.2H	14956	-30376	-28557	15120	15120	-30376
0.3H	22768	-42405	-41878	22816	22816	-42405
0.4H	30236	-53870	-54012	30223	30236	-54012
0.5H	36473	-63324	-63712	36438	36473	-63712
0.6H	40422	-69039	-69427	40387	40422	-69427
0.7H	40034	-67663	-67939	40009	40034	-67939
0.8H	33516	-56268	-56413	33503	33516	-56413
0.9H	19747	-33020	-33053	19744	19747	-33053
Bottom	0	0	0	0	0	0

	Tension	Compression
Bottom	0	0
0.9H	20	-33
0.8H	34	-56
0.7H	40	-68
0.6H	40	-69
0.5H	36	-64
0.4H	30	-54
0.3H	23	-42
0.2H	15	-30
0.1H	7	-18
Top	0	-6



Project Name Uintah Highlands Reservoir #3
 Project # 15068
 Prepared By ZCH
 Date 3/11/2015

Program Authors: TAB & DOC
 Last Revised: 1/19/2006
 Reviewed By: TMD




Envelope of Moments

	LC#1	LC#2	LC#3	LC#4	Max	Min
Top	0	0	0	0	0	0
0.1H	0	0	-514	-46	0	-514
0.2H	46	-66	-677	-9	46	-677
0.3H	322	-461	-975	276	322	-975
0.4H	921	-1318	-1670	889	921	-1670
0.5H	2003	-2867	-3067	1985	2003	-3067
0.6H	3522	-5041	-5128	3514	3522	-5128
0.7H	5110	-7315	-7331	5109	5110	-7331
0.8H	6123	-8765	-8740	6126	6126	-8765
0.9H	5157	-7381	-7329	5161	5161	-7381
Bottom	0	0	76	7	76	0


~ CHECK WALL FOR THIS MOMENT

	Tension O.F.	Tension I.F.
Bottom	0	0
0.9H	5	-7
0.8H	6	-9
0.7H	5	-7
0.6H	4	-5
0.5H	2	-3
0.4H	1	-2
0.3H	0	-1
0.2H	0	-1
0.1H	0	-1
Top	0	0



Project Name Uintah Highlands Reservoir #3
 Project # 15068
 Prepared By ZCH
 Date 3/11/2015

Program Authors: TAB & DOC
 Last Revised 1/19/2006
 Reviewed By: TAB



D _{tank}	48	ft
H _L	16	ft
g	32.17	ft/s ²
λ	9.981706965	
T _C	4.361096243	s
S _{D1}	0.481	g
S _{D5}	0.841	g
T _S	0.571938169	s
C _C	0.106124558	
l	1.25	
d _{max}	3.183736748	ft

Required Freeboard


Tank Volume	203046	Gallons
Ht to Water	15	ft

New H _L	15	ft
New d _f	1	ft

Height to Liquid after Freeboard Check (IF desired to change from above)


h _n	16	ft
T	0.16	s
T _o	0.114387634	s
T _L	8	s
S _a	0.59608	g
S _a	0.841	g

height above base to highest level of structure
 Approximate Fundamental Period as Per ASCE 7 eqn 12.8-7
 Per ASCE 7
 Per ASCE 7 (fig 22-15)
 For periods less than T_o
 For periods >= to T_o and <= to T_s



Find Pressure at Roof to Shell interface from insufficient freeboard depth.

SA (T_c)	0.11029337	g	Spectral Acceleration at T_c
Theta	6.293905847	degrees	Angle of free surface at sloshing load
h_r	0	ft	height from top of wall to underside of topmost point of lid
V_{EMPTY}	1809.557368	ft ³	Empty Volume of tank above water
d	2.647040872	ft	Vertical displacement of liquid surface
d_r/d	0.37778034		
h_r/d	0		
X_i/R	0.9		Fig 6 from "Earthquake Induced Sloshing in Tanks with insufficient Freeboard"
X_i	21.6	ft	
ρ	1.94	slugs/ft ³	mass density of liquid
P_{max}	4.62	psf	Weight of Roof is heavier, therefore ok
F_{max}	49.91	plf	#5 Radial Dowels @ 16" o.c. okay (Roof Slab to Wall)



Weight

D/H_L	3.2			
W_i/W_L	0.38	PCA EB219 fig 4-4 (b)		
W_c/W_L	0.6	PCA EB219 fig 4-4 (b)		
W_L	1764 kips	Weight Of Water		
W_i	670 kips	Impulsive Weight		
W_c	1059 kips	Convective Weight		
T_w	12 inches	Wall Thickness	D_{outer}	50.00 ft
T_r	10 inches	Roof Thickness		
W_w	369 kips	Weight of Walls		
W_R	245 kips	Weight of Roof		

Period

C_w	0.147	PCA EB219 fig 4-10	
C_L	0.30		
E_c	3823.676242 ksi	Elastic Modulus of Concrete	
ρ_c	4.66 #-s/ft ³	Mass Density of Concrete	
ω_f	217.4449364 rad/s		
T_f	0.03 s		

Base Shear

R	1.5	Response Modification Factor
C_g	0.70	
$C_{si} (min)$	13.87	
C_{sc}	0.70	
$C_{sc} (min)$	0.09	
V_i	1126 kips	Impulsive Base Shear
V_c	122 kips	Convective Base Shear
V_T	1133 kips	Total Base Shear

Overturing Moment

h_i/H_L	0.38	PCA EB219 fig 4-5 (b)
h_c/H_L	0.54	PCA EB219 fig 4-5 (b)
h_i	5.7 ft	
h_c	8.1 ft	
h_w	8 ft	
M_i	7502 kip ft	Impulsive
M_c	6009 kip ft	Convective (Per ACI 350)
M_T	9612 kip ft	Total

Overall Stability Check

Sliding (Neglecting Backfill)

Weight of tank w/out contents:

Walls	369 kips
Roof	245 kips
Columns	30 kips
Base Slab	189 kips
Water	1764 kips
Total Weight	2598 kips
Friction Coeff	0.49
Base Shear	1133
Safety Factor	1.12 ok

Overturing

OTM	9612 kip ft
RM	62351 kip ft
Safety Factor	6.5 ok

Design of Walls for In-Plane Loading

V_u	1133 kips	Base Shear
V_c	12.0 kips/ft	Shear in wall
α_c	3	See ACI 318 eqn 21-7
ρ_t	0.006111	See ACI 318 eqn 21-7
ϕV_n	60.1 kips/ft	ok

#6 at 12" oc EF

PER PCA EB219 for $D \gg H$ out of plane bending effects are small and can be neglected.