



State of Utah

GARY R. HERBERT  
*Governor*

SPENCER J. COX  
*Lieutenant Governor*

Department of  
Environmental Quality

Alan Matheson  
Executive Director

DIVISION OF DRINKING WATER  
Kenneth H. Bousfield, P.E.  
*Director*

January 6, 2016

Val Surrage  
Taylor West Weber Water District  
2815 West 3300 South  
West Haven, Utah 84401

Dear Mr. Surrage,

Subject: **Plan Submittal Waiver**, Russel Place Phase 2 Water Line Project, System #29019, File #10285

The Division of Drinking Water (the Division) received a Project Notification Form from your office for the Russel Place Phase 2 water line project with a request for a Plan Submittal Waiver in accordance with *R309-500-6(3)(b)* of the Utah Administrative Code on December 29, 2015. The Division also received a hydraulic modeling analysis certification dated January 4, 2016 by Dan White, P.E., and a certification dated January 4, 2016 by Dan White, P.E., stating that Plan Submittal Waiver conditions will be met prior to placing the new water lines in service, for this project.

Our understanding of the project is that approximately 200 linear feet of C-900 PVC 8-inch water line and one (1) fire hydrant will be constructed at about 2100 South 4000 West in Taylor, Utah. This water line will add four (4) new service connections in the Russel Place Subdivision to the water system.


Your water system has formally designated Dan White, P.E., as the Professional Engineer having direct responsibility for the entire water system in your letter to the Division dated August 23, 2012; and Dan White, P.E., as the Professional Engineer responsible for oversight of the hydraulic analysis for the entire water system in your letter to the Division dated August 23, 2013. The construction of the proposed water line project shall conform to the construction standards previously approved by the Division on September 10, 2012. The pipeline size is within the limits of Rule *R309-500-6(3)(b)(ii)* based on the population of 7,073 this water system currently serves. On this basis, a **Plan Submittal Waiver is hereby granted** for the Russel Place Phase 2 water line project. Please note that approvals or permits by the local authority or county may be necessary before beginning construction of this project.

Val Surrage  
Page 2  
January 6, 2016

Upon receiving this Plan Submittal Waiver, you may proceed with construction of the Russel Place Phase 2 water line project. Upon completion of construction and the Plan Submittal Waiver conditions certified by Dan White, P.E., you may place the new water lines in service. You are not required to obtain an Operating Permit for this project.

If you have any questions regarding this letter, please contact Camron Harry, of this office, at (801) 536-0087.

Sincerely,



Kenneth H. Bousfield, P.E.  
Director

CH

cc: Louis Cooper, Environmental Director, Weber-Morgan Health Department, lcooper@co.weber.ut.us  
Val Surrage, Taylor West Weber Water District, taylorwestweberwater@msn.com  
Dan White, Gardner Engineering, dan@gardnerengineering.net  
Camron Harry, Division of Drinking Water, caharry@utah.gov

DDW-2016-000113.docx