

Weber Fire District

Plan Review

Date: July 20, 2015 Project Name: Lot 39 Summit LLC –REVIEW #2 Project Address: 8365 E Summit Pass Eden Utah 84310 Contractor/Contact: Andrea Milner 312-507-1167 | andrea@summit.co Fees:

| Property Type | Schedule Rates | Square Foot Rate | Square Feet or Number of Res. Units | Total |
|-------------------------------|----------------|------------------|-------------------------------------|---------|
| Туре | Rate | Rate/ Sq Ft | Sq Ft or # of Units | Total |
| Plan Review | Residential | | | \$50.00 |
| Residential Impact Fee | 328.15 | PAID- | | \$0.00 |
| | | | | \$0.00 |
| | | | | \$0.00 |
| | | | Total Due | \$50.00 |

FEE NOTICE:

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: <u>Weber Fire District.</u>

REVIEW STATUS: APPROVED

SPECIFIC COMMENTS:

- 1. Concerns from review #1 have been addressed. See page 98 of the second submittal.
- 2. Fire suppression system is required for this residence. The fire suppression plans may be a deferred submittal. No work on the fire suppression system may begin without approved plans and permit.
- 3. Provide a temporary address marker at the building site during construction.
- 4. Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for height, width and imposed loads as permanent roads.
- 5. All required fire hydrants and water systems shall be installed, approved and fully functional prior to any combustible construction.
- 6. Fire department apparatus access is required for each lot.

Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all applicable codes and standards. Any change or revision of this plan will render this review void and will require submittal of the new or revised layout for fire department review.

Reviewed by: Brandon Thueson Fire Marshal



Weber Fire District

Plan Review

cc: File