


From: Day, Summer sday@co.weber.ut.us
Subject: River Ranch
Date: November 30, 2015 at 3:41 PM
To: John Rhees johnrhees@gmail.com
Cc: Jason Felt JasonF@greatbasineng.com



Just in case I hadn't sent you this.

Thank you
Summer Day, LEHS
Weber-Morgan Health Department
801-399-7174



BRIAN W. BENNION, M.P.A., L.E.H.S.
Health Officer/Executive Director

November 24, 2015

Weber County Planning Commission
2380 Washington Blvd.
Ogden, UT 84401

RE: River Ranch 1st Amendment
8940 Eagle Way
Parcel #21-097-0008, 21-097-0002, & 21-098-0007
Soil log #1538 & 14171

Gentlemen:

The soil and percolation information for the above-referenced lot have been reviewed. Culinary water will be provided by a private well. The placement of the well is critical so as to provide the required 100 foot protection zone around the well. The well will need to be dug, tested and the water supply approved prior to issuance of a wastewater disposal permit.

DESIGN REQUIREMENTS

Lot 12: Has an existing home.

Lot 10 & 11

Anticipated ground water tables not to exceed 36 inches, and documented permissible soils to a depth of 24 inches but not to 48 inches below original grade, fall within the range of acceptability for the utilization of a Wisconsin Mound Wastewater Disposal System as a means of wastewater disposal. Maximum trench depth is limited to 0 inches. The absorption system is to be designed using a maximum loading rate (Basal/Hydraulic Loading Rate) of 0.32 gpd/sq. ft. as required for the sandy loam, granular structure soil horizon.

Lot 13 & 14: Anticipated ground water tables not to exceed 36 inches, and highly permeable Type I soils as classified in the Utah Administrative Rule R317-4 Onsite Wastewater Systems, fall within the range of acceptability for the utilization of a Packed Bed Media System as a means of wastewater disposal. Maximum trench depth is limited to 24 inches. The absorption system is to be designed using a maximum loading rate of 0.9 gal/sq. ft. /day as required for the gravelly coarse loamy sand, single grained structure soil horizon. Due to the size of the lots additional soil evaluation may be performed in the future.

Plans for the construction of any wastewater disposal system are to be prepared by a Utah State certified individual and submitted to this office for review prior to the issuance of a Wastewater Disposal permit.


All subdivisions plats submitted for review are to show the location of exploration pits and percolation tests as well as the documented soil horizons and percolation rates. Mylars submitted for signature without this information will be returned.

Each on-site individual wastewater disposal system must be installed in accordance with R317-4, Utah Administrative Code, Individual Wastewater Disposal Systems and Weber-Morgan District Health Department Rules. Final approval will be given only after an on-site inspection of the completed project and prior to the accomplishment of any backfilling.

Please be advised that the conditions of this letter are valid for a period of 18 months. At that time the site will be

re-evaluated in relation to rules in effect at that time.

Sincerely,


Summer Day, LEHS
Environmental Health Division
801-399-7160

EDUCATE | ENGAGE | EMPOWER

phone: 801-399-7100 | fax: 801-399-7110 | 477 23rd Street, Ogden, UT 84401 | www.webermorganshalth.org