



A NETWORK OF KINGDOM BUILDING SERVICES

building buildings. building lives.

July 7, 2011

Rochelle Pfeaster
Engineering Project Manager
Weber County Engineering Division
2380 Washington Blvd, Suit 240
Ogden, UT 84401

Engineering Review Response #2

Comment 1. How is storm water detention being handled on site?

Response: Site elevations create a natural drainage both North and West on the site. Some of the site drainage accumulates on the West of the site beyond the existing parking lot in what is currently pasture, the areas that does not drain to this area drains into a large retention basin located to the North of the property.

Adrian Ben

aben@bgwservices.com

Office: 801-409-1041