From: Jake Russell
To: Pfeaster,Rochelle;
cc: Hennon, Iris M.;
Subject: Response to questions about Russell Run Project
Date: Monday, July 11, 2011 9:21:22 AM

I received a email addressing comments about Russell's Run (dog kennel). I have addressed the following comments below.

1. Deferral on the curb, gutter and sidewalk for the property was applied for and granted when I first purchased the property and subdivided it into a one lot subdivision.

2. It is my understanding that before the ditch can be filled in I have to do the following. The ditch in front of the property requires a 15" RCP pipe before ditch is to be filled in and curb, gutter and sidewalk or grade to be brought up to a foot below the edge of asphalt until curb, gutter and sidewalk are required to be put in.

3. The alternative ditch relocated to run along West property line, I will not be asking for.

4. When asphalt is to be placed on property, requirements and tests set forth by Weber County will be adhered to.

Thank You,
Brad Russell