



WEBER-MORGAN HEALTH DEPARTMENT

GARY M. HOUSE, M.P.H.
Health Officer / Director

June 21, 2005

Division Directors
KAY LARRISON, Administration
CLAUDIA PRICE, Nursing
JOE DECARIA, Environmental Health
COLLEEN JENSEN, WIC

Judith Olson
3718 Monarca
Bountiful, UT 84010

RE: **Private Well Approval at:**
2421 N. Water Canyon
Huntsville, UT 84317

Dear Ms. Olson:

The application for approval of the above referenced well has been submitted for review to determine conformance to the Weber-Morgan District Health Department Regulations for Installation and Approval of Nonpublic Water System Serving 1-14 Connections.

The following have been submitted:

1. The Water Right Number: E4496 (35-11691)
2. Well driller license is #724
3. The well is 240 feet deep with a clay layer greater than 15 feet.
4. The well yields greater than 10 gpm with a 102 ft. draw down.
5. The water samples for the partial inorganic analysis was submitted to Chem Tech Ford Laboratory on June 6, 2005.
6. The third bacteriological water sample was collected by staff of this department on June 14, 2005. The water analysis was satisfactory.
7. This is not a shared well.

The required 100 foot protection zone around the well must be kept free from any septic tank absorption systems, garbage dumps, hazardous and toxic material storage or disposal sites, feed lots and other concentrated sources of pollution. We would recommend that a bacteriological sample be collected and submitted for analysis on an annual basis.

Based on compliance with the above requirements, the Health Department considers this an approved well for culinary purposes.

Please contact our office at 399-7160 if you have further questions.

Sincerely,

Michelle Cooke, LEHS
Division of Environmental Health