



# Weber Fire District

## Plan Review

**Date:** May 26, 2016

**Project Name:** Summit Eden Ridge Nests PRUD Amendment 2

**Project Address:** 7914 E Heartwood Drive Eden Utah

**Contractor/Contact:** Rick Everson 801-897-4880 [rick@wattsenterprises.com](mailto:rick@wattsenterprises.com)

**Fees:**

Property Type	Schedule Rates	Square Foot Rate	Square Feet or Number of Res. Units	Total
Type	Rate	Rate/ Sq Ft	Sq Ft or # of Units	Total
Plan Review	1 Lot Subdivision			\$50.00
Residential Impact Fee	328.15			\$0.00
				\$0.00
				\$0.00
			<b>Total Due</b>	<b>\$50.00</b>

**FEE NOTICE:**

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: **Weber Fire District.**

**REVIEW STATUS: APPROVED**

**SPECIFIC COMMENTS:**

1. Weber Fire District has no concerns with the amendment to the plat as indicated.

**General Requirements:**

- Roads and bridges shall be designed, constructed and maintained to support an imposed load of 75,000 lbs.
- Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for height, width and imposed loads as permanent roads.
- All required fire hydrants and water systems shall be installed, approved and fully functional prior to any combustible construction.
- Fire department apparatus access is required for each lot.

Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all applicable codes and standards. Any change or revision of this plan will render this review void and will require submittal of the new or revised layout for fire department review.

Reviewed by: Brandon Thueson  
Fire Marshal