



PERMIT TO CONSTRUCT AN ONSITE WASTEWATER TREATMENT SYSTEM

ISSUED BY THE WEBER-MORGAN HEALTH DEPARTMENT

477 23rd Street, OGDEN, UTAH 84401



Permit No.: W101258

Issued: May 11, 2016

Expires: May 11, 2017

This is to certify that **BRET DAVIS** is hereby issued a permit to install an onsite wastewater treatment system for the property with the Property Identification Number **10-048-0026** with the following specifications and provisions:

Approximate construction site address: **2069 S 7500 W, WEST WARREN**

Lot: **N/A** of the **MEAT PACKING** subdivision in **Weber county Utah**.

Water supply will be provided by: **WEST WARREN-WARREN L.D.**

Type of System will be **ABSORPTION FIELD** with an absorption area of **1500 Sq. Ft.**

Septic tank capacity must be at least **1000 gallons**. System is designed for a **0 bedroom** home.

Maximum depth of trench bottoms must be limited to **12 inches** from original ground surface.

***** IMPORTANT - PLEASE READ CAREFULLY *****

SIZED FOR MAXIMUM WATER USAGE OF 600 GPD.

MAXIMUM DEPTH TO BOTTOM OF TRENCH FROM ORIGINAL GROUND SURFACE IS 12".

MAINTAIN 100 FOOT SEPARATION FROM DITCHES.

INSTALL ACCORDING TO CONSTRUCTION PLANS REVIEWED BY THIS OFFICE.

WASHED 3/4 TO 2 1/2 INCH GRAVEL MUST BE USED. 1 INCH MINUS WILL NOT BE ACCEPTED.

WATER TIGHTNESS TEST REQUIRED. TANK MUST BE FULL AT TIME OF INSPECTION.

Please provide the permit number and address when requesting the final inspection or any additional information regarding this system.
Final inspection to be completed prior to any backfilling of installed system.

This permit may be revoked or altered if the site is found to be in a flood hazard or other geologic hazard area. This permit is based on minimum design standards, and in no case does it guarantee against the failure of the installed system. The performance of the installed system is affected by many other factors, such as operation, maintenance, wastewater contents, etc., not addressed by the standards.

Brian Cowan / gm