



NOTES:

BEFORE RELOCATING AN EXISTING WATERLINE THE CONTRACTOR SHALL NOTIFY ALL AFFECTED BUSINESSES AND RESIDENTS 24 HOURS BEFORE CONSTRUCTION. THE CONTRACTOR MUST DEMONSTRATE TO THE CITY THAT ALL OF THE MATERIALS ARE ON HAND THAT MAY BE NEEDED BEFORE RELOCATING ANY WATERLINES. RELOCATION OF WATERLINES WILL NOT BE STARTED AFTER 10:00 A.M. THE CITY SHALL OPERATE ALL MAINLINE WATER VALVES AND THE CONTRACTOR MUST CONTACT THE CITY IF SERVICE IS REQUIRED.

WATER LINE RELOCATION DETAIL

N.T.S.

REUSE OF DRAWINGS			
THIS DOCUMENT, AND THE IDEAS AND DESIGNS INCORPORATED HEREIN AS INSTRUMENT OF PROFESSIONAL SERVICE, IS THE PROPERTY OF J-U-B ENGINEERS, INC. AND IS NOT TO BE USED, IN WHOLE OR PART, FOR ANY OTHER PROJECT WITHOUT THE EXPRESS WRITTEN AUTHORIZATION OF J-U-B ENGINEERS, INC.			
REVISION			
NO.	DESCRIPTION	BY	DATE



**Hooper Irrigation Company
Pressure Irrigation Standards**

**WATERLINE
RELOCATION DETAIL**

SHEET	PI-12
CAD DWG:	detail01.dwg
PLOT SCALE:	N/A
DATE:	MAY 2003
DRAWN BY:	D.STEELE
DESIGN BY:	D.STEELE
CHECKED BY:	TLA
SCALE:	-