

U P W A L L D E S I G N
A R C H I T E C T S
1025 EAST HOLLYWOOD AVENUE SALT LAKE CITY, UTAH 84105 (801) 485-0708 FAX(801) 485-6992

21 July, 2016

Weber County Building Department
2380 Washington Blvd., Suite 240
Ogden, UT 84401

Re: Lot 37 Powder Mountain 2015 Code Review

Dear Sir or Madam,

As of July 1st, Utah has adopted the 2015 series of codes from the ICC. Upon studying the residence located on lot 37 of Powder Mountain. I have determined that the project is in compliance with the code with the following revision;

A Carbon Monoxide Detector will be required outside the guest suite adjacent to the boot room on the lower level and outside the master suite on the upper level.

If you have any questions, please contact me.

Sincerely

Josh Arrington
Josh Arrington, Architect
Upwall Design

