

Riverdale Office Tel: 801.621.1025

January 12, 2017

Design Engineer Response Letter to Weber County Engineering Department comments dated January 9, 2017.

Re: Gallop Bend Subdivision

## "Weber County Engineering Division Review"

1. As per the conversation with Chad Meyerhoffer and Brock Loomis, move the most western manhole on 2475 south to the western borderline of the property. Adjust the slopes accordingly. We will continue to work together on this coordination.

Response:

Manhole moved to west property line.

2. Specify the asphalt to be a PG 64-22 mix design

Response:

Revised as noted.

3. Fix the rim elevations of CO-4, CO-8, CO-9, CO-10, and CO-11.

Response:

Removed foundation drain system. Added internal ditches to allow for foundation drains to be discharged to rear ditches.

4. Fix the overlapping labels on CG101.

Response:

Revised as noted.

5. Add design and detail of the northbound walkway, per our conversation. Have the walkway rise halfway up to the max elevation.

Response:

Design of walkway added to construction drawings.

Please let me know if there are any questions or concerns with the plan submittal. Thank you.

Dean Barker, P.E. cc: Brock Loomis