


Date: 1/11/2017
 Scale: 1" = 30'
 Design: MDD
 Draft: MDD
 Check: DLW

Revisions	Description
Date	




TANK SITE PLAN
 500,000 GALLON TANK
 WOLF CREEK WATER + SEWER I.D.
 EDEN, WEBER, UTAH



C1
 10

PAY ITEM (LOCATION)	#	NUMBER OF PARTS	PART NAME	CONNECTION TYPE	NOTES
YARD PIPING					
INLET	1	2	10" X 6" REDUCER	MJ X MJ	TIE TO EXISTING 6" CAST IRON
INLET	1	1	10" GV	MJ X MJ	
INLET	1	1	10" TEE	MJ X MJ	
INLET	1	1	10" 22.5 ELBOW	MJ X MJ	
INLET	2	1	10" COUPLER		ROMAC MACRO HP OR APPROVED
INLET	2	1	10" 45 ELBOW	MJ X MJ	
INLET	3	≈140'	10" D.I.P.		≈ LENGTH FROM COUPLER TO TIE IN
DRAIN AND OVER FLOW	4	2	10" X 6" REDUCER	MJ X MJ	TIE TO EXISTING 6" CAST IRON
DRAIN AND OVER FLOW	4	1	10" TEE	MJ X MJ	
DRAIN AND OVER FLOW	4	2	10" 22.5 ELBOW	MJ X MJ	
DRAIN AND OVER FLOW	5	2	10" COUPLER		ROMAC MACRO HP OR APPROVED
DRAIN AND OVER FLOW	5	1	10" TEE	MJ X MJ	
DRAIN AND OVER FLOW	5	1	10" 90 ELBOW	MJ X MJ	
DRAIN AND OVER FLOW	5	1	10" GV	MJ X MJ	RESILIENT
DRAIN AND OVER FLOW	6	≈140'	10" D.I.P.		≈ LENGTH FROM COUPLER TO TIE IN
OUTLET	7	2	12" X 8" REDUCER	MJ X MJ	TIE TO EXISTING 8" CAST IRON
OUTLET	7	1	12" TEE	MJ X MJ	TIE TO EXISTING 8" CAST IRON
OUTLET	7	1	12" BV	MJ X MJ	
OUTLET	8	1	12" COUPLER		ROMAC MACRO HP OR APPROVED
OUTLET	9	≈100'	12" D.I.P.		≈ LENGTH FROM COUPLER TO TIE IN



Scale in Feet
 1" = 30'

R:\239 - WOLF CREEK WATER AND SEWER\1602-500K TANK AND I.P. WATERLINE\DESIGN\DWG\BOOK TANK I.D-2017.DWG, 1/23/2017 4:52:49 PM, RHE