

A

R

W

**ENGINEERS**

structural consultants

# Structural Calculations

For

## Wolf Creek 500,000 Gal. Water Tank

Project Number: 16402

December 01, 2016



Prepared by  
**ARW Engineers**  
1594 West Park Circle  
Ogden, Utah 84404

DESIGN CRITERIASOIL CRITERIA

$$\text{AT-REST PRESSURE} = 65 \text{ pcf (DOWNHILL SIDE)}$$

$$95 \text{ pcf (UPHILL SIDE)}$$

$$\text{PASSIVE PRESSURE} = 250 \text{ pcf}$$

$$\text{FRICTION} = 0.35$$

$$\text{SEISMIC AT-REST} = 65 \text{ pcf} + 7 \text{ pcf} = 72 \text{ pcf (DOWNHILL SIDE)}$$

$$95 \text{ pcf} + 7 \text{ pcf} = 102 \text{ pcf (UPHILL SIDE)}$$

$$\text{SEISMIC PASSIVE} = 250 \text{ pcf} - 22 \text{ pcf} = 228 \text{ pcf}$$

$$\text{SOIL BEARING PRESSURE} = 3,500 \text{ psf}$$

SEISMIC CRITERIA

$$S_0 = 0.92g \quad F_a = 1.029 \quad S_{ms} = 0.954g \quad S_{ds} = 0.636g$$

$$S_1 = 0.31g \quad F_v = 1.49 \quad S_{mi} = 0.467g \quad S_{d1} = 0.212g$$


SITE CLASS C

SNOW LOAD

ELEV. 5,600 FE (PER GOOGLE EARTH)

$$P_g = 82.0 \text{ psf}$$

$$\text{MAX SOIL COVER ON LID} = 6" = 75 \text{ psf}$$

TANK GEOMETRY

WALL HEIGHT = 16'-0"

WATER HEIGHT = 15'-3"

**USGS** Design Maps Detailed Report

2012/2015 International Building Code (41.3333°N, 111.825°W)

Site Class C - "Very Dense Soil and Soft Rock", Risk Category I/II/III

Section 1613.3.1 — Mapped acceleration parameters

Note: Ground motion values provided below are for the direction of maximum horizontal spectral response acceleration. They have been converted from corresponding geometric mean ground motions computed by the USGS by applying factors of 1.1 (to obtain  $S_5$ ) and 1.3 (to obtain  $S_1$ ). Maps in the 2012/2015 International Building Code are provided for Site Class B. Adjustments for other Site Classes are made, as needed, in Section 1613.3.3.

From Figure 1613.3.1(1) <sup>(1)</sup>  $S_5 = 0.927 g$

From Figure 1613.3.1(2) <sup>(2)</sup>  $S_1 = 0.315 g$

Section 1613.3.2 — Site class definitions

The authority having jurisdiction (not the USGS), site-specific geotechnical data, and/or the default has classified the site as Site Class C, based on the site soil properties in accordance with Section 1613.

2010 ASCE-7 Standard - Table 20.3-1  
SITE CLASS DEFINITIONS

Site Class	$\bar{v}_s$	$\bar{N}$ or $\bar{N}_{ch}$	$\bar{s}_u$
A. Hard Rock	>5,000 ft/s	N/A	N/A
B. Rock	2,500 to 5,000 ft/s	N/A	N/A
C. Very dense soil and soft rock	1,200 to 2,500 ft/s	>50	>2,000 psf
D. Stiff Soil	600 to 1,200 ft/s	15 to 50	1,000 to 2,000 psf
E. Soft clay soil	<600 ft/s	<15	<1,000 psf

Any profile with more than 10 ft of soil having the characteristics:

- Plasticity index  $PI > 20$ ,
- Moisture content  $w \geq 40\%$ , and
- Undrained shear strength  $\bar{s}_u < 500$  psf

F. Soils requiring site response analysis in accordance with Section 21.1

See Section 20.3.1

For SI: 1ft/s = 0.3048 m/s 1lb/ft<sup>2</sup> = 0.0479 kN/m<sup>2</sup>

Section 1613.3.3 — Site coefficients and adjusted maximum considered earthquake spectral response acceleration parameters

TABLE 1613.3.3(1)  
VALUES OF SITE COEFFICIENT  $F_s$

Site Class	Mapped Spectral Response Acceleration at Short Period				
	$S_s \leq 0.25$	$S_s = 0.50$	$S_s = 0.75$	$S_s = 1.00$	$S_s \geq 1.25$
A	0.8	0.8	0.8	0.8	0.8
B	1.0	1.0	1.0	1.0	1.0
C	1.2	1.2	1.1	1.0	1.0
D	1.6	1.4	1.2	1.1	1.0
E	2.5	1.7	1.2	0.9	0.9
F	See Section 11.4.7 of ASCE 7				

Note: Use straight-line interpolation for intermediate values of  $S_s$

For Site Class = C and  $S_s = 0.927$  g,  $F_s = 1.029$

TABLE 1613.3.3(2)  
VALUES OF SITE COEFFICIENT  $F_v$

Site Class	Mapped Spectral Response Acceleration at 1-s Period				
	$S_1 \leq 0.10$	$S_1 = 0.20$	$S_1 = 0.30$	$S_1 = 0.40$	$S_1 \geq 0.50$
A	0.8	0.8	0.8	0.8	0.8
B	1.0	1.0	1.0	1.0	1.0
C	1.7	1.6	1.5	1.4	1.3
D	2.4	2.0	1.8	1.6	1.5
E	3.5	3.2	2.8	2.4	2.4
F	See Section 11.4.7 of ASCE 7				

Note: Use straight-line interpolation for intermediate values of  $S_1$

For Site Class = C and  $S_1 = 0.315$  g,  $F_v = 1.485$

**Equation (16-37):**

$$S_{MS} = F_a S_s = 1.029 \times 0.927 = 0.954 \text{ g}$$

**Equation (16-38):**

$$S_{M1} = F_v S_1 = 1.485 \times 0.315 = 0.467 \text{ g}$$

Section 1613.3.4 — Design spectral response acceleration parameters

**Equation (16-39):**

$$S_{DS} = \frac{2}{3} S_{MS} = \frac{2}{3} \times 0.954 = 0.636 \text{ g}$$

**Equation (16-40):**

$$S_{D1} = \frac{2}{3} S_{M1} = \frac{2}{3} \times 0.467 = 0.312 \text{ g}$$

**UTAH SNOW LOAD STUDY**

Version Date July 20, 2012

author: TAB Reviewed by TMD

Project: Wolf Creek Water Tank

Description: Water Tank Lid Snow Load

Date: 11/16/2016

Job#: 16402

By: ZCH

ENGINEERS

County: Weber

Po:	43	psf
S:	63	psf/1000 ft.
A <sub>o</sub> :	4.5	ft./1000
A:	5600	ft.

Pg: 81.6 psf

**Table No. 1608.1.2 (b) REQUIRED SNOW LOADS FOR SELECTED UTAH CITIES AND TOWNS<sup>1,2</sup>**

The following jurisdictions require design snow load values that differ from the equation in the Utah Snow Load Study

County	City	Elevation	Ground Snow Load (psf)	Roof Snow Load (psf) <sup>6</sup>
Carbon	Pnce <sup>3</sup>	5550	43	30
	All other County Locations <sup>5</sup>	-	-	-
Davis	Fruit Heights <sup>3</sup>	4500-4850	57	40
Emery	Green River <sup>3</sup>	4070	36	25
Garfield	Panguitch <sup>3</sup>	6600	43	30
Rich	Woodruff <sup>3</sup>	6315	57	40
	Laketown <sup>4</sup>	6000	57	40
	Garden City <sup>3</sup>	-	-	-
	Randolph <sup>4</sup>	6300	57	40
San Juan	Monticello <sup>3</sup>	6820	50	35
Summit	Coalville <sup>3</sup>	5600	86	60
	Kamas <sup>4</sup>	6500	114	80
Tooele	Tooele <sup>3</sup>	5100	43	30
Utah	Orem <sup>3</sup>	4650	43	30
	Pleasant Grove <sup>4</sup>	5000	43	30
	Provo <sup>5</sup>	-	-	-
Wasatch	Heber <sup>5</sup>	-	-	-
Washington	Leeds <sup>3</sup>	3460	29	20
	Santa Clara <sup>3</sup>	2850	21	15
	St. George <sup>3</sup>	2750	21	15
	All other County Locations <sup>5</sup>	-	-	-
Wayne	Loa <sup>3</sup>	7080	43	30

<sup>1</sup>The IBC Requires a minimum live load - See 1607.11.2

<sup>2</sup>This table is informational only in that actual site elevations may vary. Table is only valid if site elevation is within 100 feet of the listed elevation. Otherwise contact the local Building Official

<sup>3</sup>Values adopted from table VII of the Utah Snow Load Study

<sup>4</sup>Values based on site-specific study. Contact local Building Official for additional information.

<sup>5</sup>Contact Local Building Official

<sup>6</sup>Based on C<sub>e</sub>=1.0, C<sub>t</sub>=1.0, and I<sub>s</sub>=1.0



JOB TITLE Wolf Creek Water Tank  
 BUILDING LOCATION Eden, UT

# CONCRETE LAP SPLICE TABLE



JOB # 16402  
 PREPARED BY ZCH

## CONCRETE DEVELOPMENT AND LAP SPLICE DESIGN TABLE

BASED ON CHAPTER 12 OF THE 2011 ACI 318  
 Author: Matt McBride

Version: June 17, 2013

### Concrete Properties

- $\lambda = 1.0$  For horizontal reinforcement placed such that more than 12 in. of fresh concrete is cast below the development length or splice (i.e. Top Splice) = 1.3 - Otherwise = 1.0
- $\lambda = 1.0$  For Epoxy-coated bars or wires with cover less than 3db, or clear spacing less than 6db = 1.5 - For all other Epoxy-coated bars or wires = 1.2 - Otherwise = 1.0
- $\lambda = 1.0$  When Light-weight Aggregate Concrete is used = 0.75 - Otherwise = 1.0
- $\lambda = 1.0$  For No. 6 smaller bars and deformed wires = 0.8 - Otherwise = 1.0

Rebar Properties  
 $f_y = 60000$  psi

CONCRETE REINFORCING DEVELOPMENT & SPLICE LENGTHS																																			
Bar Location	Concrete		BAR SIZE																																
	Type	Strength	#3			#4			#5			#6			#7			#8			#9			#10			#11			#14			#18		
			$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$			
Vert. Wall Bars, Fill on Metal Deck	NWC	3000 psi	17	22	8	22	29	8	28	36	10	33	43	12	48	62	13	55	72	15	62	81	17	69		19	76		30	96	38	124	49		
Honz. Wall Bars, Footing Top Bars	NWC	3000 psi	17	22	8	22	29	8	28	36	10	33	43	12	48	62	13	55	72	15	62	81	17	69		19	76		30	96	38	124	49		
Beam Bottom Bars, Column Bars	NWC	3000 psi	17	22	8	22	29	11	28	38	14	33	43	16	48	62	19	55	72	22	62	81	25	69		27	76		30	96	38	124	49		
Footing Bottom Bars	NWC	3000 psi	12	16	8	14	18	8	17	22	10	20	26	12	29	38	13	33	43	15	37	48	17	42		19	46		30						
Beam Top Bars	NWC	3000 psi	22	29	8	29	38	11	36	47	14	43	56	16	63	82	19	72	94	22	81	105	25	90		27	98		30	125	38	161	49		
Slab on Grade	NWC	3000 psi	12	16	8	14	18	8	17	22	10	20	26	12	32	42	13	42	55	15	53	69	17	69		19	76		30						

CONCRETE REINFORCING DEVELOPMENT & SPLICE LENGTHS																																			
Bar Location	Concrete		BAR SIZE																																
	Type	Strength	#3			#4			#5			#6			#7			#8			#9			#10			#11			#14			#18		
			$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$			
Vert. Wall Bars, Fill on Metal Deck	NWC	4000 psi	15	20	7	19	25	7	24	31	8	29	38	10	42	55	12	48	62	13	54	70	15	60		17	66		26	84	33	107	43		
Honz. Wall Bars, Footing Top Bars	NWC	4000 psi	15	20	7	19	25	7	24	31	8	29	38	10	42	55	12	48	62	13	54	70	15	60		17	66		26	84	33	107	43		
Beam Bottom Bars, Column Bars	NWC	4000 psi	15	20	7	19	25	9	24	31	12	29	38	14	42	55	17	48	62	19	54	70	21	60		24	66		26	84	33	107	43		
Footing Bottom Bars	NWC	4000 psi	12	16	7	12	16	7	15	20	8	18	23	10	25	33	12	29	38	13	33	43	15	36		17	40		26						
Beam Top Bars	NWC	4000 psi	19	25	7	25	33	9	31	40	12	37	48	14	54	70	17	62	81	19	70	91	21	78		24	85		26	108	33	139	43		
Slab on Grade	NWC	4000 psi	12	16	7	12	16	7	15	20	8	18	23	10	28	36	12	36	47	13	46	60	15	60		17	66		26						



**CONCRETE REINFORCING DEVELOPMENT & SPLICE LENGTHS**

Bar Location	Concrete		BAR SIZE																																
	Type	Strength	#3			#4			#5			#6			#7			#8			#9			#10			#11			#14			#18		
			$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$
Vert. Wall Bars, Fill on Metal Deck	NWC	4500 psi	14	18	7	18	23	6	23	30	8	27	35	9	40	52	11	45	59	13	51	66	14	56		16	62		25	79	31	101	40		
Honz. Wall Bars, Footing Top Bars	NWC	4500 psi	14	18	7	18	23	6	23	30	8	27	35	9	40	52	11	45	59	13	51	66	14	56		16	62		25	79	31	101	40		
Beam Bottom Bars, Column Bars	NWC	4500 psi	14	18	7	18	23	9	23	30	11	27	35	13	40	52	16	45	59	18	51	66	20	56		22	62		25	79	31	101	40		
Footing Bottom Bars	NWC	4500 psi	12	16	7	12	16	6	14	18	8	17	22	9	24	31	11	27	35	13	31	40	14	34		16	37		25						
Beam Top Bars	NWC	4500 psi	18	23	7	24	31	9	30	39	11	35	46	13	51	66	16	59	77	18	66	86	20	73		22	80		25	102	31	131	40		
Slab on Grade	NWC	4500 psi	12	16	7	12	16	6	14	18	8	17	22	9	27	35	11	34	44	13	44	57	14	56		16	62		25						

**CONCRETE REINFORCING DEVELOPMENT & SPLICE LENGTHS**

Bar Location	Concrete		BAR SIZE																																
	Type	Strength	#3			#4			#5			#6			#7			#8			#9			#10			#11			#14			#18		
			$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$
Vert. Wall Bars, Fill on Metal Deck	NWC	5000 psi	13	17	6	17	22	6	22	29	7	26	34	9	38	49	10	43	56	12	48		13	54		15	59		23	75	30	96	38		
Honz. Wall Bars, Footing Top Bars	NWC	5000 psi	13	17	6	17	22	6	22	29	7	26	34	9	38	49	10	43	56	12	48		13	54		15	59		23	75	30	96	38		
Beam Bottom Bars, Column Bars	NWC	5000 psi	13	17	6	17	22	8	22	29	11	26	34	13	38	49	15	43	56	17	48		19	54		21	59		23	75	30	96	38		
Footing Bottom Bars	NWC	5000 psi	12	16	6	12	16	6	13	17	7	16	21	9	23	30	10	26	34	12	29		13	32		15	36		23						
Beam Top Bars	NWC	5000 psi	17	22	6	23	30	8	28	36	11	34	44	13	49	64	15	56	73	17	63		19	69		21	76		23	97	30	125	38		
Slab on Grade	NWC	5000 psi	12	16	6	12	16	6	13	17	7	16	21	9	25	33	10	32	42	12	41		13	54		15	59		23						



# CONCRETE LAP SPLICE TABLE



JOB TITLE: Wolf Creek Water Tank  
 BUILDING LOCATION: Eden, UT

JOB # 16402  
 PREPARED BY ZCH

## CONCRETE DEVELOPMENT AND LAP SPLICE DESIGN TABLE

BASED ON CHAPTER 12 OF THE 2011 ACI 318  
 Author: Matt McBride

Version: June 17, 2013

**Concrete Properties**

- $\psi_t = 1.3$  For horizontal reinforcement placed such that more than 12 in. of fresh concrete is cast below the development length or splice (i.e. Top Splice) = 1.3 - Otherwise = 1.0
- $\psi_e = 1.0$  For Epoxy-coated bars or wires with cover less than 3db, or clear spacing less than 6db = 1.5 - For all other Epoxy-coated bars or wires = 1.2 - Otherwise = 1.0
- $\lambda = 1.0$  When Light-weight Aggregate Concrete is used = 0.75 - Otherwise = 1.0
- $\psi_s = 1.0$  For No. 6 smaller bars and deformed wires = 0.8 - Otherwise = 1.0

**Rebar Properties**  
 $f_y = 60000$  psi

Bar Location		CONCRETE REINFORCING DEVELOPMENT & SPLICE LENGTHS																																
		Concrete		BAR SIZE																														
		Type	Strength	#3			#4			#5			#6			#7			#8			#9			#10			#11			#14			#18
		$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$			
Vert. Wall Bars, Fill on Metal Deck	NWC	3000 psi	22	29	8	29	38	8	36	47	10	43	56	12	63	82	13	72	94	15	81	105	17	90		19	98		30	125	38	161	49	
Horiz. Wall Bars, Footing Top Bars	NWC	3000 psi	22	29	8	29	38	8	36	47	10	43	56	12	63	82	13	72	94	15	81	105	17	90		19	98		30	125	38	161	49	
Beam Bottom Bars, Column Bars	NWC	3000 psi	22	29	8	29	38	11	36	47	14	43	56	16	63	82	19	72	94	22	81	105	25	90		27	98		30	125	38	161	49	
Footing Bottom Bars	NWC	3000 psi	13	17	8	18	23	8	22	29	10	26	34	12	38	49	13	43	56	15	49	64	17	54		19	59		30					
Beam Top Bars	NWC	3000 psi	28	36	8	38	49	11	47	61	14	56	73	16	81	105	19	93	121	22	105	137	25	116		27	128		30	162	38	209	49	
Slab on Grade	NWC	3000 psi	13	17	8	18	23	8	22	29	10	26	34	12	42	55	13	54	70	15	69	90	17	90		19	98		30					

Bar Location		CONCRETE REINFORCING DEVELOPMENT & SPLICE LENGTHS																																
		Concrete		BAR SIZE																														
		Type	Strength	#3			#4			#5			#6			#7			#8			#9			#10			#11			#14			#18
		$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$	$l_d$	$l_s$	$l_{dn}$			
Vert. Wall Bars, Fill on Metal Deck	NWC	4000 psi	19	25	7	25	33	7	31	40	8	37	48	10	54	70	12	62	81	13	70	91	15	78		17	85		26	108	33	139	43	
Horiz. Wall Bars, Footing Top Bars	NWC	4000 psi	19	25	7	25	33	7	31	40	8	37	48	10	54	70	12	62	81	13	70	91	15	78		17	85		26	108	33	139	43	
Beam Bottom Bars, Column Bars	NWC	4000 psi	19	25	7	25	33	9	31	40	12	37	48	14	54	70	17	62	81	19	70	91	21	78		24	85		26	108	33	139	43	
Footing Bottom Bars	NWC	4000 psi	12	16	7	15	20	7	19	25	8	23	30	10	33	43	12	37	48	13	42	55	15	47		17	51		26					
Beam Top Bars	NWC	4000 psi	25	33	7	33	43	9	41	53	12	49	64	14	71	92	17	81	105	19	91	118	21	101		24	111		26	141	33	181	43	
Slab on Grade	NWC	4000 psi	12	16	7	15	20	7	19	25	8	23	30	10	36	47	12	47	61	13	60	78	15	78		17	85		26					

**CONCRETE REINFORCING DEVELOPMENT & SPLICE LENGTHS**

Bar Location	Concrete		BAR SIZE																														
	Type	Strength	#3			#4			#5			#6			#7			#8			#9			#10			#11			#14		#18	
			$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$		
Vert. Wall Bars, Fill on Metal Deck	NWC	4500 psi	18	23	7	24	31	6	30	39	8	35	46	9	51	66	11	59	77	13	66	86	14	73		16	80		25	102	31	131	40
Honz. Wall Bars, Footing Top Bars	NWC	4500 psi	18	23	7	24	31	6	30	39	8	35	46	9	51	66	11	59	77	13	66	86	14	73		16	80		25	102	31	131	40
Beam Bottom Bars, Column Bars	NWC	4500 psi	16	23	7	24	31	9	30	39	11	35	46	13	51	66	16	59	77	18	66	86	20	73		22	80		25	102	31	131	40
Footing Bottom Bars	NWC	4500 psi	12	16	7	14	18	6	18	23	8	21	27	9	31	40	11	35	46	13	40	52	14	44		16	48		25				
Beam Top Bars	NWC	4500 psi	23	30	7	31	40	9	38	49	11	46	60	13	67	87	16	76	99	18	86	112	20	95		22	104		25	133	31	171	40
Slab on Grade	NWC	4500 psi	12	16	7	14	18	6	18	23	8	21	27	9	34	44	11	44	57	13	57	74	14	73		16	80		25				

**CONCRETE REINFORCING DEVELOPMENT & SPLICE LENGTHS**

Bar Location	Concrete		BAR SIZE																														
	Type	Strength	#3			#4			#5			#6			#7			#8			#9			#10			#11			#14		#18	
			$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$	$l_{sn}$	$l_d$	$l_s$		
Vert. Wall Bars, Fill on Metal Deck	NWC	5000 psi	17	22	6	23	30	6	28	36	7	34	44	9	49	64	10	56	73	12	63		13	69		15	76		23	97	30	125	38
Honz. Wall Bars, Footing Top Bars	NWC	5000 psi	17	22	6	23	30	6	28	36	7	34	44	9	49	64	10	56	73	12	63		13	69		15	76		23	97	30	125	38
Beam Bottom Bars, Column Bars	NWC	5000 psi	17	22	6	23	30	8	28	36	11	34	44	13	49	64	15	56	73	17	63		19	69		21	76		23	97	30	125	38
Footing Bottom Bars	NWC	5000 psi	12	16	6	14	18	6	17	22	7	20	26	9	29	38	10	34	44	12	38		13	42		15	46		23				
Beam Top Bars	NWC	5000 psi	22	29	6	29	38	8	36	47	11	44	57	13	63	82	15	72	94	17	81		19	90		21	99		23	126	30	162	38
Slab on Grade	NWC	5000 psi	12	16	6	14	18	6	17	22	7	20	26	9	33	43	10	42	55	12	54		13	69		15	76		23				

ENVIRONMENTAL FACTOR

ACI 350.6 SEC. 9.2.6

WATER COMBINATIONS  $\Rightarrow \gamma = 1.6$

$$S_d = \frac{0.9(60,000)}{1.6(20,000)} = 1.69$$

SOIL COMBINATIONS  $\Rightarrow \gamma = 1.4$


$$S_d = \frac{0.9(60,000)}{1.4(20,000)} = 1.93$$

HOOP AND TENSILE STRESS ONLY

FLEXURAL STRESS

$$f_s = 20,000 \text{ psi (CONSERVATIVE)}$$

$$\therefore S_d = 1.93$$



## Circular Concrete Tanks without Prestressing

(Based on the 1993 PCA Document)

### Design Criteria

$f_c$	4500 psi
$D_{tank}$	75 ft
$H_{tank}$	16 ft
$t_{wall}$	12 in
Fluid Pressure	62.4 pcf
Soil Pressure	102 pcf
$E_s$	29000000 psi
$E_c$	3823676.24 psi
$n$	7.6
Surcharge	157 pcf
Soil on Lid	0.5 ft
Load Factor	
$F_{liquid\ pressure}$	1.4
$F_{soil\ pressure}$	1.6
Environmental	
Durability Factor	
Flexure (liquid)	1.93
Tension (liquid)	1.93
Flexure (soil)	1.69
Compression (soil)	1
$H^2/Dt$	3.41

*SEISMIC ACTIVE*

### Estimation of Tank Wall Thickness

Limit Ring Tension Stress in Concrete Wall from 7% to 12% of  $f_c$

For given  $t$  and  $H^2/Dt$ , with a hinged base/free top (Table A-5)

Max Coefficient= 0.611 (Table A-5)

$w_u$  169 pcf

$T_{max}$  61765 lbs.

$T_{unfactored}$  22859 lbs.

$A_{s( req'd)}$  1.14 in<sup>2</sup>

$A_{s( used)}$  1.2 in<sup>2</sup>

OK

$F_{l( conc.)}$  217 psi

This equates to 4.83 % of  $f_c$   
 Wall thickness is OK

#### Compression Check

$F_c$	869
0.33 $f_c$	1485
	OK

The Following Load Cases were used in Analysis:

- Load Case #1: Full of Water, No Lid, No Backfill
- Load Case #2: Empty, No Lid, w/Backfill
- Load Case #3: Empty, w/Lid, w/Backfill
- Load Case #4: Full of Water, w/Lid, Ignore Backfill

### Load Case #1-Full of Water, No Lid, No Backfill

Assume Free Top/Hinged Base (Tables A-5 and A-7)

Effects of Possible outward movement will be handled by designing the entire portion of the wall for the maximum Ring Tension and Moment


Ring Force=(A-5 Coef.) $w_u H$   $w_u H$ = 101162.88

Moment =(A-7 Coef.) $w_u H^2$   $w_u H^2$ = 690605.2608

	A-5 Coef.	RF (#)	A-7 Coef.	Moment (#-ft/ft)
Top	-0.004	-380	0	0
0.1H	0.118	11928	0.0000	12
0.2H	0.238	24082	0.0002	139
0.3H	0.358	36203	0.0008	532
0.4H	0.469	47445	0.0019	1304
0.5H	0.559	56562	0.0038	2618
0.6H	0.611	61765	0.0061	4241
0.7H	0.597	60394	0.0085	5865
0.8H	0.493	49923	0.0098	6773
0.9H	0.288	29089	0.0080	5551
Bottom	0.000	0	0	0

Project Name Wolf Creek Water Tank  
 Project # 16402  
 Prepared By ZCH  
 Date 11/16/2016

Program Authors. TAB & DOC  
 Last Revised 1/19/2006  
 Reviewed By TMD



Load Case #2-Empty, No Lid, w/ Backfill

Use Durability Coefficients as Noted Previous

Soil Over Lid= 0.5 ft  
 p 78.5

Ring Force=(A-5 Coef )w<sub>o</sub>HR+(A-6 Coef )pR

w<sub>o</sub>HR= -188986  
 pR= -9090.3

Moment=(A-7 Coef )w<sub>o</sub>h<sup>3</sup>+ph<sup>2</sup>

w<sub>o</sub>h<sup>3</sup>+ph<sup>2</sup> -1184049

	A-5 Coef	RF (#)	A-5 Coef.	RF (#)	Total RF (#)	A-7 Coef.	Moment (#-ft/ft)
Top	-0.004	710	0.996	-9056.168496	-8347	0	0
0.1H	0.118	-22282	1.018	-9253.067825	-31536	0.0000	-20
0.2H	0.238	-44989	1.038	-9436.245945	-54426	0.0002	-239
0.3H	0.358	-67632	1.058	-9616.336794	-77248	0.0008	-911
0.4H	0.469	-88634	1.069	-9717.5307	-98352	0.0019	-2236
0.5H	0.559	-105664	1.059	-9627.656791	-115292	0.0038	-4488
0.6H	0.611	-115385	1.011	-9186.176938	-124571	0.0061	-7272
0.7H	0.597	-112824	0.897	-8153.9991	-120978	0.0085	-10055
0.8H	0.493	-93263	0.693	-6304.037292	-99567	0.0098	-11613
0.9H	0.288	-54342	0.388	-3522.920038	-57865	0.0080	-9517
Bottom	0.000	0	0.000	0	0	0	0

Load Case #3-Empty, w/Lid, w/Backfill

Apply a shear force (V) @ top of wall to make Ring Tension = 0 @ top of Wall

When top of tank is free, Ring Force (LC#2) = -8347 #

At top of wall (0.0H) from table A-8. Coefficient= -8.07 #

Therefore, the shear force (V) required to produce zero ring force at the top of the tank=  
 (Coef A-8 @ 0.0H)(VR/H)=(Ring Force from LC#2)

Therefore

V= -441 #  
 VR/H= -1034 #

Delta<sub>RF</sub>=Change in Ring Force Due to V applied @ the top of wall

Delta<sub>RF</sub>=(A-8 Coef )(VR/H)

Find the change in moment (Delta<sub>mom</sub>) due to the V applied @ top

If S<sub>D</sub> for moment is less than S<sub>D</sub> for compression, then V is reduced by (S<sub>DM</sub>/S<sub>DC</sub>)


Delta<sub>mom</sub>=(A-9 Coef )VH

VH= -7060

	A-8 Coef.	Delta <sub>RF</sub> (#)	LC#2 RF (#)	Total RF (#)	A-9 Coef.	Delta <sub>mom</sub> (#-ft/ft)	LC #2 Moment (#-ft/ft)	Total Moment (#-ft/ft)
Top	-8.071	8347	-8347	0	0	0	0	0
0.1H	-4.946	5115	-31536	-26421	0.0647	-457	-20	-477
0.2H	-2.475	2560	-54426	-51865	0.0797	-563	-239	-802
0.3H	-0.843	871	-77248	-76377	0.0694	-490	-911	-1401
0.4H	0.059	-61	-98352	-98413	0.0497	-351	-2236	-2587
0.5H	0.434	-449	-115292	-115741	0.0305	-216	-4488	-4704
0.6H	0.480	-496	-124571	-125067	0.0150	-106	-7272	-7378
0.7H	0.363	-376	-120978	-121354	0.0042	-30	-10055	-10085
0.8H	0.198	-205	-99567	-99772	-0.0027	19	-11613	-11594
0.9H	0.060	-62	-57865	-57927	-0.0075	53	-9517	-9464
Bottom	0.000	0	0	0	-0.0124	87	0	87

Project Name Wolf Creek Water Tank  
 Project # 16402  
 Prepared By ZCH  
 Date 11/16/2016

Program Authors: TAB & DOC  
 Last Revised: 1/19/2006  
 Reviewed By: TMD



Load Case #4-Full of Water, w/Lid, ignore Backfill

Add the effects of shear @ the top of the tank to LC #1

At the top of the wall - Coefficient from Table A-8= -8.07 #

(Coef A-8 @ 0.0H)(VR/H) = (Ring Force from LC#1)


V= -20 #  
 VR/H= -47 # (For Ring Force)  
 VH= -321 # (For Moment)

	A-8 Coef.	Delta <sub>RF</sub> (#)	LC#1 RF (#)	Total RF (#)	A-9 Coef.	Delta <sub>mom</sub> (#-ft/ft)	LC#1 Moment (#-ft/ft)	Total Moment (#-ft/ft)
Top	-8.07	380	-380	0	0	0	0	0
0.1H	-4.95	233	11928	12160	0.065	-21	12	-9
0.2H	-2.48	117	24082	24199	0.080	-26	139	114
0.3H	-0.84	40	36203	36243	0.069	-22	532	509
0.4H	0.06	-3	47445	47443	0.050	-16	1304	1288
0.5H	0.43	-20	56562	56541	0.031	-10	2618	2608
0.6H	0.48	-23	61765	61742	0.015	-5	4241	4237
0.7H	0.36	-17	60394	60377	0.004	-1	5865	5864
0.8H	0.20	-9	49923	49914	-0.003	1	6773	6774
0.9H	0.06	-3	29089	29086	-0.008	2	5551	5553
Bottom	0	0	0	0	-0.012	4	0	4

Envelope of Ring Forces


	LC#1	LC#2	LC#3	LC#4	Max	Min
Top	-380	-8347	0	0	0	-8347
0.1H	11928	-31536	-26421	12160	12160	-31536
0.2H	24082	-54426	-51865	24199	24199	-54426
0.3H	36203	-77248	-76377	36243	36243	-77248
0.4H	47445	-98352	-98413	47443	47445	-98413
0.5H	56562	-115292	-115741	56541	56562	-115741
0.6H	61765	-124571	-125067	61742	61765	-125067
0.7H	60394	-120978	-121354	60377	60394	-121354
0.8H	49923	-99567	-99772	49914	49923	-99772
0.9H	29089	-57865	-57927	29086	29089	-57927
Bottom	0	0	0	0	0	0

	Tension	Compression
Bottom	0	0
0.9H	29	-58
0.8H	50	-100
0.7H	60	-121
0.6H	62	-125
0.5H	57	-116
0.4H	47	-98
0.3H	36	-77
0.2H	24	-54
0.1H	12	-32
Top	0	-8



Project Name Wolf Creek Water Tank  
 Project # 16402  
 Prepared By ZCH  
 Date 11/16/2016


Program Authors TAB & DOC  
 Last Revised 1/19/2006  
 Reviewed By TMD



Envelope of Moments

	LC#1	LC#2	LC#3	LC#4	Max	Min
Top	0	0	0	0	0	0
0.1H	12	-20	-477	-9	12	-477
0.2H	139	-239	-802	114	139	-802
0.3H	532	-911	-1401	509	532	-1401
0.4H	1304	-2236	-2587	1288	1304	-2587
0.5H	2618	-4488	-4704	2608	2618	-4704
0.6H	4241	-7272	-7378	4237	4241	-7378
0.7H	5865	-10055	-10085	5864	5865	-10085
0.8H	6773	-11613	-11594	6774	6774	-11613
0.9H	5551	-9517	-9464	5553	5553	-9517
Bottom	0	0	87	4	87	0

	Tension O.F.	Tension I.F.
Bottom	0	0
0.9H	6	-10
0.8H	7	-12
0.7H	6	-10
0.6H	4	-7
0.5H	3	-5
0.4H	1	-3
0.3H	1	-1
0.2H	0	-1
0.1H	0	0
Top	0	0





(WALL DESIGN)

\* SEE SPREADSHEET FOR MAX TENSION AND COMPRESSION CHECK

RING STEEL (HORIZONTAL BARS)

MAX RING FORCE  $\Rightarrow$  62 K @ 0.6(16') = 9.6' FROM TOP

Up to 10' wall  $\therefore$  USE (2) #7 @ 12" O.C. (SEE SPREADSHEET)  $A_s = 1.20 \text{ in}^2$

TOP 6' OF WALL  $\Rightarrow T = 47 \text{ K}$

$$A_{s\text{REQD}} = \frac{47.0 \text{ K}}{0.9(60 \text{ ksi})} = 0.87 \text{ in}^2/\text{ft}$$


$\therefore$  USE (2) #6 @ 12" O.C. (0.88 in<sup>2</sup>/ft)

CHECK MIN. SHRINKAGE STEEL:

$$A_{s\text{min}} = 0.005 (12") (12") = 0.72 \text{ in}^2/\text{ft}$$

$\therefore$  USE #6 @ 12" O.C.

MOMENT REINF. (VERT. BARS)



MAX MOMENT  $\Rightarrow$  TENSION INSIDE FACE = 12 K-ft-ft  
TENSION OUTSIDE FACE = 7 K-ft-ft

$f'_c = 4,500 \text{ psi}$   
 $d = 9.5 \text{ in (INSIDE)}$   
 $= 8.5 \text{ in (OUTSIDE)}$   
 $b = 12 \text{ in}$

TEMP STEEL = 0.003  
 $A_{s\text{min}} = 0.003 (12") (12") = 0.43 \text{ in}^2/\text{ft}$  (BOTH FACE)  
FLEXURE  $A_{s\text{min}} \Rightarrow$   
 $A_{s\text{min}} = \frac{3\sqrt{4,500}}{60,000} (12") (9.5") = 0.38 \text{ in}^2/\text{ft}$  (ONE FACE)

$\therefore$  USE #6 @ 12" O.C. EA. FACE

INSIDE FACE:

$$\frac{M_u}{\phi b d^2} = \frac{12,000 \text{ lb-ft}(12)}{0.9 (12") (9.5")^2} = 148$$

$$\rho = \frac{0.85(4.5)}{60} \left( 1 - \sqrt{1 - \frac{2(148)}{0.85(4,500)}} \right)$$

$$\rho = 0.0025 \quad A_s = 12"(9.5")(0.0025)$$

$$A_s = 0.28 \text{ in}^2/\text{ft}$$

OUTSIDE FACE:

$$\frac{7,000 \text{ lb-ft}(12)}{0.9 (12") (8.5")^2} = 107$$

$$\rho = \frac{0.85(4.5)}{60} \left( 1 - \sqrt{1 - \frac{2(107)}{0.85(4,500)}} \right)$$

$$\rho = 0.0018$$

$\therefore$  FLEXURE MIN. CONTROLS

Wall Design (cont'd)

SHEAR STRENGTH OF WALL

$$\text{WALL CAPACITY} \Rightarrow \phi V_c = 0.75(2) \sqrt{4,500} (12 \text{ in})(8.5 \text{ in}) = 10.3 \text{ K}$$

$$\phi V_c = 10.3 \text{ K}$$

$$V_{\text{MAX IN WALL}} \Rightarrow H^2/DC = 3.41$$

$$\text{COEFF} = 0.158 \quad (\text{PCA TABLE A-12})$$

$$V = 0.158 (102 \text{ pcf})(16)^2 (1.6) = 6.6 \text{ K} < 10.3 \text{ K} \quad \checkmark \text{ ADEQUATE}$$

TANK LID DESIGN

Snow Load = 82 psf

$$DL = 150 \text{ pcf } (8')/12 + 15 \text{ psf} + 75 \text{ psf} = 190 \text{ psf}$$


↓  
2016

USE 8" LID - SEE SPREADSHEET FOR CALLS

TEMP. SHRINKAGE STEEL  $\Rightarrow$   $A_{\text{min}} = 12" (5") (0.005) = 0.48 \text{ in}^2$

@ A MIN. #5 @ 12" O.C. TOP AND BOTTOM.

FLEURE MIN.  $\Rightarrow$



**Concrete Water Tank - Roof Design**

11/17/2016  
11:49:42 AM

Version Date: 10/28/10  
Job Title Wolf Creek Water Tank

Author TAB  
Job #

16402

**Roof Slab Design**

Min Thickness

Slab Span	18.75 ft	Est. Column Thickness	14 in
$h_{min}$	6.39 in		
Use Slab Thickness	8 in	d	5.5 in
$f_c$	4500 psi	$f_y$	60 ksi

Loads

Dead Load	115 psf
Live Load	0 psf
Soil Load	75 psf
Snow Load	82 psf
$W_U$	359.2 psf

Shear Capacity of Slab

Round Column Dim	14 in	
$b_o$	61.2611 in	
$V_U$	126.281 kips	
$\phi V_C$ (No Drop Panel)	67.807 kips	NG Use Drop Panel
Drop Panel Dimension	4 ft square	
New $b_o$	214 in	
$\phi V_C$ Drop Panel	236.867 kips	Ok
Drop Panel Thickness	4 in	
$b_o$	73.8274 in	
$\phi V_C$	141.146 kips	Ok

Flexural Design by Direct Design Method Of ACI 318

$l_2$	17.667 ft	$S_d$	1.93
$l_n$	16.5003 ft	Strip Width	8.833 ft
$M_o$	215.971 K-ft		
Exterior Span $M^+$ factor	0.63	Exterior $M^+$ factored Moment	136.06 k-ft
Exterior Span $M^-$ factor	0.75	Exterior $M^-$ factored Moment	161.98 k-ft
Interior Span $M^+$ factor	0.35	Interior $M^+$ factored Moment	75.59 k-ft
Interior Span $M^-$ factor	0.65	Interior $M^-$ factored Moment	140.38 k-ft

Col Strip Factored Mom.

$M^+$	0.6
Exterior $M^-$	0.75
Interior $M^-$	0.75

Mid Strip Factored Mom

	0.4
	0.25
	0.25

Exterior Positive Moment

Column Strip	157.559 k-ft
Moment per foot of width	17.8376 k-ft/ft
$Mu/\phi$	19.8195 k-ft/ft
$Mu/\phi$	237.834 k-in/ft
$A_s$	0.79601 in <sup>2</sup>
a	1.04053
#4 Bar Spacing	3.02 in oc
#5 Bar Spacing	4.67 in oc
#6 Bar Spacing	6.63 in oc
#7 Bar Spacing	9.05 in oc
#8 Bar Spacing	11.91 in oc

Middle Strip	105.04 k-ft
Moment per foot of width	11.892 k-ft/ft
$Mu/\phi$	13.213 k-ft/ft
$Mu/\phi$	158.56 k-in/ft
$A_s$	0.5116 in <sup>2</sup>
a	0.6687
#4 Bar Spacing	4.69 in oc
#5 Bar Spacing	7.27 in oc
#6 Bar Spacing	10.32 in oc
#7 Bar Spacing	14.07 in oc
#8 Bar Spacing	18.53 in oc

Exterior Negative Moment

Enter new d for Col strip	9.5
Column Strip	234.463 k-ft
Moment per foot of width	26.544 k-ft/ft
$Mu/\phi$	29.4933 k-ft/ft
$Mu/\phi$	353.92 k-in/ft
$A_s$	0.64998 in <sup>2</sup>
a	0.84964
#4 Bar Spacing	3.69 in oc
#5 Bar Spacing	5.72 in oc
#6 Bar Spacing	8.12 in oc
#7 Bar Spacing	11.08 in oc
#8 Bar Spacing	14.59 in oc

Middle Strip	78.154 k-ft
Moment per foot of width	8.848 k-ft/ft
$Mu/\phi$	9.8311 k-ft/ft
$Mu/\phi$	117.97 k-in/ft
$A_s$	0.3741 in <sup>2</sup>
a	0.4891
#4 Bar Spacing	6.41 in oc
#5 Bar Spacing	9.94 in oc
#6 Bar Spacing	14.11 in oc
#7 Bar Spacing	19.24 in oc
#8 Bar Spacing	25.34 in oc

Interior Positive Moment

Column Strip 87.5329 k-ft  
Moment per foot of width 9.90976 k-ft/ft  
Mu/φ 11.0108 k-ft/ft  
Mu/φ 132.13 k-in/ft  
As 0.42151 in<sup>2</sup>  
a 0.55099  
#4 Bar Spacing 5.69 in oc  
#5 Bar Spacing 8.83 in oc  
#6 Bar Spacing 12.53 in oc  
#7 Bar Spacing 17.08 in oc  
#8 Bar Spacing 22.49 in oc

Middle Strip 58.355 k-ft  
Moment per foot of width 6.6065 k-ft/ft  
Mu/φ 7.3406 k-ft/ft  
Mu/φ 88.087 k-in/ft  
As 0.276 in<sup>2</sup>  
a 0.3608  
#4 Bar Spacing 8.70 in oc  
#5 Bar Spacing 13.48 in oc  
#6 Bar Spacing 19.13 in oc  
#7 Bar Spacing 26.09 in oc  
#8 Bar Spacing 34.35 in oc

Interior Negative Moment

Enter new d for Col strip 9.5 in  
Column Strip 203.201 k-ft  
Moment per foot of width 23.0048 k-ft/ft  
Mu/φ 25.5609 k-ft/ft  
Mu/φ 306.731 k-in/ft  
As 0.55967 in<sup>2</sup>  
a 0.7316  
#4 Bar Spacing 4.29 in oc  
#5 Bar Spacing 6.65 in oc  
#6 Bar Spacing 9.43 in oc  
#7 Bar Spacing 12.86 in oc  
#8 Bar Spacing 16.94 in oc

Middle Strip 67.734 k-ft  
Moment per foot of width 7.6683 k-ft/ft  
Mu/φ 8.5203 k-ft/ft  
Mu/φ 102.24 k-in/ft  
As 0.3222 in<sup>2</sup>  
a 0.4211  
#4 Bar Spacing 7.45 in oc  
#5 Bar Spacing 11.55 in oc  
#6 Bar Spacing 16.39 in oc  
#7 Bar Spacing 22.35 in oc  
#8 Bar Spacing 29.43 in oc

How Far past support must negative moment reinf. Extend?

Column Strip 5.44511 ft  
Middle Strip 3.63007 ft


Use 6 ft  
Use 4 ft

COLUMN DESIGN

$$DL = 115 \text{ psf} (18.75')^2 (1.32) (1 + 0.2 \overset{0.25 \text{ ds}}{(0.64)}) = 60.2 \text{ K}$$

$$SL = 82 \text{ psf} (18.75')^2 (1.32) = 38 \text{ K}$$

$$S_{soil} = 75 \text{ psf} (18.75')^2 (1.32) = 34.8 \text{ K}$$



$$H = \pi (1.25') (62.4 \text{ pcf}) (17 \frac{1}{2}')^2 + 0.4 (0.64) (1.25') (1.2')^2 (150 \text{ pcf}) = 149 \text{ pcf}$$

USE 16" Ø COLUMN w/ (8) #5 BARS

Find TRANSVERSE REINF ⇒ ACI 350 CH 21.4.4

$$\rho_s = 0.12 (4.5) / 60 \text{ ksi} = 0.009$$

$$\text{SPACING} = 16 \frac{1}{4} = 4"$$

$$6 (\frac{5}{8}) = 3.75"$$

PER 10.9.3

$$\rho_s \Rightarrow A_g = \pi (16)^2 / 4 = 201 \text{ in}^2$$

$$A_c = \pi (12)^2 / 4 = 113 \text{ in}^2$$

$$\rho_s = 0.45 \left( \frac{201}{113} - 1 \right) \frac{4.5}{60} = 0.026 \checkmark \text{ CONTRLS}$$

$$\text{REQ'D PITCH \#4 TIES} = 0.026 = \frac{0.20 (\pi) (12.5 \text{ in})}{113 (s)} = 2.7 \text{ in} \quad S_{REQ'D} = 2.5"$$

$$\text{SPACING OF \#3 HOOPS} = 0.009 = \frac{0.11 (\pi) (12.625 \text{ in})}{113 (s)} = 4.2 \text{ in} \quad S_{REQ'D} = 4"$$

USE #4 SPIRAL TIES @ 2.5" PITCH  
OR #3 HOOPS @ 3" O.C.

Title Block Line 1  
You can change this area  
using the "Settings" menu item  
and then using the "Printing &  
Title Block" selection  
Title Block Line 6

Project Title:  
Engineer:  
Project Descr:

Project ID

### Concrete Column

Project 26191402 - Water Tank at Wolf Creek Engineering Calculations Sheet 19-47 wof creek water tank.xls  
ENERCALC, INC. 1993-2018, Build: 16.10.31, Ver: 16.10.31

Description: 14" Square Concrete Column

#### Code References

Calculations per ACI 318-11, IBC 2012, CBC 2013, ASCE 7-10  
Load Combinations Used ASCE 7-10

#### General Information


f'c - Concrete 28 day strength = 4,500 ksi  
E = 3,823,68 ksi  
Density = 150 lb/cft  
 $\beta$  = 0.8250  
fy - Main Rebar = 80,000 ksi  
E - Main Rebar = 29,000,000 ksi  
Allow. Reinforcing Limits  
Min. Reinf. = 1.0 %  
Max. Reinf. = 8.0 %

Circular Column Height = 17.0 ft  
End Fixity Top & Bottom Pinned  
Base condition for deflection (backing) along column(s):  
X-X (width) axis  
Unbraced Length for X-X Axis backing = 17.0 ft,  $K_x = 1.0$   
Y-Y (depth) axis  
Unbraced Length for Y-Y Axis backing = 17.0 ft,  $K_y = 1.0$

#### Column Cross Section

Column Dimensions: 14.0in Square Column, Column Edge to  
Rebar Edge Cover = 2.0in

Column Reinforcing: 4 - #5 bars @ corners, 1 - #5 bars top &  
bottom between corner bars, 1 - #5 bars left  
& right between corner bars



#### Applied Loads

Column self weight (calculated): 3,470.83 lbs \* Dead Load Factor  
AXIAL LOADS  
Axial Load at 17.0 ft above base, Xact = 3.0k, Yact = 3.0k, D = 60.2k, S = 38.0, H = 35.0 k  
BENDING LOADS  
Lat. Uniform Load creating Mx, E = 0.1490 k/ft

Entered loads are factored per load combinations specified by user

#### DESIGN SUMMARY

Load Combination = +1.2D+1.6S+1.6H  
Location of max. above base = 16.886 ft

Maximum Stress Ratio = 0.808 : 1

Ratio =  $(P_u^2 + M_u^2)^{0.5} / (F_y P_n^2 + F_y M_n^2)^{0.5}$   
Pu = 193,205 k  $\phi^* P_n$  = 237,843 k  
Mu x = -47,260 k-ft  $\phi^* M_n x$  = -58,324 k-ft  
Mu y = 47,260 k-ft  $\phi^* M_n y$  = 58,688 k-ft

Mu Angle = 45.0 deg  $\phi^* M_n$  at Angle = 82,750 k-ft  
Mu at Angle = 66,836 k-ft  $\phi^* M_n$  at Angle = 82,750 k-ft

Pn & Mn values located at Pu-Mu vector intersection with capacity curve

Column Capacities  
Fymin - Nominal Max. Compressive Axial Capacity = 889,011 k  
Fymin - Nominal Min. Tensile Axial Capacity = -148,880 k  
 $\phi^* P_n$  max. Usable Compressive Axial Capacity = 463,287 k  
 $\phi^* P_n$  min. Usable Tensile Axial Capacity = -96,720 k

#### Governing Load Combination Results

Governing Factored Load Combination	Moment		Dist. from base ft	Axial Load k			Bending Analysis k-ft					Utilization Ratio	
	X-X	Y-Y		Pu	$\phi^* P_n$	$\delta_x$	$\delta_x^* M_{ux}$	$\delta_y$	$\delta_y^* M_{uy}$	Alpha (deg)	$\delta M_u$		$\phi^* M_n$
+1.40D+1.60H	193.2	47.3	16.9	193.2	244.8	1.00	193.2	170	167	45.0	170	227.3	0.808

Title Block Line 1  
You can change this area  
using the "Settings" menu item  
and then using the "Printing &  
Title Block" selection  
Title Block Line 6

Project Title:  
Engineer:  
Project Descr:

Project ID

### Concrete Column

Project 26191402 - Water Tank at Wolf Creek Engineering Calculations Sheet 19-42 wof creek water tank.xls  
ENERCALC, INC. 1993-2018, Build: 16.10.31, Ver: 16.10.31

Description: 14" Square Concrete Column

#### Governing Load Combination Results

Governing Factored Load Combination	Moment		Dist. from base ft	Axial Load k			Bending Analysis k-ft					Utilization Ratio	
	X-X	Y-Y		Pu	$\phi^* P_n$	$\delta_x$	$\delta_x^* M_{ux}$	$\delta_y$	$\delta_y^* M_{uy}$	Alpha (deg)	$\delta M_u$		$\phi^* M_n$
+1.20D+1.60H	193.2	47.3	16.9	193.2	244.8	1.00	193.2	170	167	45.0	170	227.3	0.808

#### Maximum Reactions

Load Combination	Reaction along X-X Axis		Reaction along Y-Y Axis		Axial Reaction @ Base
	@ Base	@ Top	@ Base	@ Top	
+D+H	1,400	1,400 k	1,400	1,400 k	88,671 k
+D+S+H	1,959	1,959 k	1,959	1,959 k	138,671 k
+D+0.75D+S+H	1,819	1,819 k	1,819	1,819 k	127,171 k
+D+0.75E+H	1,400	1,400 k	0,515	2,287 k	88,671 k
+D+0.75D+S+0.525E+H	1,819	1,819 k	1,154	2,484 k	127,171 k
+D+0.60D+0.60H	0,840	0,840 k	0,840	0,840 k	58,203 k
+D+0.60D+0.75E+0.60H	0,840	0,840 k	0,947	1,727 k	59,203 k
D Only	0,685	0,685 k	0,685	0,685 k	67,671 k
S Only	0,559	0,559 k	0,559	0,559 k	38,004 k
E Only			1,287	1,287 k	
H Only	0,515	0,515 k	0,515	0,515 k	35,000 k

#### Maximum Moments

Load Combination	Moment About X-X Axis		Moment About Y-Y Axis	
	@ Base	@ Top	@ Base	@ Top
+D+H	23,500		23,600	
+D+S+H	33,300		33,300	
+D+0.75D+S+H	32,825		30,625	
+D+0.75E+H	23,600		23,600	
+D+0.75D+S+0.525E+H	30,925		32,525	
+D+0.60D+0.60H	14,280		14,280	
+D+0.60D+0.75E+0.60H	14,280		14,280	
D Only	15,150		15,050	
S Only	9,500		9,500	
H Only	8,750		8,750	

#### Maximum Deflections for Load Combinations

Load Combination	Max. X-X Deflection		Max. Y-Y Deflection	
	Distance	Value	Distance	Value
+D+H	0.0428 in	8.928 ft	0.0603 in	9.925 ft
+D+S+H	0.0479 in	9.928 ft	0.0603 in	9.925 ft
+D+0.75D+S+H	0.0418 in	9.928 ft	0.0603 in	9.925 ft
+D+0.75E+H	0.0428 in	9.928 ft	-0.0477 in	10.363 ft
+D+0.75D+S+0.525E+H	0.0418 in	9.928 ft	-0.0700 in	10.154 ft
+D+0.60D+0.60H	0.0372 in	9.928 ft	-0.0398 in	9.925 ft
+D+0.60D+0.75E+0.60H	0.0377 in	9.928 ft	-0.0727 in	10.839 ft
D Only	0.0397 in	9.928 ft	-0.0440 in	9.925 ft
S Only	0.0251 in	9.925 ft	0.0225 in	9.925 ft
E Only	0.0000 in	0.000 ft	0.0273 in	8.557 ft
H Only	0.0281 in	9.928 ft	-0.0281 in	9.928 ft



Title Block Line 1  
 You can change this area  
 using the "Settings" menu item  
 and then using the "Printing &  
 Title Block" selection  
 Title Block Line 5

Project Title:  
 Engineer:  
 Project Descr:


Project ID:

### Concrete Column



Project 21101942 - Water Tank at Wolf Creek Engineering Calculations 01/14/12 wlf creek water tank en  
 ENERCAL, INC. 19832016, Suite 14, 15, 31, 32  
 Licensee: ARW ENGINEERS

Description: 14" Square Concrete Column

#### Sketches



#### Interaction Diagrams



Title Block Line 1  
 You can change this area  
 using the "Settings" menu item  
 and then using the "Printing &  
 Title Block" selection  
 Title Block Line 5





Project Title:  
 Engineer:  
 Project Descr:

Project ID:

### Concrete Column

Project 21101942 - Water Tank at Wolf Creek Engineering Calculations 01/14/12 wlf creek water tank en  
 ENERCAL, INC. 19832016, Suite 14, 15, 31, 32  
 Licensee: ARW ENGINEERS

Description: 14" Square Concrete Column



Title Block Line 1  
You can change this area  
using the "Settings" menu item  
and then using the "Printing &  
Title Block" selection



Project Title  
Engineer:  
Project Descr:

Project ID

### Concrete Column

Project 201616432 - Water Tank at Wolf Creek Engineering Calculations Sheet 16 of 24  
SHERCALS, INC. 1985 2016 (Sheet 16 of 24), Ver 3.16.16.31  
Landscape PART ENGINEERS

Description 14" Square Concrete Column



Title Block Line 1  
You can change this area  
using the "Settings" menu item  
and then using the "Printing &  
Title Block" selection  
Title Block Line 6

Project Title  
Engineer:  
Project Descr:  
Project ID

### Concrete Column

Project: 201611402 - Water Tank at Wolf Creek Engineering Calculations: 01/04/17 wolf creek water tank 40  
ENR/CALC. INC. 1983-2218, Suite 18, 1031, W. 8, 14, 15, 31

Description: 10" Concrete Column

#### Code References

Calculations per ACI 318-11, IBC 2012, CBC 2013, ASCE 7-10  
Load Combinations Used: ASCE 7-10

#### General Information


f'c - Concrete 28 day strength = 4,500 ksi  
E - = 3,823,888 ksi  
Density = 150.0 pcf  
 $\beta$  = 0.8250  
fy - Main Rebar = 60.0 ksi  
E - Main Rebar = 29,000,000 ksi  
Min. Reinforcing Limits  
Min. Reinf = 1.0 %  
Max. Reinf = 8.0 %

Overall Column Height = 17.0 ft  
End Fixity: Top & Bottom Pinned  
Basis condition for deflection (buckling) along column:  
X-X (width) axis  
Unbraced Length for X-X Axis buckling = 17.0 ft, K = 1.0  
Y-Y (depth) axis  
Unbraced Length for Y-Y Axis buckling = 17.0 ft, K = 1.0

#### Column Cross Section

Column Dimensions: 16.0in Diameter, Column Edge to Rebar  
Edge Cover = 2.0in

Column Reinforcing: 8.0 - #5 bars



Entered loads are factored per load combinations specified by user

#### Applied Loads

Column self weight included: 3,560.47 lbs \* Dead Load Factor  
AXIAL LOADS  
Axial Load at 17.0 ft above base, Xsec = 3.0in, Ysec = 3.0in, D = 60.20, S = 38.0, H = 39.9 k  
BENDING LOADS  
Lat. Uniform Load creating Mx-x, E = 0.140 k/ft

#### DESIGN SUMMARY

Load Combination: +1.20D+1.60S+1.60H  
Location at max above base: 16.888 ft

Maximum Stress Ratio: 0.648 : 1

Ratio =  $(P_u/2 + M_x/2) * 5 / ((P_u/2 + M_x/2) + (P_u/2 + M_y/2) * 5)$

$P_u = 103,313$  k,  $\phi * P_u = 297,578$  k

$M_{x-x} = -47,260$  k-ft,  $\phi * M_{x-x} = -72,003$  k-ft

$M_{y-y} = 47,260$  k-ft,  $\phi * M_{y-y} = 72,003$  k-ft

Max Angle = 45.0 deg

Min at Angle = 68.836 k-ft,  $\phi M_{n}$  at Angle = 103,150 k-ft

$P_u$  &  $M_{x-x}$  values located at  $P_u$ - $M_{x-x}$  vector intersection with capacity curve

Column Capacities ...

Phi\*max. Nominal Max. Compressive Axial Capacity: 908.38 k

Phi\*min. Nominal Min. Tension Axial Capacity: -148.80 k

Phi\*Phi\_max. Ultimate Compressive Axial Capacity: 579.09 k

Phi\*Phi\_min. Ultimate Tension Axial Capacity: -111.60 k

#### Governing Load Combination Results

Governing Factored Load Combination	Moment		Dist. from base ft	Axial Load k		Bending Analysis k-ft					Utilization Ratio		
	X-X	Y-Y		Pu	phi*Pu	delta_x	delta_x*Mu_x	delta_y	delta_y*Mu_y	Alpha (deg)	phi*Mu	phi*Mn	Ratio
+1.40D+1.60H	Actual	Actual	16.88	103.35	300.81	1.000	22.81	1.100	25.07	45.000	45.00	101.02	0.483

Title Block Line 1  
You can change this area  
using the "Settings" menu item  
and then using the "Printing &  
Title Block" selection  
Title Block Line 6

Project Title  
Engineer:  
Project Descr:  
Project ID

### Concrete Column

Project: 201611402 - Water Tank at Wolf Creek Engineering Calculations: 01/04/17 wolf creek water tank 40  
ENR/CALC. INC. 1983-2218, Suite 18, 1031, W. 8, 14, 15, 31

Description: 10" Concrete Column

#### Governing Load Combination Results

Governing Factored Load Combination	Moment		Dist. from base ft	Axial Load k		Bending Analysis k-ft					Utilization Ratio		
	X-X	Y-Y		Pu	phi*Pu	delta_x	delta_x*Mu_x	delta_y	delta_y*Mu_y	Alpha (deg)	phi*Mu	phi*Mn	Ratio
+1.20D+1.60H	Actual	Actual	16.88	103.35	300.81	1.000	22.81	1.100	25.07	45.000	45.00	101.02	0.483
+1.20D+0.50S+1.60H	Actual	Actual	16.88	151.31	307.91	1.000	22.81	1.070	25.07	45.000	45.00	101.02	0.508
+1.20D+1.60S+1.60H	Actual	Actual	16.88	150.31	297.58	1.000	22.81	1.070	25.07	45.000	45.00	101.02	0.508
+1.20D+0.20S+E+1.60H	Actual	Actual	16.88	140.11	293.48	1.000	22.81	1.080	25.07	45.000	45.00	101.02	0.504
+0.90D+0.90H	Actual	Actual	16.88	99.58	274.81	1.000	22.81	1.080	25.07	45.000	45.00	101.02	0.504
+0.90D+E+0.90H	Actual	Actual	16.88	88.38	273.27	1.000	22.81	1.090	25.07	45.000	45.00	101.02	0.511

#### Maximum Reactions

Load Combination	Reaction along X-X Axis		Reaction along Y-Y Axis		Axial Reaction @ Base
	@ Base	@ Top	@ Base	@ Top	
+D+H	1.400	1.400 k	1.400	1.400 k	98,780 k
+D+S+H	1.958	1.958 k	1.958	1.958 k	136,790 k
+D+0.750S+H	1.818	1.818 k	1.818	1.818 k	127,200 k
+D+0.70E+H	1.400	1.400 k	0.513	2.287 k	98,780 k
+D+0.750S+0.5250E+H	1.818	1.818 k	1.154	2.484 k	127,200 k
+0.80D+0.60H	0.840	0.840 k	0.840	0.840 k	68,208 k
+0.80D+0.70E+0.60H	0.840	0.840 k	0.047	1.724 k	59,256 k
D Only	0.885	0.885 k	0.885	0.885 k	83,760 k
S Only	0.559	0.559 k	0.559	0.559 k	38,808 k
E Only			1.267	1.267 k	
H Only	0.515	0.515 k	0.515	0.515 k	35,000 k

#### Maximum Moments

Load Combination	Moment About X-X Axis		k-ft	Moment About Y-Y Axis		k-ft
	@ Base	@ Top		@ Base	@ Top	
+D+H	23,800		23,800		23,800	23,800
+D+S+H	33,300		33,300		33,300	33,300
+D+0.750S+H	30,925		30,925		30,925	30,925
+D+0.70E+H	23,800		23,800		23,800	23,800
+D+0.750S+0.5250E+H	30,925		30,925		30,925	30,925
+0.80D+0.60H	14,280		14,280		14,280	14,280
+0.80D+0.70E+0.60H	14,280		14,280		14,280	14,280
D Only	15,050		15,050		15,050	15,050
S Only	9,500		9,500		9,500	9,500
H Only	8,750		8,750		8,750	8,750

#### Maximum Deflections for Load Combinations

Load Combination	Max. X-X Deflection		Distance ft	Max. Y-Y Deflection		Distance ft
	in	ft		in	ft	
+D+H	0.0825	0.0068	9.926	0.0825	0.0068	9.926
+D+S+H	0.0875	0.0072	9.926	0.0875	0.0072	9.926
+D+0.750S+H	0.0812	0.0066	9.926	0.0812	0.0066	9.926
+D+0.70E+H	0.0625	0.0051	9.926	0.047	0.0038	9.926
+D+0.750S+0.5250E+H	0.0812	0.0066	9.926	0.0812	0.0066	9.926
+0.80D+0.60H	0.0375	0.0029	9.926	0.035	0.0027	9.926
+0.80D+0.70E+0.60H	0.0375	0.0029	9.926	0.022	0.0017	10.839
D Only	0.0365	0.0028	9.926	0.040	0.0030	9.926
S Only	0.0250	0.0019	9.926	0.025	0.0019	9.926
E Only	0.0600	0.0047	9.926	0.023	0.0017	8.557
H Only	0.0250	0.0019	9.926	0.023	0.0017	9.926

Title Block Line 1  
 You can change this area  
 using the "Settings" menu item  
 and then using the "Printing &  
 Title Block" selection.

Project Title  
 Engineer:  
 Project Descr:


Project ID

**Concrete Column**



Project: 201616402 - Water Tank at Wolf Creek Engineering/Civil/Structural/16402.wolf creek water tank at  
 ENERCALC, INC. 1983-2016, Build 16.00.11 Ver 6.16.10.31

License: ARV ENGINEERS  
 Description: 14" Concrete Column

**Sketches**



**Interaction Diagrams**



Title Block Line 1  
 You can change this area  
 using the "Settings" menu item  
 and then using the "Printing &  
 Title Block" selection.




Project Title  
 Engineer:  
 Project Descr:

Project ID

**Concrete Column**

Project: 201616402 - Water Tank at Wolf Creek Engineering/Civil/Structural/16402.wolf creek water tank at  
 ENERCALC, INC. 1983-2016, Build 16.00.11 Ver 6.16.10.31

License: ARV ENGINEERS  
 Description: 14" Concrete Column



Title Block Line 1  
You can change this area  
using the "Settings" menu item  
and then using the "Printing &  
Title Block" section  
Title Block Line 6



Project Title  
Engineer:  
Project Descr:

Project ID

### Concrete Column

Project: 21016462 - Water Tank at West Coast Engineering Calculated: 05/07/2012 10:07:00 AM  
ENRHALO, INC. 1980-2018, Suite 11, 9330, Ver 9.16.10.31  
License: JRV ENGINEER

Description: R1 Concrete Column



Title Block Line 1  
You can change this area  
using the "Settings" menu item  
and then using the "Printing &  
Title Block" selection.

Project Title  
Engineer  
Project Descr.

Project ID

**General Footing**

Project 21811442 - Water Tank at Wolf Creek Engineering Calculations 11/4/21  
ENERCALC, INC. 1183 29th, Suite 516 10 31, Var 5, 14, 10 31  
11/4/21 10:31 AM  
Author: ARW ENGINEERS

Description: Typical Column Footing

**Code References**

Calculations per ACI 318-11, IBC 2012, CBC 2013, ASCE 7-10  
Load Combinations Used ASCE 7-10

**General Information**


<b>Material Properties</b>		<b>Soil Design Values</b>	
f <sub>c</sub> Concrete 28 day strength	= 4.50 ksi	Allowable Soil Bearing	= 3.50 ksf
f <sub>y</sub> Rebar Yield	= 60.0 ksi	Increase Bearing by Footing Weight	= No
E <sub>c</sub> Concrete Elastic Modulus	= 3,823.68 ksi	Soil Passive Resistance (for Sliding)	= 250.0 pcf
Concrete Density	= 145.0 pcf	Soil/Concrete Friction Coeff.	= 0.30
ψ Value: Flexure	= 0.90	<b>Increases based on footing depth</b>	
ψ Value: Shear	= 0.750	Footing base depth below soil surface	= 0.0 ft
<b>Analysis Settings</b>		Allow press. increase per foot of depth	= 0.0 ksf
Min. Steel % Bending Reinf.	=	when footing base is below	= 0.0 ft
Min. Allow % Temp. Reinf.	= 0.00180	<b>Increases based on footing plan dimension</b>	
Min. Overturning Safety Factor	= 1.0 : 1	Allowable pressure increase per foot of depth	=
Min. Sliding Safety Factor	= 1.0 : 1	when max. length or width is greater than	= 0.0 ksf
Add Ftg Wt for Soil Pressure	Yes		
Use Ftg Wt for stability, moments & shears	Yes		
Add Pedestal Wt for Soil Pressure	No		
Use Pedestal Wt for stability, mom & shear	No		

**Dimensions**

Width parallel to X-X Axis	= 6.50 ft
Length parallel to Z-Z Axis	= 6.50 ft
Footing Thickness	= 18.0 in

**Pedestal dimensions:**

px: parallel to X-X Axis	= 14.0 in
py: parallel to Z-Z Axis	= 14.0 in
Height	= 0.0 in
Rebar Centerline to Edge of Concrete at Bottom of footing	= 3.0 in



**Reinforcing**

<b>Bars parallel to X-X Axis</b>	
Number of Bars	= 7
Reinforcing Bar Size	= # 6
<b>Bars parallel to Z-Z Axis</b>	
Number of Bars	= 7
Reinforcing Bar Size	= # 6



Bar/Width Distribution Check (ACI 18.4.4.2)  
Direction Resisting Closer Separation: n/a  
# Bars required within zone: n/a  
# Bars required on each side of zone: n/a

**Applied Loads**

	D	Lr	L	S	W	E	H
P: Column Load	= 60.20	0.0	0.0	0.0	0.0	0.0	35.0 k
OB: Overburden	= 0.0	0.0	0.0	0.0	0.0	0.0	0.0 ksf
M:xx	= 0.0	0.0	0.0	0.0	0.0	0.0	0.0 k-ft
M:zz	= 0.0	0.0	0.0	0.0	0.0	0.0	0.0 k-ft
V:x	= 0.0	0.0	0.0	0.0	0.0	0.0	0.0 k
V:z	= 0.0	0.0	0.0	0.0	0.0	0.0	0.0 k

Title Block Line 1  
You can change this area  
using the "Settings" menu item  
and then using the "Printing &  
Title Block" selection.

Project Title  
Engineer  
Project Descr.

Project ID

**General Footing**

Project 21811442 - Water Tank at Wolf Creek Engineering Calculations 11/4/21  
ENERCALC, INC. 1183 29th, Suite 516 10 31, Var 5, 14, 10 31  
11/4/21 10:31 AM  
Author: ARW ENGINEERS

Description: Typical Column Footing

**DESIGN SUMMARY**

	Min. Ratio	Item	Applied	Capacity	Governing Load Combination
PASS	0.9900	Soil Bearing	3.346 ksf	3.50 ksf	+D+S+H about Z-Z axis
PASS	n/a	Overturning - X-X	0.0 k-ft	0.0 k-ft	No Overturning
PASS	n/a	Overturning - Z-Z	0.0 k-ft	0.0 k-ft	No Overturning
PASS	n/a	Sliding - X-X	0.0 k	0.0 k	No Sliding
PASS	n/a	Sliding - Z-Z	0.0 k	0.0 k	No Sliding
PASS	n/a	Uplift	0.0 k	0.0 k	No Uplift
PASS	0.5878	Z Flexure (+X)	15.905 k-ft	27.060 k-ft	+1.20D+0.50L+1.60S+1.60H
PASS	0.5878	Z Flexure (-X)	15.905 k-ft	27.060 k-ft	+1.20D+0.50L+1.60S+1.60H
PASS	0.5878	X Flexure (+Z)	15.905 k-ft	27.060 k-ft	+1.20D+0.50L+1.60S+1.60H
PASS	0.5878	X Flexure (-Z)	15.905 k-ft	27.060 k-ft	+1.20D+0.50L+1.60S+1.60H
PASS	0.4832	1-way Shear (-X)	46.608 psi	100.623 psi	+1.20D+0.50L+1.60S+1.60H
PASS	0.4832	1-way Shear (+X)	46.608 psi	100.623 psi	+1.20D+0.50L+1.60S+1.60H
PASS	0.4832	1-way Shear (-Z)	46.608 psi	100.623 psi	+1.20D+0.50L+1.60S+1.60H
PASS	0.4832	1-way Shear (+Z)	46.608 psi	100.623 psi	+1.20D+0.50L+1.60S+1.60H
PASS	0.5347	2-way Punching	119.683 psi	201.246 psi	+1.20D+0.50L+1.60S+1.60H

**Detailed Results**

Soil Bearing Rotation Axis & Load Combination...	Gross Allowable	Yecc (in)	Zecc (in)	Actual Soil Bearing Stress @ Location				Actual / Allow Ratio
				Bottom -Z	Top -Z	Left -X	Right +X	
X-X +D+H	3.50	n/a	0.0	2.447	2.447	n/a	n/a	0.697
X-X +D+L+H	3.50	n/a	0.0	2.447	2.447	n/a	n/a	0.697
X-X +D+L+H+H	3.50	n/a	0.0	2.447	2.447	n/a	n/a	0.697
X-X +D+H	3.50	n/a	0.0	3.346	3.346	n/a	n/a	0.956
X-X +D+0.750L+0.750L+H	3.50	n/a	0.0	2.447	2.447	n/a	n/a	0.697
X-X +D+0.750L+0.750S+H	3.50	n/a	0.0	3.121	3.121	n/a	n/a	0.892
X-X +D+0.60W+H	3.50	n/a	0.0	2.447	2.447	n/a	n/a	0.697
X-X +D+0.70E+H	3.50	n/a	0.0	2.447	2.447	n/a	n/a	0.697
X-X +D+0.750L+0.750L+0.450W+H	3.50	n/a	0.0	2.447	2.447	n/a	n/a	0.697
X-X +D+0.750L+0.750S+0.450W+H	3.50	n/a	0.0	3.121	3.121	n/a	n/a	0.892
X-X +D+0.750L+0.750S+0.5250E+H	3.50	n/a	0.0	3.121	3.121	n/a	n/a	0.892
X-X +0.600+0.60W+0.60H	3.50	n/a	0.0	1.468	1.468	n/a	n/a	0.419
X-X +0.600E+0.70E+0.60H	3.50	n/a	0.0	1.468	1.468	n/a	n/a	0.419
Z-Z +D+H	3.50	0.0	n/a	n/a	n/a	2.447	2.447	0.697
Z-Z +D+L+H	3.50	0.0	n/a	n/a	n/a	2.447	2.447	0.697
Z-Z +D+L+H+H	3.50	0.0	n/a	n/a	n/a	2.447	2.447	0.697
Z-Z +D+H	3.50	0.0	n/a	n/a	n/a	3.346	3.346	0.956
Z-Z +D+0.750L+0.750L+H	3.50	0.0	n/a	n/a	n/a	2.447	2.447	0.697
Z-Z +D+0.750L+0.750S+H	3.50	0.0	n/a	n/a	n/a	3.121	3.121	0.892
Z-Z +D+0.60W+H	3.50	0.0	n/a	n/a	n/a	2.447	2.447	0.697
Z-Z +D+0.70E+H	3.50	0.0	n/a	n/a	n/a	2.447	2.447	0.697
Z-Z +D+0.750L+0.750L+0.450W+H	3.50	0.0	n/a	n/a	n/a	2.447	2.447	0.697
Z-Z +D+0.750L+0.750S+0.450W+H	3.50	0.0	n/a	n/a	n/a	3.121	3.121	0.892
Z-Z +D+0.750L+0.750S+0.5250E+H	3.50	0.0	n/a	n/a	n/a	3.121	3.121	0.892
Z-Z +0.600+0.60W+0.60H	3.50	0.0	n/a	n/a	n/a	1.468	1.468	0.419
Z-Z +0.600E+0.70E+0.60H	3.50	0.0	n/a	n/a	n/a	1.468	1.468	0.419

**Overturning Stability**

Rotation Axis & Load Combination...	Overturning Moment	Resisting Moment	Stability Ratio	Status
Footing Has NO Overturning				As Limit #
<b>Sliding Stability</b>				
Force Application Axis Load Combination...	Sliding Force	Resisting Force	Stability Ratio	Status
Footing Has NO Sliding				

Title Block Line 1  
You can change this area  
using the "Settings" menu item  
and then using the "Printing &  
Title Block" selection.

Project Title  
Engineer  
Project Descr:

Project ID:

**General Footing**

Project 20161842 - Water Tank at Work Creek Engineering Calculations/Chart/1842 and tank water tank.xls  
ENERCAL, INC. 1843-016, Sheet 16 of 31, Ver 6.16.12.31  
License #: ARW ENGINEERS

Description: Typical Column Footing

Footing Flexure								
Flexure Axis & Load Combination	Mu k-ft	Side	Tension Surface	As Req'd in <sup>2</sup>	Gvrr. As in <sup>2</sup>	Actual As in <sup>2</sup>	Phi*Mu k-ft	Status
X-X, +1.40D+1.60H	11.802	+Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK

Title Block Line 1  
You can change this area  
using the "Settings" menu item  
and then using the "Printing &  
Title Block" selection.

Project Title  
Engineer  
Project Descr:

Project ID:

**General Footing**

Project 20161842 - Water Tank at Work Creek Engineering Calculations/Chart/1842 and tank water tank.xls  
ENERCAL, INC. 1843-016, Sheet 16 of 31, Ver 6.16.12.31  
License #: ARW ENGINEERS

Description: Typical Column Footing

Footing Flexure										
Flexure Axis & Load Combination	Mu k-ft	Side	Tension Surface	As Req'd in <sup>2</sup>	Gvrr. As in <sup>2</sup>	Actual As in <sup>2</sup>	Phi*Mu k-ft	Status		
X-X, +1.40D+1.60H	11.802	-Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
X-X, +1.20D+0.50L+1.60L+1.60H	10.789	+Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
X-X, +1.20D+0.50L+1.60L+1.60H	10.789	-Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
X-X, +1.20D+1.60L+0.50S+1.60H	12.388	+Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
X-X, +1.20D+1.60L+0.50S+1.60H	12.388	-Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
X-X, +1.20D+1.60L+0.50W+1.60H	10.789	+Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
X-X, +1.20D+1.60L+0.50W+1.60H	10.789	-Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
X-X, +1.20D+0.50L+1.60S+1.60H	15.905	+Z	Bottom	0.3675980767574	Min ACI 10.5	0.4738	27.060	OK		
X-X, +1.20D+0.50L+1.60S+1.60H	15.905	-Z	Bottom	0.3675980767574	Min ACI 10.5	0.4738	27.060	OK		
X-X, +1.20D+1.60S+0.50W+1.60H	15.905	+Z	Bottom	0.3675980767574	Min ACI 10.5	0.4738	27.060	OK		
X-X, +1.20D+1.60S+0.50W+1.60H	15.905	-Z	Bottom	0.3675980767574	Min ACI 10.5	0.4738	27.060	OK		
X-X, +1.20D+0.50L+0.50L+W+1.60H	10.789	+Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
X-X, +1.20D+0.50L+0.50L+W+1.60H	10.789	-Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
X-X, +1.20D+0.50L+0.50S+W+1.60H	12.388	+Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
X-X, +1.20D+0.50L+0.50S+W+1.60H	12.388	-Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
X-X, +1.20D+0.50L+0.20S+E+1.60H	11.429	+Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
X-X, +1.20D+0.50L+0.20S+E+1.60H	11.429	-Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
X-X, +0.90D+W+0.90H	7.209	+Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
X-X, +0.90D+W+0.90H	7.209	-Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
X-X, +0.90D+E+0.90H	7.209	+Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
X-X, +0.90D+E+0.90H	7.209	-Z	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.40D+1.60H	11.802	+X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.40D+1.60H	11.802	-X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.20D+0.50L+1.60L+1.60H	10.789	+X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.20D+0.50L+1.60L+1.60H	10.789	-X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.20D+1.60L+0.50S+1.60H	12.388	+X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.20D+1.60L+0.50S+1.60H	12.388	-X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.20D+1.60L+0.50S+1.60H	12.388	+X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.20D+1.60L+0.50S+1.60H	12.388	-X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.20D+1.60L+0.50W+1.60H	10.789	+X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.20D+1.60L+0.50W+1.60H	10.789	-X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.20D+1.60L+0.50W+1.60H	10.789	+X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.20D+1.60L+0.50W+1.60H	10.789	-X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.20D+0.50L+1.60S+1.60H	15.905	+X	Bottom	0.3675980767574	Min ACI 10.5	0.4738	27.060	OK		
Z-Z, +1.20D+0.50L+1.60S+1.60H	15.905	-X	Bottom	0.3675980767574	Min ACI 10.5	0.4738	27.060	OK		
Z-Z, +1.20D+1.60S+0.50W+1.60H	15.905	+X	Bottom	0.3675980767574	Min ACI 10.5	0.4738	27.060	OK		
Z-Z, +1.20D+1.60S+0.50W+1.60H	15.905	-X	Bottom	0.3675980767574	Min ACI 10.5	0.4738	27.060	OK		
Z-Z, +1.20D+0.50L+0.50L+W+1.60H	10.789	+X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.20D+0.50L+0.50L+W+1.60H	10.789	-X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.20D+0.50L+0.50S+W+1.60H	12.388	+X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.20D+0.50L+0.50S+W+1.60H	12.388	-X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.20D+0.50L+0.20S+E+1.60H	11.429	+X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +1.20D+0.50L+0.20S+E+1.60H	11.429	-X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +0.90D+W+0.90H	7.209	+X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +0.90D+W+0.90H	7.209	-X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +0.90D+E+0.90H	7.209	+X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
Z-Z, +0.90D+E+0.90H	7.209	-X	Bottom	0.3456	Min Temp %	0.4738	27.060	OK		
One Way Shear										
Load Combination	Vu @ -X	Vu @ +X	Vu @ -Z	Vu @ +Z	Vu Max	Phi Vn	Vu / Phi Vn	Status		
+1.40D+1.60H	34.586 psi	34.586 psi	34.586 psi	34.586 psi	34.586 psi	100.623 psi	0.3437	OK		
+1.20D+0.50L+1.60L+1.60H	31.617 psi	31.617 psi	31.617 psi	31.617 psi	31.617 psi	100.623 psi	0.3142	OK		
+1.20D+1.60L+0.50S+1.60H	36.302 psi	36.302 psi	36.302 psi	36.302 psi	36.302 psi	100.623 psi	0.3629	OK		
+1.20D+1.60L+0.50L+1.60H	31.617 psi	31.617 psi	31.617 psi	31.617 psi	31.617 psi	100.623 psi	0.3142	OK		
+1.20D+1.60L+0.50W+1.60H	31.617 psi	31.617 psi	31.617 psi	31.617 psi	31.617 psi	100.623 psi	0.3142	OK		
+1.20D+0.50L+1.60S+1.60H	46.608 psi	46.608 psi	46.608 psi	46.608 psi	46.608 psi	100.623 psi	0.4632	OK		
+1.20D+0.50L+0.50L+W+1.60H	46.608 psi	46.608 psi	46.608 psi	46.608 psi	46.608 psi	100.623 psi	0.4632	OK		
+1.20D+0.50L+0.50S+W+1.60H	31.617 psi	31.617 psi	31.617 psi	31.617 psi	31.617 psi	100.623 psi	0.3142	OK		
+1.20D+0.50L+0.20S+E+1.60H	33.491 psi	33.491 psi	33.491 psi	33.491 psi	33.491 psi	100.623 psi	0.3326	OK		
+0.90D+W+0.90H	21.124 psi	21.124 psi	21.124 psi	21.124 psi	21.124 psi	100.623 psi	0.2099	OK		
+0.90D+E+0.90H	21.124 psi	21.124 psi	21.124 psi	21.124 psi	21.124 psi	100.623 psi	0.2099	OK		

Title Block Line 1  
 You can change this area  
 using the "Settings" menu item  
 and then using the "Printing &  
 Title Block" selection  
 Title Block Line 6

Project Title  
 Engineer  
 Project Descr

Project ID:

General Footing

Project: 20181442 - Water Tank at WW Treatment Engineering/Calculations/Other (547) wof steel tank tank  
 ENRICALO, INC. 193-2018, Suite 110, W 31, W 18, 10-31  
 License: V.A. 778 210223.000


Description: Typical Column Footing

Punching Shear				All units
Load Combination	Yu	Phi*Yn	Vu / Phi*Vn	Status
+1.4D+1.60H	88.813 kips	201.246 kips	0.4413	OK
+1.2D+0.50L+1.00L+1.60H	81.19 kips	201.246 kips	0.4034	OK
+1.2D+1.60L+0.50S+1.60H	93.219 kips	201.246 kips	0.4632	OK
+1.2D+1.60L+0.50L+1.60H	81.19 kips	201.246 kips	0.4034	OK
+1.2D+1.60L+0.50W+1.60H	81.19 kips	201.246 kips	0.4034	OK
+1.2D+0.50L+1.60S+1.60H	119.883 kips	201.246 kips	0.5947	OK
+1.2D+1.60S+0.50W+1.60H	119.883 kips	201.246 kips	0.5947	OK
+1.2D+0.50L+0.50L+W+1.60H	81.19 kips	201.246 kips	0.4034	OK
+1.2D+0.50L+0.50S+W+1.60H	93.219 kips	201.246 kips	0.4632	OK
+1.2D+0.50L+0.50S+E+1.60H	86.002 kips	201.246 kips	0.4273	OK
-0.90D+W+0.90H	54.245 kips	201.246 kips	0.2695	OK
-0.90D+E+0.90H	54.245 kips	201.246 kips	0.2695	OK



Project Name LPC - Upper System Tank  
 Project # 16194  
 Prepared By WWY  
 Date 11/21/2016

Program Author: TAB & DOC  
 Last Revised: 1/19/2006  
 Reviewed By: TAB



$H_{total}$	79 ft
H	46 ft
g	32.17 ft/s <sup>2</sup>
A	0.00969322
$T_c$	6.176463161 s
$S_{01}$	0.312 g
$S_{02}$	0.636 g
$T_b$	0.490566038 s
$C_1$	0.040011851
I	1.25
$d_{max}$	1.675555531 ft

Required Freeboard


Tank Volume	512241 Gallons
H <sub>l</sub> to Water	15.5 ft

New H <sub>l</sub>	15.5 ft
New $d_l$	0.5 ft

Height to Liquid after Freeboard Check (If desired to change from above)

$r_{ls}$	17 ft
T	0.167442881 s
$T_1$	0.090113205 s
$T_2$	6 s
$S_{01}$	0.444261016 g
$S_{02}$	0.636 g

height above base to highest level of structure  
 Approximate Fundamental Period as Per ASCE 7 eqn 12.8-7  
 Per ASCE 7  
 Per ASCE 7 (fig 22-15)  
 For periods less than  $T_c$   
 For periods  $\geq T_b$  and  $\leq T_2$




Find Pressure at Roof to Shell Interface from insufficient freeboard depth.

SA ( $T_c$ )	0.050514346 g
Theta	2.89180066 degrees
h	0.5 ft
$V_{empty}$	2945.243113 ft <sup>3</sup>
d	1.894787992 ft
$d/d$	0.263951417
$h_p/d$	0.263951417
$X_p/R$	0.75
$X_1$	28.125 ft
$\rho$	1.94 slugs/ft <sup>3</sup>
$F_{max}$	26.16 psf
$F_{min}$	367.82 psf

Spectral Acceleration at  $T_c$   
 Angle of free surface at sloshing load  
 height from top of wall to underside of topmost point of lid  
 Empty Volume of tank above water  
 Vertical displacement of liquid surface

Fig 6 from "Earthquake Induced Sloshing in Tanks with insufficient Freeboard"

mass density of liquid  
 Weight of Roof is heavier, therefore ok  
 #5 Radial Dowels @ 16" o.c. okay (Roof Slab to Wall)



**Weight**

D/H <sub>1</sub>	4.836709677	
W/W <sub>1</sub>	0.25	PCA EB219 fig 4-4 (b)
W <sub>o</sub> /W <sub>1</sub>	0.73	PCA EB219 fig 4-4 (b)
W <sub>1</sub>	4451 kips	Weight Of Water
W <sub>l</sub>	1113 kips	Impulsive Weight
W <sub>c</sub>	3249 kips	Convective Weight
T <sub>w</sub>	12 inches	Wall Thickness
T <sub>r</sub>	8 inches	Roof Thickness
W <sub>w</sub>	573 kips	Weight of Walls
W <sub>k</sub>	466 kips	Weight of Roof

D<sub>max</sub> 77.00 ft**Period**

C <sub>w</sub>	0.13	PCA EB219 fig 4-10
C <sub>d</sub>	0.21	
E <sub>c</sub>	3823 ksi	Elastic Modulus of Concrete
ρ <sub>c</sub>	4.56 #/ft <sup>3</sup>	Mass Density of Concrete
ω <sub>1</sub>	148.8628937 rad/s	
T <sub>1</sub>	0.04 s	

**Base Shear**

R	1.5	Response Modification Factor
C <sub>h</sub>	0.53	
C <sub>u</sub>	6.16	
C <sub>w</sub>	0.53	
C <sub>u(m)</sub>	0.04	
V <sub>l</sub>	1425 kips	Impulsive Base Shear
V <sub>c</sub>	171 kips	Convective Base Shear
V <sub>t</sub>	1436 kips	Total Base Shear

**Overturing Moment**

h <sub>1</sub> /H <sub>1</sub>	0.375	PCA EB219 fig 4-5 (b)
h <sub>2</sub> /H <sub>1</sub>	0.53	PCA EB219 fig 4-5 (b)
h <sub>1</sub>	5.8125 ft	
h <sub>2</sub>	8.215 ft	
h <sub>u</sub>	8 ft	
M <sub>1</sub>	9806 kip ft	Impulsive
M <sub>c</sub>	14147 kip ft	Convective (Per ACI 350)
M <sub>t</sub>	17213 kip ft	Total

**Overall Stability Check****Sliding (Neglecting Buckling)**

Weight of tank w/out contents:	
Walls	573 kips
Roof	466 kips
Columns	30 kips
Base Slab	454 kips
Water	4451 kips
Total Weight	5973 kips
Friction Coeff	0.35
Base Shear	1436
Safety Factor	1.46 ok

**Overturing**

OTM	17213 kip ft
RM	224006 kip ft
Safety Factor	13.0 ok

**Design of Walls for In-Plane Loading**

V <sub>u</sub>	1436 kips	Base Shear
R2	38.5 ft	Outside tank radius
R1	37.5 ft	Inside tank radius
V <sub>c</sub>	12.0 kips/ft	Shear in wall
ρ <sub>c</sub>	3	See ACI 318 eqn 21-7
ρ <sub>n</sub>	0.006333	See ACI 318 eqn 21-7 #6 at 12" oc EF
φV <sub>n</sub>	74.5 kips/ft	ok

PER PCA EB219 for D&gt;&gt;H out of plane bending effects are small and can be neglected

FOOTINGSColumn FTG

DL = 60.2K

S = 38K

H = 35K

USE 6.5x6.5 FTG W/ (7) #6 BARSWall FOOTING

DL = 115 psf (18.75')(1/2) = 1.1 KLF + Wall DL =  $\frac{12''(150 \text{ psf})(16')}{12}$  = 2,400 PLF

S = 82 psf (18.75')(1/2) = 769 PLF

H = 75 psf (18.75')(1/2) = 703 PLF

USE 3'-0" x 16" FTG W/ (3) #6 BARS