

October 17, 2017

Brandon Thueson

Project: Emerson Landing Subdivision
Re: Weber Fire District Review

Below please find our response to your posted comments dated 3-13-17. Please note that our numbering reference system corresponds to your comment numbering system.

- 1. Subdivision has only one lot. Location of home may be on north side of property or south side of property. Access road and home to be shown on final site plan,
- 2. Added note "A fire hydrant must be provided within 400 feet of the furthest most portion of a building or facility"
- 3. Not plat item
- 4. Not plat item
- 5. Not plat item
- 6. Not plat item
- 7. Not plat item

We appreciate your review and trust we have changed and/or clarified all of your comments.

Sincerely,

REEVE & ASSOCIATES, INC.

Nate Reeve, P.E. Principal Engineer

nreeve@reeve-assoc.com