

**Weber Fire District** 

# **Plan Review**

Date: June 7, 2017 Project Name: Yellowstone Pioneer Enterprises LLC- Alternative Access Project Address: 9190 East 100 South Huntsville Utah 84317 Contractor/Contact: Eric Householder 801-389-0040 eric@thg-cs.com Fees:

Property Type	Schedule Rates	Square Foot Rate	Square Feet or Number of Res. Units	Total
Туре	Rate	Rate/ Sq Ft	Sq Ft or # of Units	Total
Plan Review	Alternatvie Access Review			\$50.00
<b>Residential Impact Fee</b>	328.15			\$0.00
				\$0.00
				\$0.00
			Total Due	\$50.00

#### FEE NOTICE:

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: <u>Weber Fire District.</u>

## **REVIEW STATUS: APPROVED**

## **SPECIFIC COMMENTS:**

- 1. The turn-around indicated on the plan has a 100 foot diameter. If desired this may be reduced to an 80 foot diameter turn-around if engineering approves as well.
- 2. Prior to any construction/building on the property the site plan and construction drawings shall be submitted for review. Other requirements may exist at that time.
- 3. Provide a temporary address marker at the building site during construction.
- 4. Fire Access roads to any property shall have a minimum clear width of 20 feet (face of curb to face of curb) and a vertical clearance of 13 foot 6 inches and shall be capable of supporting a 75,000 pound load.
- 5. Roads shall have a maximum grade of 10% unless specifically approved as outlined by the International Fire Code.

### **General Requirements:**

- Roads and bridges shall be designed, constructed and maintained to support an imposed load of 75,000 lbs.
- All roads shall be designed, constructed, surfaced and maintained so as to provide an all-weather driving surface.
- Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for height, width and imposed loads as permanent roads.
- All required fire hydrants and water systems shall be installed, approved and fully functional prior to any combustible construction.



• Fire department apparatus access is required for each lot.

Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all applicable codes and standards. Any change or revision of this plan will render this review void and will require submittal of the new or revised layout for fire department review.

Reviewed by: Brandon Thueson Fire Marshal

cc: File