

PERMIT TO CONSTRUCT AN ONSITE WASTEWATER TREATMENT SYSTEM

ISSUED BY THE WEBER-MORGAN HEALTH DEPARTMENT 477 23rd Street, OGDEN, UTAH 84401



Permit No.: W100872

Issued: November 14, 2011

Expires: November 14, 2012

Property Identification Number 22-046-0036 with the following specifications and provisions: This is to certify that R G SCHNEIDER SR is hereby issued a permit to install an onsite wastewater treatment system for the property with the

Maximum depth of trench bottoms must be limited to 24 inches from original ground surface Septic tank capacity must be at least 1000 gallons. System is designed for a 0 bedroom home Water supply will be provided by: EDEN WATERWORKS SYSTEM Lot: N/A of the N/A subdivision in Weber county Utah Approximate construction site address: 2580 N HWY 162, EDEN Type of System will be ABSORPTION FIELD with an absorption area of 263 Sq. Ft.


*** IMPORTANT - PLEASE READ CAREFULLY ***

THREE FOOT MAXIMUM BACKFILL OVER SEPTIC TANK MAXIMUM DEPTH TO BOTTOM OF TRENCH FROM ORIGINAL GROUND SURFACE IS 24 INCHES WATER TIGHTNESS TEST REQUIRED. TANK MUST BE FULL AT TIME OF INSPECTION. INSTALL ACCORDING TO CONSTRUCTION PLANS REVIEWED BY THIS OFFICE TYPE A CHAMBERS REQUIRED.

Final inspection to be completed prior to any backfilling of installed system Please provide the permit number and address when requesting the final inspection or any additional information regarding this system.

other factors, such as operation, maintenance, wastewater contents, etc., not addressed by the standards standards, and in no case does it guaranteee against the failure of the installed system. The performance of the installed system is affected by many This permit may be revoked or altered if the site is found to be in a flood hazard or other geologic hazard area. This permit is based on minimum design

Treat Course /10



 $\epsilon.\mathsf{q}$