



PERMIT TO CONSTRUCT AN ONSITE WASTEWATER TREATMENT SYSTEM

ISSUED BY THE WEBER-MORGAN HEALTH DEPARTMENT

477 23rd Street, OGDEN, UTAH 84401



Permit No.: **W101296**

Issued: **July 29, 2016**

Expires: **July 29, 2017**

This is to certify that **MARTY HARRIS** is hereby issued a permit to install an onsite wastewater treatment system for the property with the Property Identification Number **230820004** with the following specifications and provisions:

Approximate construction site address: **11211 E PARTRIDGE POINT DR. HUNTSVILLE**

Lot: **81** of the **SUNRIDGE HIGHLANDS #2** subdivision in Weber county Utah.

Water supply will be provided by: **SUNRIDGE.**

Type of System will be **ABSORPTION FIELD** with an absorption area of **1000** Sq. Ft.

Septic tank capacity must be at least **1000** gallons. System is designed for a **3** bedroom home.

Maximum depth of trench bottoms must be limited to **24** inches from original ground surface.

***** IMPORTANT - PLEASE READ CAREFULLY *****

MAXIMUM DEPTH TO BOTTOM OF TRENCH FROM ORIGINAL GROUND SURFACE IS 24" INCHES.

INSTALL ACCORDING TO CONSTRUCTION PLANS REVIEWED BY THIS OFFICE.

Please provide the permit number and address when requesting the final inspection or any additional information regarding this system.

Final inspection to be completed prior to any backfilling of installed system.

This permit may be revoked or altered if the site is found to be in a flood hazard or other geologic hazard area. This permit is based on minimum design standards, and in no case does it guarantee against the failure of the installed system. The performance of the installed system is affected by many other factors, such as operation, maintenance, wastewater contents, etc., not addressed by the standards.

Brian Cowan / gh