



PUBLIC WORKS /ENGINEERING  
(801) 399-8374  
FAX: (801) 399-8862  
*Curtis Christensen, P.E.*  
County Engineer

July 6, 2011

Wade Shaw  
Eddy L. Shaw Construction

RE: Roadway Repairs on Moose Hollow Drive

Following are the items needed before I can release obligation of additional funds:

1. Geo-Fab and 6" Rip Rap needs to be installed around the newly constructed waterway and catch basin.
2. The disturbed area needs to be uniformly graded from the back of curb without a swale and stabilized.
3. The ground around the existing catch basin which has the above ground pipes draining into it needs to be lowered and uniformly graded so the plywood can be removed.
4. The area needs to be cleaned up a bit especially around the newly installed gutter.

If you have any questions please give me a call at 801-399-8372.

Sincerely,

Rochelle Pfeaster  
Weber County Engineering