

BRIAN W. BENNION, M.P.A., L.E.H.S.  
Health Officer/Executive Director



April 5, 2017

Bell Built Homes  
4655 S 1900 W Suite #9  
Roy, UT 84067

**Subject: Water Table Monitoring, Located north of 1388 S 2900 W in Ogden, UT. Land Serial #15-060-0158.**

This letter is to notify you of the results for water table monitoring that was conducted on your property. Monitoring was performed from January 20, 2017 through March 10, 2017.

The water table for the subject property remained below 36 inches throughout the monitoring period. Therefore a **Conventional Wastewater Disposal System** would be suitable for the property with respect to water table.

The Weber-Morgan Health Department does not assert that this property meets zoning, subdivision or any other development feasibility requirements.

If not already accomplished, the following requirements must be satisfied in accordance with Utah Administrative code R317-4 and Weber-Morgan Health Department Onsite Wastewater Treatment System regulation, before the Weber-Morgan Health Department is able to issue a letter of feasibility for residential development on the property:

1. Approval of onsite systems in western Weber County is made in accordance with the A Ground Water Management Plan for Western Weber County, (adopted by the Weber-Morgan Board of Health 27 August 2001). The plan addresses replacement systems and density requirements.
2. **Drinking water.** Indicate the source. If a private well is used to supply drinking water, the well must be installed and approved.
3. **Soils Evaluation and Percolation Testing.** Soil exploration pits shall be made at the minimum rate of one exploration pit per lot proposed. Application and guidance for soils evaluation are available at the health department or online at

EDUCATE | ENGAGE | EMPOWER