


BRIAN W. BENNION, M.P.A., L.E.H.S.
Health Officer/Executive Director



June 30, 2017

Weber County Planning Commission
2380 Washington Blvd.
Ogden, UT 84401

RE: Charles James Property
2548 Nordic Valley Drive
Parcel #22-030-0010

The aforementioned property was issued an onsite wastewater permit on September 13, 1978 permit #W78270. Final approval of that onsite wastewater treatment system (septic system) was granted in September of 1979 after the appropriate inspection where performed by staff of the Weber-Morgan Health Department.

If the residence has been maintained in its original state, no increase in daily wastewater generation would be expected thus no additional permitting or approval would be required by our office to allow the continued use of the residence in its current state.

If you have any further questions you may contact this office at 801-399-7160.

Sincerely,

A handwritten signature in black ink, appearing to read "Summer Day".

Summer Day, LEHS III
Environmental Health Division

EDUCATE | ENGAGE | EMPOWER

phone: 801-399-7100 | fax: 801-399-7110 | 477 23rd Street, Ogden, UT 84401 | www.webermorganhealth.org

WEBER COUNTY HEALTH DEPARTMENT
DIVISION OF ENVIRONMENTAL SANITATION
2570 Grant Avenue, Ogden, Utah 84401

Permit Number 78-270
Fee Paid \$10.00

Part I - Individual Sewage Disposal System Application

Date 9-13-78
Construction Address _____ City or Town Eden
Subdivision Nordic Valley #1 Lot Number 22
Owner or Applicant Max P. Bierwolf Phone 825-8372
Mailing Address 286 W. 825 N., Sunset Zip Code 84015
Contractors _____ Mortgage Sponsor _____

HEALTH DEPARTMENT USE ONLY

Part II - Code Requirements

Plot Plan Provided X Secondary Treatment: Drainfield () Seepage Pit (X)
Number of Bedrooms 4 Basement Yes Septic Tank Capacity 1000 Gallons
Total Absorption Area: _____ Square Feet Drainfield 1000 Square Feet Wall Area
Water Table 10'+ Percolation Rate Pit
Remarks No Land Parcel Serial # on Land Use Permit.

Approved By WMK


Part III - Individual Sewage Disposal Record

Installed Absorption Area: _____ Square Feet Drainfield 1000 Square Feet Wall Area
Installed Septic Tank Capacity 1000 Gallons Date of Final Approval/~~Rejection~~ 9-79

SEE REVERSE FOR INSPECTOR'S SKETCH

Instruction Address _____ City or Town _____
Division _____ Nordic Valley #1 _____ Lot Number _____
Owner or Applicant _____ Max P. Bierwolf _____

INSPECTOR'S SKETCH



W. K. Kern
Registered Sanitarian