



1497 West 40 South
Lindon, Utah - 84042
Phone (801) 225-5711

3662 West 2100 South
Salt Lake City, Utah - 84120
Phone (801) 787-9138

1596 W. 2650 S. #108
Ogden, Utah - 84401
Phone (801) 399-9516

June 3, 2015

Mr. Ryan Moore
6486 Highway 39, Unit 12
Huntsville, UT 84317

**Re: Addendum I to the Geotechnical Report
Lot 26 Big Sky Estates No. 1
2230 North Panorama Circle
Weber County, Utah
Project No. 155083G**

Mr. Moore:

This letter is an addendum to the geotechnical report¹ was previously prepared for the property by Earthtec Engineering, dated May 6, 2015. The purpose of this letter is to refine information presented within the above referenced report based upon additional information provided by the client.

Section 3.0, *Proposed Construction*, of the previously prepared geotech report states: "We have based our recommendations in this report on the assumption that foundation loads for the proposed structures will not exceed 4,000 pounds per linear foot for bearing walls, 15,000 pounds for column loads, and 100 pounds per square foot for floor slabs." Section 11.0, *Foundations*, Subsection 11.2, *Strip/Spread Footings*, of the previously prepared geotech report states: "Footings founded on native clay and silt soils may be designed using a maximum allowable bearing capacity of 1,500 pounds per square foot." We understand from our conversations with Scott Moore with Moore Consulting that column loads up to 60 kips are anticipated for the structure.

Our engineering analyses for the project was then refined to account for the increase in structural loads for the structure. The results of our updated analyses indicate a maximum allowable bearing capacity of 1,200 pounds per square foot, up to 5,000 pounds per linear foot for bearing walls, and up to 60,000 pounds for column loads.

General Conditions


The information presented in this letter was produced to provide supplementary geotechnical design recommendations for the subject property. This letter should be considered as Addendum I to the geotechnical report. All other recommendations in the above referenced report should be followed. The General Conditions section of the geotechnical report applies to this letter.

¹ "Geotechnical Study, Lot 26 Big Sky Estates No. 1, 2230 North Panorama Circle, Weber County, Utah", EE Project No. 155083G, May 6, 2015.

Closure


We appreciate the opportunity of providing our services on this project. If we can answer questions or be of further service, please contact our office (801) 399-9516.

Respectfully;
EARTHTEC ENGINEERING



Shawn Stuart, E.I.T.
Staff Geotechnical Engineer

1 copy emailed
2 copies mailed



Timothy A. Mitchell, P.E.
Geotechnical Engineer