



# Weber Fire District

## Hillside Review

**Date:** August 17, 2017

**Project Name:** Hollis Lot 75 R

**Project Address:** 8452 E Spring Park Rd Eden Utah 84310

**Contractor/Contact:** Josh Arrington 801-458-0708 [josh@upwalldesign.com](mailto:josh@upwalldesign.com)

**Fees:**

Property Type	Schedule Rates	Square Foot Rate	Square Feet or Number of Res. Units	Total
Type	Rate	Rate/ Sq Ft	Sq Ft or # of Units	Total
Plan Review	Residential			\$50.00
Residential Impact Fee	328.15			\$0.00
				\$0.00
				\$0.00
			<b>Total Due</b>	<b>\$50.00</b>

**FEE NOTICE:**

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: **Weber Fire District.**

**REVIEW STATUS: APPROVED WITH CONDITIONS**

**SPECIFIC COMMENTS:**

1. Fire Suppression Systems: As per the Utah Fire Code Act, “R” occupancies built in accordance with the International Residential Code may require fire suppression systems if any of the following apply:

**R Occupancy Built Under IRC Requirements**

Structure is located in Urban-Wildland Interface Area	May Require Fire Suppression
Public Water Distribution System With Hydrants Does Not Exist	May Require Fire Suppression
Single Access Road With Grade Greater Than 10% For More Than 500 Linear Feet	May Require Fire Suppression
Structure Is Larger Than 10,000 Square Feet (Total Floor Area Of All Floor Levels Within Exterior Walls Of Dwelling Unit)	May Require Fire Suppression
Structure Is Larger Than Double The Average Size Of The Unsprinklered Homes In The Subdivision (Total Floor Area Of All Floor Levels Within Exterior Walls Of Dwelling Unit).	May Require Fire Suppression

*The residence is within a development area that requires fire suppression in the home. These systems have been proven to provide effective lifesaving functions. You are encouraged to visit <http://homefiresprinkler.org/> to learn more.*



# Weber Fire District

## Hillside Review

For more information, please contact the Fire Prevention Division at 801-782-3580.

2. The property location and structure is within the Wildland Urban Interface and is therefore subject to the requirements of the 2006 Utah Wildland-Urban Interface Code. Provide the following documentation when submitting the building plans for permit:
  - a. Completed “Fire Hazard Severity Form” (Appendix C).
  - b. Statement of conformance signed by the architect.
  - c. Any applicable alterations to comply the WUI code.
3. Provide a temporary address marker at the building site during construction.
4. Fire Access via Driveways: Driveways serving no more than 5 residences shall have a minimum clear width of 16 feet with a minimum of 12 feet of drive-able surface (measured from face of curb to face of curb) and a vertical clearance of 13 foot 6 inches and shall be capable of supporting a 75,000 pound load. Driveways in excess of 150 feet shall be provided with turn-arounds. Driveways exceeding 200 feet in length and less than 20 feet in width shall be provided with turnouts in addition to turnarounds. (See driveways- 2006 Wildland Urban Interface Code used as a reference for residential driveway requirements exceeding 150 feet in length). Roads and driveways shall also comply with City/County standards as applicable. *In cases of differing requirements, contact the Fire Marshal for clarification.*
5. Roads shall have a maximum grade of 10% unless specifically approved as outlined by the International Fire Code.

### General Requirements:

- Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for height, width and imposed loads as permanent roads.
- All required fire hydrants and water systems shall be installed, approved and fully functional prior to any combustible construction.
- Fire department apparatus access is required for each lot.
- If the building is equipped with an fire suppression system, there shall be a weather proof horn/strobe device located on the street side of the building as approved by the Fire Prevention Division (coordinate with fire inspector regarding location).

Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all applicable codes and standards. Any change or revision of this plan will render this review void



# Weber Fire District

## Hillside Review

and will require submittal of the new or revised layout for fire department review.

Reviewed by: Brandon Thueson  
Fire Marshal

cc: File