



# Weber Fire District

## Plan Review

**Date:** October 16, 2017

**Project Name:** John Porter Subdivision

**Project Address:** 4794 East 2925 N Eden Utah 84310

**Contractor/Contact:** John Porter 801-710-4501 [john@focusservices.com](mailto:john@focusservices.com)

**Fees:**

| Property Type          | Schedule Rates    | Square Foot Rate | Square Feet or Number of Res. Units | Total          |
|------------------------|-------------------|------------------|-------------------------------------|----------------|
| Type                   | Rate              | Rate/ Sq Ft      | Sq Ft or # of Units                 | Total          |
| Plan Review            | 1 Lot Subdivision |                  |                                     | \$50.00        |
| Residential Impact Fee | 328.15            |                  |                                     | \$0.00         |
|                        |                   |                  |                                     | \$0.00         |
|                        |                   |                  |                                     | \$0.00         |
|                        |                   |                  | <b>Total Due</b>                    | <b>\$50.00</b> |

**FEE NOTICE:**

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: **Weber Fire District.**

**REVIEW STATUS: APPROVED WITH CONDITIONS**

**SPECIFIC COMMENTS:**

1. Fire Hydrant(s): If there is a waterline in the area that will support a hydrant, there must be a hydrant provided within 400 feet of the furthest most portion of a building or facility (see IFC 507.5.1). The maximum spacing between hydrants in a residential area is 500 ft.
2. Fire Flow: Fire flow for the subdivision shall be 1000 GPM.
3. Fire Suppression Systems: As per the Utah Fire Code Act, "R" occupancies built in accordance with the International Residential Code may require fire suppression systems if any of the following apply:

**R Occupancy Built Under IRC Requirements**

|   |                              |
|---|------------------------------|
| Structure is located in Urban-Wildland Interface Area   | May Require Fire Suppression |
| Public Water Distribution System With Hydrants Does Not Exist   | May Require Fire Suppression |
| Single Access Road With Grade Greater Than 10% For More Than 500 Linear Feet  | May Require Fire Suppression |
| Structure Is Larger Than 10,000 Square Feet (Total Floor Area Of All Floor Levels Within Exterior Walls Of Dwelling Unit)     | May Require Fire Suppression |
| Structure Is Larger Than Double The Average Size Of The Unsprinklered Homes In The Subdivision (Total Floor Area Of All Floor | May Require Fire Suppression |



# Weber Fire District

## Plan Review

|   |  |
|---|--|
| Levels Within Exterior Walls Of Dwelling Unit). |  |
|---|--|

*Weber Fire District strongly encourages the builder/owner to provide a fire suppression system to protect the lives and property of the occupants. These systems have been proven to provide effective lifesaving functions. You are encouraged to visit <http://homefiresprinkler.org/> to learn more. For more information, please contact the Fire Prevention Division at 801-782-3580.*

4. Provide a temporary address marker at the building site during construction.
5. Fire Access via Driveways: Driveways serving no more than 5 residences shall have a minimum clear width of 16 feet with a minimum of 12 feet of drive-able surface (measured from face of curb to face of curb) and a vertical clearance of 13 foot 6 inches and shall be capable of supporting a 75,000 pound load. Driveways in excess of 150 feet shall be provided with turn-arounds. Driveways exceeding 200 feet in length and less than 20 feet in width shall be provided with turnouts in addition to turnarounds. (See driveways- 2006 Wildland Urban Interface Code used as a reference for residential driveway requirements exceeding 150 feet in length). Roads and driveways shall also comply with City/County standards as applicable. *In cases of differing requirements, contact the Fire Marshal for clarification.*
6. Roads shall have a maximum grade of 10% unless specifically approved as outlined by the International Fire Code.

### General Requirements:

- Roads and bridges shall be designed, constructed and maintained to support an imposed load of 75,000 lbs.
- All roads shall be designed, constructed, surfaced and maintained so as to provide an all-weather driving surface.
- Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for height, width and imposed loads as permanent roads.
- All required fire hydrants and water systems shall be installed, approved and fully functional prior to any combustible construction.

|   |
|---|
| <p><b>A written response for this review is required.</b></p> <p>Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all applicable codes and standards. Any change or revision of this plan will render this review void and will require submittal of the new or revised layout for fire department review.</p> |
|---|

Reviewed by: Brandon Thueson



# Weber Fire District

## Plan Review

Fire Marshal

cc: File