


BRIAN W. BENNION, M.P.A., L.E.H.S.  
Health Officer/Executive Director



June 26, 2018

Weber County Planning Commission  
2380 Washington Blvd.  
Ogden, UT 84401

RE: Preliminary Subdivision Determination  
Fenster Farm, Phase 2, Lots 5-12  
Parcel #15-024-0016  
Soil log #13996

Gentlemen:

The soil and percolation information for the above-referenced lot have been reviewed. Culinary water will be provided by Peterson Pipeline Water Improvement District, an extension of an existing approved non-community water system. **A letter from the water supplier is required prior to issuance of a permit**

DESIGN REQUIREMENTS

Lot 7, 8, 9, 10, 11 Documented ground water tables not to exceeding 12 inches, fall within the range of acceptability for the utilization of a Wisconsin Mound Treatment System or a Packed Bed Media System followed by an At-Grade absorption area, as a means of wastewater disposal. Maximum absorption area depth is limited to 0 inches. As defined in the Utah Administrative Code R317-4 Table 6 the absorption area is to be designed using a maximum loading rate of 0.25 gal/sq. ft./day for a Wisconsin Mound absorption area, or 0.40 gal/sq. ft./day for the At-Grade absorption area as required for the fine sandy loam, massive structure to clay loam, blocky structure soil horizon, with documented percolation rates of less than 60 minutes per inch.

Lot 5, 6, 12: Documented ground water tables not to exceeding 12 inches, fall within the range of acceptability for the utilization of a Packed Bed Media System followed by an At-Grade absorption area, as a means of wastewater disposal. Maximum absorption area depth is limited to 0 inches. The absorption system is to be designed using a maximum loading rate of 0.35 gal/sq. ft. /day as required for a clay loam blocky structure with a documented percolation rate of between 96-120 minutes per inch.

Plans for the construction of any wastewater disposal system are to be prepared by a Utah State certified individual and submitted to this office for review prior to the issuance of a Wastewater Disposal permit.

The following items are required for a formal **subdivision review**; application, receipt of the appropriate fee, and a full sized copy of the subdivision plats showing the location of exploration pits and percolation tests as well as the documented soil horizons and percolation rates. A subdivision review will not occur until all items are submitted. Mylars submitted for signature without this information will be returned

Each on-site individual wastewater disposal system must be installed in accordance with R317-4, Utah Administrative Code, Individual Wastewater Disposal Systems and Weber-Morgan District Health Department Rules. Final approval will be given only after an on-site inspection of the completed project and prior to the accomplishment of any backfilling.

Please be advised that the conditions of this letter are valid for a period of 18 months. At that time the site will be re-evaluated in relation to rules in effect at that time.

Sincerely,

Summer Day, LEHS III, Program Manager  
Environmental Health Division  
801-399-7160

EDUCATE | ENGAGE | EMPOWER