



## Central Weber Sewer Improvement District

December 20, 2018

Kerry Egbert  
3133 s 4700 w  
Ogden Utah 84401

**SUBJECT:** Glenn Shannon subdivision  
Sanitary Sewer Service  
Will Server Letter

Kerry:

We have reviewed and provide a Will Serve Letter for the subdivision to be named the Glenn Shannon subdivision including a 1 acre parcel located at approximate address 3100 South 5100 West in Weber County (Taylor). We offer the following comments regarding Central Weber providing sanitary sewer service.

1. Central Weber has the capacity to treat the sanitary sewer flow from this subdivision.
2. If any connection is made directly into Central Weber's line the connection must be inspected by Central Weber while the work is being done. A minimum of 48 hour notice for inspection shall be given to Central Weber prior to any work associated with the connection.
3. Central Weber will not take ownership or responsibility for the condition, ownership or maintenance of the proposed sanitary sewer lines (gravity or pressure) or system that will be installed to serve this subdivision.
4. The connection of any sump pumps (or similar type pumps) to the sanitary sewer system is prohibited during or after construction. Central Weber's Wastewater Control Rules and Regulations state:



## Central Weber Sewer Improvement District

Kerry Egbert  
December 20, 2018  
Page -2-

*Prohibited Discharge into Sanitary Sewer. No person shall discharge or cause or make a connection which would allowed to be discharged any storm water, surface water, groundwater, roof water runoff or subsurface drainage to any sanitary sewer.*

5. The entire parcel of property to be served will need to be annexed into the District prior to any connection to the District's line. This annexation must be complete before the sale of any lots in the subdivision.
6. Impact fees will need to be paid to Central Weber Sewer Improvement District no later than the issuance of any building permits.

If you have any further questions or need additional information please let us know.  
Sincerely,

Kevin Hall, P. E.  
Technical Director

cc: Chad Meyerhoffer, Weber County