



REScheck Software Version 4.6.5 Compliance Certificate

Project Klinefelter Residence

Energy Code: **2015 IECC**
 Location: **Ogden, Utah**
 Construction Type: **Single-family**
 Project Type: **New Construction**
 Conditioned Floor Area: **5,177 ft2**
 Glazing Area **20%**
 Climate Zone: **5 (5557 HDD)**
 Permit Date:
 Permit Number:

Construction Site:
 Lot 79
 Eden, UT 84310

Owner/Agent:
 Kelsey Klinefelter
 CA

Designer/Contractor:
 MacKay-Lyons Sweetapple
 Architects
 2188 Gottingen Street
 Halifax, NS, Ontario
 1-902-429-1867

Compliance: Passes using UA trade-off

Compliance: **10.9% Better Than Code** Maximum UA: **2320** Your UA: **2068**

The % Better or Worse Than Code Index reflects how close to compliance the house is based on code trade-off rules. It DOES NOT provide an estimate of energy use or cost relative to a minimum-code home.

Envelope Assemblies

Assembly	Gross Area or Perimeter	Cavity R-Value	Cont. R-Value	U-Factor	UA
W Building Roof: Cathedral Ceiling Comment: RA 1	1,297	18.0	10.0	0.035	45
W Buiding Basement Terrace Soffit: Flat Ceiling or Scissor Truss Comment: SA 1	78	18.0	20.0	0.026	2
W Buiding North EL Wood Frame: Other Framed Wall Comment: EWA 1	251			0.049	12
w035: Vinyl/Fiberglass Frame:Double Pane with Low-E	8			0.320	3
W Building West EL Wood Frame: Other Framed Wall Comment: EWA 1	674			0.049	27
w020: Vinyl/Fiberglass Frame:Double Pane with Low-E	24			0.320	8
w021: Vinyl/Fiberglass Frame:Double Pane with Low-E	7			0.320	2
w022-025: Vinyl/Fiberglass Frame:Double Pane with Low-E	86			0.320	28
W Building South EL Wood Frame: Other Framed Wall Comment: EWA 1	439			0.049	14
w001: Vinyl/Fiberglass Frame:Double Pane with Low-E	151			0.320	48
W Building East EL Wood Frame: Other Framed Wall Comment: EWA 1	821			0.049	29
w002-005: Vinyl/Fiberglass Frame:Double Pane with Low-E	211			0.320	68
w026-027: Vinyl/Fiberglass Frame:Double Pane with Low-E	23			0.320	7
	296	0.0	17.5	0.049	15

Assembly	Gross Area or Perimeter	Cavity R-Value	Cont. R-Value	U-Factor	UA
W Building Crawl Space: Solid Concrete or Masonry Wall height: 6.5' Depth below grade: 4.0' Insulation depth: 6.5' Comment: EWA 4	263	0.0	14.0	0.061	11
W Building North EL Basement: Solid Concrete or Masonry Wall height: 8.5' Depth below grade: 5.5' Insulation depth: 8.5' Comment: EWA 3	245	0.0	17.5	0.045	11
W Building West EL Basement: Solid Concrete or Masonry Wall height: 8.5' Depth below grade: 5.5' Insulation depth: 8.5' Comment: EWA 3	272	0.0	17.5	0.045	12
w036: Vinyl/Fiberglass Frame:Double Pane with Low-E	11			0.320	4
W Building South EL Basement: Solid Concrete or Masonry Wall height: 8.5' Depth below grade: 5.5' Insulation depth: 8.5' Comment: EWA 3	245	0.0	17.5	0.045	8
w038: Vinyl/Fiberglass Frame:Double Pane with Low-E	43			0.320	14
d036: Solid	24			0.340	8
W Building East EL Basement: Solid Concrete or Masonry Wall height: 8.5' Depth below grade: 5.5' Insulation depth: 8.5' Comment: EWA 3	272	0.0	17.5	0.045	12
Entry Knuckle Roof: Flat Ceiling or Scissor Truss Comment: RA 3	138	18.0	8.0	0.037	5
Entry Knuckle South EL: Wood Frame, 16" o.c.	106	36.0	7.5	0.031	1
w018-019: Vinyl/Fiberglass Frame:Double Pane with Low-E	51			0.320	16
Door 2: Glass	20			0.320	6
Entry Knuckle North EL: Wood Frame, 16" o.c.	203	36.0	7.5	0.031	2
w006: Vinyl/Fiberglass Frame:Double Pane with Low-E	116			0.320	37
Door 3: Solid	20			0.340	7
C Building Roof: Cathedral Ceiling Comment: RA 2	667	18.0	10.0	0.035	23
w039: Vinyl/Fiberglass Frame:Double Pane with Low-E	11			0.430	5
C Buiding North EL Wood Frame: Other Framed Wall Comment: EWA 1	416			0.049	19
w016: Vinyl/Fiberglass Frame:Double Pane with Low-E	12			0.320	4
w017: Vinyl/Fiberglass Frame:Double Pane with Low-E	12			0.320	4
C Building West EL Wood Frame: Other Framed Wall Comment: EWA 1	674			0.049	32
w034: Vinyl/Fiberglass Frame:Double Pane with Low-E	12			0.320	4
C Building South EL Wood Frame: Other Framed Wall Comment: EWA 1	476			0.049	17
w007: Vinyl/Fiberglass Frame:Double Pane with Low-E	56			0.320	18
w028: Vinyl/Fiberglass Frame:Double Pane with Low-E	64			0.320	20
C Building East EL Wood Frame: Other Framed Wall Comment: EWA 1	393			0.049	19
w033: Vinyl/Fiberglass Frame:Double Pane with Low-E	12			0.320	4

Assembly	Gross Area or Perimeter	Cavity R-Value	Cont. R-Value	U-Factor	UA
C Building Crawl Space: Solid Concrete or Masonry Wall height: 6.5' Depth below grade: 4.0' Insulation depth: 6.5' Comment: EWA 4	446	0.0	14.0	0.061	19
C Building North EL Basement: Solid Concrete or Masonry Wall height: 8.5' Depth below grade: 5.5' Insulation depth: 8.5' Comment: EWA 3	171	0.0	17.5	0.045	8
C Building West EL Basement: Solid Concrete or Masonry Wall height: 8.5' Depth below grade: 5.5' Insulation depth: 8.5' Comment: EWA 3	101	0.0	17.5	0.045	5
C Building South EL Basement: Solid Concrete or Masonry Wall height: 8.5' Depth below grade: 5.5' Insulation depth: 8.5' Comment: EWA 3	112	0.0	17.5	0.045	5
C Building East EL Basement: Solid Concrete or Masonry Wall height: 8.5' Depth below grade: 5.5' Insulation depth: 8.5' Comment: EWA 3	155	0.0	17.5	0.045	7
Garage Knuckle Roof: Flat Ceiling or Scissor Truss Comment: RA 3	71	18.0	8.0	0.037	3
Garage Knuckle South EL: Wood Frame, 16" o.c.	42	36.0	7.5	0.031	0
w008: Vinyl/Fiberglass Frame:Double Pane with Low-E	28			0.320	9
Garage Knuckle North EL: Wood Frame, 16" o.c.	33	36.0	7.5	0.031	0
w015: Vinyl/Fiberglass Frame:Double Pane with Low-E	28			0.320	9
E Building Roof: Cathedral Ceiling Comment: RA 2	1,248	18.0	10.0	0.035	43
w040: Vinyl/Fiberglass Frame:Double Pane with Low-E	11			0.430	5
w041: Vinyl/Fiberglass Frame:Double Pane with Low-E	11			0.430	5
E Building Basement Terrace Soffit: Flat Ceiling or Scissor Truss Comment: SA 1	79	36.0	10.0	0.024	2
E Building North EL Wood Frame: Other Framed Wall Comment: EWA 1	412			0.049	9
w031-032: Vinyl/Fiberglass Frame:Double Pane with Low-E	43			0.320	14
Garage Doors: Solid	193			0.340	66
E Building West EL Wood Frame: Other Framed Wall Comment: EWA 1	653			0.049	26
w009-010: Vinyl/Fiberglass Frame:Double Pane with Low-E	106			0.320	34
w029: Vinyl/Fiberglass Frame:Double Pane with Low-E	22			0.320	7
E Building South EL Wood Frame: Other Framed Wall Comment: EWA 1	477			0.049	15
w011: Vinyl/Fiberglass Frame:Double Pane with Low-E	97			0.320	31
w030: Vinyl/Fiberglass Frame:Double Pane with Low-E	75			0.320	24
E Building East EL Wood Frame: Other Framed Wall Comment: EWA 1	928			0.049	42
w012: Vinyl/Fiberglass Frame:Double Pane with Low-E	36			0.320	12
w013-014: Vinyl/Fiberglass Frame:Double Pane with Low-E	23			0.320	7

Assembly	Gross Area or Perimeter	Cavity R-Value	Cont. R-Value	U-Factor	UA
w043: Vinyl/Fiberglass Frame:Double Pane with Low-E	11			0.320	4
E Building Crawl Space: Solid Concrete or Masonry Wall height: 6.5' Depth below grade: 4.0' Insulation depth: 6.5' Comment: EWA 4	243	0.0	14.0	0.061	10
E Building North EL Basement: Solid Concrete or Masonry Wall height: 8.5' Depth below grade: 5.5' Insulation depth: 8.5' Comment: EWA 3	231	0.0	17.5	0.045	10
E Building West EL Basement: Solid Concrete or Masonry Wall height: 8.5' Depth below grade: 5.5' Insulation depth: 8.5' Comment: EWA 3	188	0.0	17.5	0.045	8
E Building South EL Basement: Solid Concrete or Masonry Wall height: 8.5' Depth below grade: 5.5' Insulation depth: 8.5' Comment: EWA 3	231	0.0	17.5	0.045	8
w039: Vinyl/Fiberglass Frame:Double Pane with Low-E	23			0.320	7
Door 5: Glass	20			0.340	7
E Building East EL Basement: Solid Concrete or Masonry Wall height: 8.5' Depth below grade: 5.5' Insulation depth: 8.5' Comment: EWA 3	188	0.0	17.5	0.045	8
Wood Truss Floor: All-Wood Joist/Truss:Over Unconditioned Space	1,118	36.0	10.0	0.021	23
Concrete Floor: Slab-On-Grade:Unheated Insulation depth: 6.0'	1,486		20.0	0.636	945

Compliance Statement: The proposed building design described here is consistent with the building plans, specifications, and other calculations submitted with the permit application. The proposed building has been designed to meet the 2015 IECC requirements in REScheck Version 4.6.5 and to comply with the mandatory requirements listed in the REScheck Inspection Checklist.

Name - Title

Signature

Date



Inspection Checklist

Energy Code: 2015 IECC

Requirements: 38.0% were addressed directly in the REScheck software

Text in the "Comments/Assumptions" column is provided by the user in the REScheck Requirements screen. For each requirement, the user certifies that a code requirement will be met and how that is documented, or that an exception is being claimed. Where compliance is itemized in a separate table, a reference to that table is provided.

Section # & Req.ID	Pre-Inspection/Plan Review	Plans Verified Value	Field Verified Value	Complies?	Comments/Assumptions
103.1, 103.2 [PR1] ¹	Construction drawings and documentation demonstrate energy code compliance for the building envelope. Thermal envelope represented on construction documents.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
103.1, 103.2, 403.7 [PR3] ¹	Construction drawings and documentation demonstrate energy code compliance for lighting and mechanical systems. Systems serving multiple dwelling units must demonstrate compliance with the IECC Commercial Provisions.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
302.1, 403.7 [PR2] ²	Heating and cooling equipment is sized per ACCA Manual S based on loads calculated per ACCA Manual J or other methods approved by the code official.	Heating: Btu/hr____ Cooling: Btu/hr____	Heating: Btu/hr____ Cooling: Btu/hr____	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

Additional Comments/Assumptions:

1 High Impact (Tier 1)	2 Medium Impact (Tier 2)	3 Low Impact (Tier 3)
------------------------	--------------------------	-----------------------


Section # & Req.ID	Foundation Inspection	Plans Verified Value	Field Verified Value	Complies?	Comments/Assumptions
402.1.2 [FO1] ¹	Slab edge insulation R-value.	R-____ <input type="checkbox"/> Unheated <input type="checkbox"/> Heated	R-____ <input type="checkbox"/> Unheated <input type="checkbox"/> Heated	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Envelope Assemblies table for values.
402.1.2 [FO3] ¹	Slab edge insulation depth/length.	____ ft	____ ft	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Envelope Assemblies table for values.
402.1.1 [FO4] ¹	Conditioned basement wall insulation R-value. Where interior insulation is used, verification may need to occur during Insulation Inspection. Not required in warm-humid locations in Climate Zone 3.	R-____ R-____	R-____ R-____	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Envelope Assemblies table for values.
303.2 [FO5] ¹	Conditioned basement wall insulation installed per manufacturer's instructions.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
402.2.9 [FO6] ¹	Conditioned basement wall insulation depth of burial or distance from top of wall.	____ ft	____ ft	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Envelope Assemblies table for values.
402.2.11 [FO7] ¹	Unvented crawl space wall insulation R-value.	R-____ R-____	R-____ R-____	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Envelope Assemblies table for values.
303.2 [FO8] ¹	Unvented crawl space wall insulation installed per manufacturer's instructions.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
402.2.11 [FO9] ¹	Unvented crawl space continuous vapor retarder installed over exposed earth, joints overlapped by 6 in. and sealed, extending at least 6 in. up and attached to the wall.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
402.2.11 [FO10] ¹	Unvented crawl space wall insulation depth of burial or distance from top of wall.	____ in.	____ in.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Envelope Assemblies table for values.
303.2.1 [FO11] ²	A protective covering is installed to protect exposed exterior insulation and extends a minimum of 6 in. below grade.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Exception: Requirement is not applicable.
403.9 [FO12] ²	Snow- and ice-melting system controls installed.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

Additional Comments/Assumptions:

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Section # & Req.ID	Framing / Rough-In Inspection	Plans Verified Value	Field Verified Value	Complies?	Comments/Assumptions
402.1.1, 402.3.4 [FR1] ¹	Door U-factor.	U-____	U-____	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Envelope Assemblies table for values.
402.1.1, 402.3.1, 402.3.3, 402.5 [FR2] ¹	Glazing U-factor (area-weighted average).	U-____	U-____	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Envelope Assemblies table for values.
303.1.3 [FR4] ¹	U-factors of fenestration products are determined in accordance with the NFRC test procedure or taken from the default table.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
402.1.1, 402.3.3, 402.3.6, 402.5 [FR5] ¹	Skylight U-factor.	U-____	U-____	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Envelope Assemblies table for values.
402.4.1.1 [FR23] ¹	Air barrier and thermal barrier installed per manufacturer's instructions.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
402.4.3 [FR20] ¹	Fenestration that is not site built is listed and labeled as meeting AAMA /WDMA/CSA 101/I.S.2/A440 or has infiltration rates per NFRC 400 that do not exceed code limits.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
402.4.5 [FR16] ²	IC-rated recessed lighting fixtures sealed at housing/interior finish and labeled to indicate ≤2.0 cfm leakage at 75 Pa.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
403.3.1 [FR12] ¹	Supply and return ducts in attics insulated ≥ R-8 where duct is ≥ 3 inches in diameter and ≥ R-6 where < 3 inches. Supply and return ducts in other portions of the building insulated ≥ R-6 for diameter ≥ 3 inches and R-4.2 for < 3 inches in diameter.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
403.3.5 [FR15] ³	Building cavities are not used as ducts or plenums.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
403.4 [FR17] ²	HVAC piping conveying fluids above 105 °F or chilled fluids below 55 °F are insulated to ≥R-3.	R-____	R-____	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
403.4.1 [FR24] ¹	Protection of insulation on HVAC piping.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Section # & Req.ID	Framing / Rough-In Inspection	Plans Verified Value	Field Verified Value	Complies?	Comments/Assumptions
403.5.3 [FR18] ² 	Hot water pipes are insulated to $\geq R-3$.	R-_____	R-_____	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
403.6 [FR19] ²	Automatic or gravity dampers are installed on all outdoor air intakes and exhausts.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. Location on plans/spec: Refer to mechanical: deferred submittal

Additional Comments/Assumptions:

1	High Impact (Tier 1)	2	Medium Impact (Tier 2)	3	Low Impact (Tier 3)
---	----------------------	---	------------------------	---	---------------------

Section # & Req.ID	Insulation Inspection	Plans Verified Value	Field Verified Value	Complies?	Comments/Assumptions
303.1 [IN13] ²	All installed insulation is labeled or the installed R-values provided.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
402.1.1, 402.2.6 [IN1] ¹	Floor insulation R-value.	R-_____ <input type="checkbox"/> Wood <input type="checkbox"/> Steel	R-_____ <input type="checkbox"/> Wood <input type="checkbox"/> Steel	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Envelope Assemblies table for values.
303.2, 402.2.7 [IN2] ¹	Floor insulation installed per manufacturer's instructions and in substantial contact with the underside of the subfloor, or floor framing cavity insulation is in contact with the top side of sheathing, or continuous insulation is installed on the underside of floor framing and extends from the bottom to the top of all perimeter floor framing members.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
402.1.1, 402.2.5, 402.2.6 [IN3] ¹	Wall insulation R-value. If this is a mass wall with at least ½ of the wall insulation on the wall exterior, the exterior insulation requirement applies (FR10).	R-_____ <input type="checkbox"/> Wood <input type="checkbox"/> Mass <input type="checkbox"/> Steel	R-_____ <input type="checkbox"/> Wood <input type="checkbox"/> Mass <input type="checkbox"/> Steel	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Envelope Assemblies table for values.
303.2 [IN4] ¹	Wall insulation is installed per manufacturer's instructions.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.

Additional Comments/Assumptions:


1	High Impact (Tier 1)	2	Medium Impact (Tier 2)	3	Low Impact (Tier 3)
---	----------------------	---	------------------------	---	---------------------

Section # & Req.ID	Final Inspection Provisions	Plans Verified Value	Field Verified Value	Complies?	Comments/Assumptions
402.1.1, 402.2.1, 402.2.2, 402.2.6 [FI1] ¹	Ceiling insulation R-value.	R-____ <input type="checkbox"/> Wood <input type="checkbox"/> Steel	R-____ <input type="checkbox"/> Wood <input type="checkbox"/> Steel	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Envelope Assemblies table for values.
303.1.1.1, 303.2 [FI2] ¹	Ceiling insulation installed per manufacturer's instructions. Blown insulation marked every 300 ft ² .			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
402.2.3 [FI22] ²	Vented attics with air permeable insulation include baffle adjacent to soffit and eave vents that extends over insulation.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Exception: Requirement is not applicable.
402.2.4 [FI3] ¹	Attic access hatch and door insulation ≥R-value of the adjacent assembly.	R-____	R-____	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
402.4.1.2 [FI17] ¹	Blower door test @ 50 Pa. ≤=5 ach in Climate Zones 1-2, and ≤=3 ach in Climate Zones 3-8.	ACH 50 = ____	ACH 50 = ____	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
402.4.2 [FI8] ²	Wood-burning fireplaces have tight fitting flue dampers and outdoor air for combustion.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
403.3.4 [FI4] ¹	Duct tightness test result of ≤=4 cfm/100 ft ² across the system or ≤=3 cfm/100 ft ² without air handler @ 25 Pa. For rough-in tests, verification may need to occur during Framing Inspection.	____ cfm/100 ft ²	____ cfm/100 ft ²	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
403.3.3 [FI27] ¹	Ducts are pressure tested to determine air leakage with either: Rough-in test: Total leakage measured with a pressure differential of 0.1 inch w.g. across the system including the manufacturer's air handler enclosure if installed at time of test. Postconstruction test: Total leakage measured with a pressure differential of 0.1 inch w.g. across the entire system including the manufacturer's air handler enclosure.	____ cfm/100 ft ²	____ cfm/100 ft ²	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
403.3.2.1 [FI24] ¹	Air handler leakage designated by manufacturer at ≤=2% of design air flow.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
403.1.1 [FI9] ²	Programmable thermostats installed for control of primary heating and cooling systems and initially set by manufacturer to code specifications.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
403.1.2 [FI10] ²	Heat pump thermostat installed on heat pumps.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Section # & Req.ID	Final Inspection Provisions	Plans Verified Value	Field Verified Value	Complies?	Comments/Assumptions
403.5.1 [FI11] ²	Circulating service hot water systems have automatic or accessible manual controls.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
403.6.1 [FI25] ²	All mechanical ventilation system fans not part of tested and listed HVAC equipment meet efficacy and air flow limits.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
403.2 [FI26] ²	Hot water boilers supplying heat through one- or two-pipe heating systems have outdoor setback control to lower boiler water temperature based on outdoor temperature.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
403.5.1.1 [FI28] ²	Heated water circulation systems have a circulation pump. The system return pipe is a dedicated return pipe or a cold water supply pipe. Gravity and thermos-syphon circulation systems are not present. Controls for circulating hot water system pumps start the pump with signal for hot water demand within the occupancy. Controls automatically turn off the pump when water is in circulation loop is at set-point temperature and no demand for hot water exists.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
403.5.1.2 [FI29] ²	Electric heat trace systems comply with IEEE 515.1 or UL 515. Controls automatically adjust the energy input to the heat tracing to maintain the desired water temperature in the piping.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
403.5.2 [FI30] ²	Water distribution systems that have recirculation pumps that pump water from a heated water supply pipe back to the heated water source through a cold water supply pipe have a demand recirculation water system. Pumps have controls that manage operation of the pump and limit the temperature of the water entering the cold water piping to 104 ^o F.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
403.5.4 [FI31] ²	Drain water heat recovery units tested in accordance with CSA B55.1. Potable water-side pressure loss of drain water heat recovery units < 3 psi for individual units connected to one or two showers. Potable water-side pressure loss of drain water heat recovery units < 2 psi for individual units connected to three or more showers.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
404.1 [FI6] ¹	75% of lamps in permanent fixtures or 75% of permanent fixtures have high efficacy lamps. Does not apply to low-voltage lighting.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

1 High Impact (Tier 1)
 2 Medium Impact (Tier 2)
 3 Low Impact (Tier 3)

Section # & Req.ID	Final Inspection Provisions	Plans Verified Value	Field Verified Value	Complies?	Comments/Assumptions
404.1.1 [F123] ³ 	Fuel gas lighting systems have no continuous pilot light.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Exception: Requirement is not applicable.
401.3 [F17] ²	Compliance certificate posted.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
303.3 [F118] ³	Manufacturer manuals for mechanical and water heating systems have been provided.			<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

Additional Comments/Assumptions:

1 High Impact (Tier 1)	2 Medium Impact (Tier 2)	3 Low Impact (Tier 3)
------------------------	--------------------------	-----------------------



2015 IECC Energy Efficiency Certificate

Insulation Rating	R-Value
Above-Grade Wall	0.00
Below-Grade Wall	14.00
Floor	20.00
Ceiling / Roof	28.00
Ductwork (unconditioned spaces):	_____

Glass & Door Rating	U-Factor	SHGC
Window	0.32	
Door	0.34	
Skylight	0.43	

Heating & Cooling Equipment	Efficiency
Heating System: _____	_____
Cooling System: _____	_____
Water Heater: _____	_____

Name: _____ Date: _____

Comments