



CONSTRUCTION ACTIVITY NOTES:

1. LOAD RESTRICTIONS APPLY TO WORK PERFORMED NEAR THE BUREAU OF RECLAMATION AQUEDUCT. THE LOAD RESTRICTED AREA SURROUNDING THE AQUEDUCT IS DEFINED AS A ZONE WITHIN 12- FEET OF BOTH SIDES OF THE CENTERLINE OF THE PIPELINE (24- FEET TOTAL WIDTH).
2. CLEAR VISUAL MARKINGS SHALL BE CONTINUOUSLY MAINTAINED ALONG THE AQUEDUCT CENTERLINE AND LIMITS OF THE LOAD RESTRICTED AREA AT ALL TIMES DURING CONSTRUCTION. LOCATING PAINT IS NOT SUFFICIENT DURING ACTIVE CONSTRUCTION.
3. LIMIT EQUIPMENT, OPERATION, PROCEDURES, AND METHODS OF CONSTRUCTION WITHIN THE LOAD RESTRICTED AREA TO ENSURE THAT ANY COMBINATION OF EITHER LIVE LOADS OR DEAD LOADS DOES NOT EXCEED THE DESIGN CAPABILITIES OF THE AQUEDUCT.
4. THE LARGEST EQUIPMENT LOADING (LIVE LOAD) WHICH SHALL BE PERMITTED WITHIN THE LOAD RESTRICTED AREA IS HS-20 WITH A MINIMUM SOIL COVER OF 4- FEET OR GREATER.
5. DYNAMIC LOADING OF EQUIPMENT, INCLUDING SOIL COMPACTION EQUIPMENT, SHALL NOT EXCEED HS-20 LOADING WITH A MINIMUM OF 4- FEET OF COVER IN THE LOAD RESTRICTED AREA.
6. OPERATION OF BACKHOES, AUGERS, EXCAVATION OR LIFTING EQUIPMENT WHICH MAY IMPOSE POINT LOADS FROM OUTRIGGERS, WHEELS, OR JACKS IS NOT PERMITTED WITHIN THE LOAD RESTRICTED AREA.
7. DO NOT PLACE FILL OR TEMPORARILY STOCKPILE CONSTRUCTION MATERIALS IN THE LOAD RESTRICTED AREA.
8. ONLY UTILIZE STATIC ROLLING COMPACTION METHODS FOR CONSTRUCTION ACTIVITIES. DO NOT USE VIBRATORY COMPACTION AT THE CONSTRUCTION SITE.

GENERAL NOTES:

1. TANKS ARE CAST-IN-PLACE REINFORCED CONCRETE STRUCTURES.
2. DISTURBED SOIL SHALL BE STABILIZED AND RE-VEGETATED.
3. DURING CONSTRUCTION PROVIDE STORM WATER POLLUTION PREVENTION BMP'S TO PREVENT THE DISCHARGE OF POLLUTANTS INTO OFFSITE STORM WATER FACILITIES.
4. THE EXISTING RESERVOIR CANNOT BE REMOVED UNTIL ONE OF THE NEW RESERVOIRS HAS BEEN COMPLETED AND PLACED ON LINE.
5. THE PRIVATE ACCESS ROAD MUST BE MAINTAINED AND LEFT OPEN DURING ALL PHASES OF CONSTRUCTION.
6. PROPERTY CORNERS HAVE BEEN SET BY REEVE AND ASSOCIATES, INC (SEE RECORD OF SURVEY JULY 2020).
7. SEE GEOTECHNICAL REPORT FOR SOIL CONDITIONS (CHRISTENSEN GEOTECHNICAL REPORT NO. 226-001, MAY 16, 2020).
8. SEE SURFACE FAULT RUPTURE HAZARD EVALUATION FOR GEOLOGIC CONDITIONS (WESTERN GEOLOGIC & ENVIRONMENTAL, LLC REPORT NO. 5379, APRIL 29, 2020).
9. BUREAU OF RECLAMATION (B.O.R.) RIGHT-OF-WAY OR EASEMENTS ARE PRESENT ON THE SITE. CONTRACTORS, SUBCONTRACTORS, EQUIPMENT OPERATORS, DRIVERS AND EMPLOYEES SHALL BE REQUIRED TO RECEIVE TRAINING FROM THE BUREAU OF RECLAMATION OR THEIR REPRESENTATIVE PRIOR TO BEGINNING WORK.

REV.	DATE	APPR.