

*LANDMARK SURVEYING, INC*  
*4646 S. 3500 W.*  
*West Haven, Utah 84401*  
*ph: 801-731-4075.*  
*fax: 731-8506*

To: Weber County Engineering  
Re: Murray Flag Lot Subdivision Review Comments

Here are the responses to the comments per your review.

1. There will be a deferral on the curb, gutter and sidewalk which will be signed by the developer.
2. The irrigation ditch in the front of the property will be piped with 36" RCP with a 1 foot deep drainage swale on top. A plan & profile drawing has been submitted.
3. There are no irrigation ditches on the property use to convey water to surrounding property owners.
4. An excavation permit will be requested for all work done in the existing right-of-way.

Thank you,

Tyler Knight

Landmark Surveying, Inc.