

PERMIT TO CONSTRUCT AN ONSITE WASTEWATER TREATMENT SYSTEM

ISSUED BY THE WEBER-MORGAN HEALTH DEPARTMENT 477 23rd Street, OGDEN, UTAH 84401



Permit No.: W101930

Issued: April 13, 2021

Expires: April 13, 2022

Identification Number 22-225-0001 with the following specifications and provisions: This is to certify that BOB KIRKMAN is hereby issued a permit to install an onsite wastewater treatment system for the property with the Property

Approximate construction site address: 4267 N 3150 E, LIBERTY Lot: 4 of the WARD ACRES subdivision in Weber county Utah.

Water supply will be provided by: LIBERTY PIPELINE COMPANY.

Type of System will be ABSORPTION FIELD with an absorption area of 540 Sq. Ft

Septic tank capacity must be at least 1750 gallons. System is designed for a 0 bedroom home Maximum depth of trench bottoms must be limited to 30 inches from original ground surface

*** IMPORTANT - PLEASE READ CAREFULLY ***

SIZED FOR MAXIMUM WATER USAGE OF 250 GPD.

MAXIMUM DEPTH TO BOTTOM OF TRENCH FROM ORIGINAL GROUND SURFACE IS 30".

THREE FOOT MAXIMUM BACKFILL OVER SEPTIC TANK.

INSTALL ACCORDING TO CONSTRUCTION PLANS REVIEWED BY THIS OFFICE.

WASHED 3/4 TO 2 1/2 INCH GRAVEL MUST BE USED. 1 INCH MINUS WILL NOT BE ACCEPTED.

WATER TIGHTNESS TEST REQUIRED. TANK MUST BE FULL AT TIME OF INSPECTION.

MUST BE INSTALLED BY LEVEL 2 STATE CERTIFIED INSTALLER.

Final inspection to be completed prior to any backfilling of installed system. Please provide the permit number and address when requesting the final inspection or any additional information regarding this system.

other factors, such as operation, maintenance, wastewater contents, etc., not addressed by the standards standards, and in no case does it guaranteee against the failure of the installed system. The performance of the installed system is affected by many This permit may be revoked or altered if the site is found to be in a flood hazard or other geologic hazard area. This permit is based on minimum design