



## Central Weber Sewer Improvement District

April 6, 2021

Steve Burton  
Weber County Planning Commission  
2380 Washington Blvd #240, Ogden, UT 84401

SUBJECT: Ali Farms Development  
Sanitary Sewer Service  
Will Serve Letter

Steve:

At the request of Phil Holland, we have reviewed a subdivision plan for Ali Farms Development with 31 residential lots located at approximate address 4700 W 747 S. West Weber County. We offer the following comments regarding Central Weber providing sanitary sewer service.

1. Central Weber has the capacity to treat the sanitary sewer flow from this subdivision. The development must be annexed into Central Weber Sewer District prior to connection to sewer.
2. If any connection is made directly into Central Weber's line the connection must be inspected by Central Weber while the work is being done. A minimum of 48-hour notice for inspection shall be given to Central Weber prior to any work associated with the connection.
3. Central Weber will not take ownership or responsibility for the condition, ownership or maintenance of the proposed sanitary sewer lines (gravity or pressure) or system that will be installed to serve this subdivision.
4. The connection of any sump pumps (or similar type pumps) to the sanitary sewer system is prohibited during or after construction. Central Weber's Wastewater Control Rules and Regulations state:

*Prohibited Discharge into Sanitary Sewer. No person shall discharge or cause or make a connection which would allow to be discharged any storm water, surface water, groundwater, roof water runoff or subsurface drainage to any sanitary sewer.*

5. The entire parcel of property to be served will need to be annexed into the District prior to any connection to the District's line. This annexation must be complete before the sale of any lots in



## Central Weber Sewer Improvement District

the subdivision.

6. Impact fees will need to be paid to Central Weber Sewer Improvement District no later than the issuance of any building permits. Annexation Book 86 page 6.

If you have any further questions or need additional information, please let us know.

Sincerely,

Clay Marriott

Construction Manager

CC:

Kevin Hall, Central Weber Sewer  
Phil Holland Psholland@mac.com  
Chad Meyerhoffer

Attachments

Ali Farms Prelim

Annexation Petition checklist