

Gas Clearance Report

Address 5593 E. Highway 39 City/State Huntsville UT

Zip Code 84317 Lot/Unit # _____ Subdivision _____

General Contractor/Owner Builder Dave Orchard

Mechanical Contractor SCP HVAC Gas Line Contractor The Gas Guy LLC

12035 W 8000 N
Tremonton Ut 84337
LIC # 11379024-5501

List of Equipment/Appliances

Furnace	<u>4</u>	BTUS	<u>40,000 x 4</u>
Water Heater	<u>2</u>	BTUS	<u>150,000 x 2</u>
Range/Cook Top	<u>1</u>	BTUS	<u>40,000</u>
Fire Place	<u>4</u>	BTUS	<u>15,000 x 3 / 25,000</u>
Dryer	—	BTUS	—
Barbecue	<u>1</u>	BTUS	<u>35,000</u>
Boiler	—	BTUS	—
Garage Heater	—	BTUS	—
Generator	<u>1</u>	BTUS	<u>150,000</u>
Fire Pit	<u>2</u>	BTUS	<u>40,000 x 2</u>
Roof Top	—	BTUS	—
_____	—	BTUS	—
_____	—	BTUS	—
_____	—	BTUS	—

Total Appliances 15 Total BTUS 975,000 Total CFH 983 Furthest distance 90

Fuel line tested at 10 PSI for 30 Min

Meter tie in size $\frac{1}{8}$ " $\frac{3}{4}$ " 1" X 1 $\frac{1}{4}$ " 1 $\frac{1}{2}$ " 2"

System Operating Pressure 4oz 2lbs X Other Natural Gas Propane X

I Hereby Certify That The Entire Mechanical Fuel-Line System For The Structure Located At The Address Listed Above Has Been Sized And Pressure Tested In Accordance With The IPC,IMC,IFGC As Presently Adopted By The State Of Utah

Certified Installer Printed Chad Gray Signature Chad Gray Date 4-8-20

RMGA Card # 8999 Phone # 801-870-3764

Inspector _____ Meter Installation Approved Denied

Date _____