

EDEN IRRIGATION COMPANY

P.O. Box 56
Eden, UT 84310

November 2, 2021

To Whom It May Concern:

Subject: Easement and Piping on Stallings Ditch Daylight Ranch Subdivision Lot 1

Following are the requirements for easement and piping on the Stallings Ditch for Daylight Ranch Subdivision Lot 1:

Easement Requirements:

- 10 feet on either side of the centerline of a piped ditched.
- 16 feet on either side of the centerline of an open ditch.
- Trees must be a minimum of 20 feet away from open ditches.

Piping Requirements:

- 24" reinforced concrete pipe must be used with minimum 12" fill;
- pipe needs to be installed at same grade to maintain the same flow of water;
- if a trash grate is installed, it is the property owner's responsibility to ensure grate is cleared of debris;
- project must be completed outside of the water year (i.e., started after October 15 and completed before April 15).

You may contact me at 801-745-9546 or raccasi@msn.com, if you have questions or need additional information.

Sincerely,



Ruby Raccasi

Secretary

Eden Irrigation Company