

## **Central Weber Sewer Improvement District**

November 16, 2021

Chad Meyerhoffer Weber County Planning Commission 2380 Washington Blvd #240, Ogden, UT 84401

SUBJECT: JA Gibson Subdivision Sanitary Sewer Service Will Serve Letter

## Chad:

At the request of Koby Smith, JA Gibson Subdivision with 2 proposed residences located at approximate address. 5077 W. 2200 S. Taylor, Utah. We offer the following comments regarding Central Weber providing sanitary sewer service.

- 1. Central Weber has the capacity to treat the sanitary sewer flow from this subdivision.
- 2. The connection is made directly into Central Weber's line the connection must be inspected by Central Weber while the work is being done. A minimum of 48-hour notice for inspection shall be given to Central Weber prior to any work associated with the connection.
- 3. Central Weber will not take ownership or responsibility for the condition, ownership or maintenance of the proposed sanitary sewer lines (gravity or pressure) or system that will be installed to serve this subdivision.
- 4. The connection of any sump pumps (or similar type pumps) to the sanitary sewer system is prohibited during or after construction. Central Weber's Wastewater Control Rules and Regulations state:

Prohibited Discharge into Sanitary Sewer. No person shall discharge or cause or make a connection which would allow to be discharged any storm water, surface water, groundwater, roof water runoff or subsurface drainage to any sanitary sewer.

5. The entire parcel of property to be served will need to be annexed into the District prior to any connection to the District's line. This annexation must be complete before the sale of any lots in the subdivision.



## **Central Weber Sewer Improvement District**

6. Impact fees will need to be paid to Central Weber Sewer Improvement District no later than the issuance of any building permits.

If you have any further questions or need additional information, please let us know. Sincerely,

Clay Marriott

**Construction Manager** 

CC: Chad Meyerhoffer, Weber County Kevin Hall, Central Weber Sewer Koby Smith