
Subject: Fw: Letter for county

From: Huntsville Irrigation (huntsvilleirrigationco@yahoo.com)

To: clverhaal@yahoo.com;

Date: Friday, June 14, 2013 11:26 AM

----- Forwarded Message -----

From: Huntsville Irrigation <huntsvilleirrigationco@yahoo.com>
To: "clverhaal@yahoo.com" <clverhaal@yahoo.com>
Sent: Friday, June 14, 2013 10:16 AM
Subject: Letter for county

Huntsville Irrigation Company

PO Box 140
Huntsville, Utah 84317
Phone: 801-745-1895

June 14, 2013

To Whom It May Concern:

There are four shares of water that are attached to the parcel of land owned by The Granath Family Trust. This property is located on 100 South about 9029 East in Huntsville, Utah. The water is secondary irrigation water and is delivered through a pipe. It is pressurized irrigation.

Please contact me if more information is needed.

Sincerely,

Brenda Grow

Secretary



WEBER-MORGAN HEALTH DEPARTMENT

GARY M. HOUSE, M.P.H.
Health Officer / Director

June 12, 2013

Division Directors
KAY LARRISON, Administration
CLAUDIA PRICE, Nursing & Health Promotion
LOUIS COOPER, Environmental Health
COLLEEN JENSON, WIC

Weber County Planning Commission
2380 Washington Blvd.
Ogden, UT 84401

RE: Granath Family Trust Property, 2 Lots
9929 E. 100 S., Huntsville
Parcel #21-025-0011

Gentlemen:

The plans and supporting information for the above-referenced subdivision have been reviewed.

Culinary water will be provided by a private well. The placement of the well is critical so as to provide the required 100 foot protection zone. The well will need to be dug, tested and the water supply approved prior to issuance of a wastewater disposal permit.

Soil characteristics, percolation rates of 30 MPI, and anticipated ground water tables not to exceed 50 inches, fall within the range of acceptability for the utilization of a Conventional Wastewater Disposal System as a means of wastewater disposal. Maximum trench depth is limited to 36 inches.


Plans for the construction of any wastewater disposal system are to be prepared by a Utah State certified individual and submitted to this office for review prior to the issuance of a Wastewater Disposal permit.

All subdivision plats submitted for review are to show the location of exploration pits and percolation tests. Key number or letter designation will be provided by this office along with logs of soil horizons and final percolation rates. Mylars submitted for signature without this information will be returned.

Each on-site individual wastewater disposal system must be installed in accordance with R317-501 through R317-513, Utah Administrative Code, Individual Wastewater Disposal Systems and Weber-Morgan District Health Department Rules. Final approval will be given only after an on-site inspection of the completed project and prior to the accomplishment of any backfilling.

Please be advised that the conditions of this letter are valid for a period of 18 months. At that time the site will be re-evaluated in relation to rules in effect at that time.

Sincerely,



Summer Day, LEHS
Environmental Health Division

SD/jc