

Department of Environmental Quality

Kimberly D. Shelley Executive Director

DIVISION OF DRINKING WATER Tim Davis Director

February 28, 2022

Brad Blanch Terakee Farms P.O. Box 14016 Ogden, Utah 84412

Subject: Plan Approval, Meter Vault and Backflow Assembly, Terakee Farms, The Barn & The

Meadow Subdivisions (DS001); WBWCD North, System #29109, File #12910

Dear Brad Blanch:

The Division of Drinking Water (the Division) received the plans and specifications, prepared by Great Basin Engineering, for the proposed Meter Vault and Backflow Assembly, Terakee Farms, The Barn & The Meadow Subdivisions (DS001) from you on February 15, 2022. Written review comments were provided to you on February 22, 2022. The Division received the revised plans and specifications on February 23, 2022. This project has met the conditions for receiving a plan approval.

Our understanding of the project is the installation of a meter vault and backflow assembly (Watts RPZ 6-inch Series 009), that will provide secondary water service for The Barn at Terakee Farms Planned Residential Unit Development (PRUD) and The Meadow at Terakee Farms Subdivision. The meter and backflow assembly will tie into an existing culinary water line owned and operated by the Weber Basin Water Conservancy District. Weber Basin Water Conservancy District has approved the installation of the project.

We have completed our review of the plans and specifications, by Great Basin Engineering, and find they basically comply with the applicable portions of Utah's Administrative Rules for Public Drinking Water Systems in R309. On this basis, the plans for Meter Vault Backflow Assembly Terakee Farms The Barn & The Meadow Subdivisions (DS001) are hereby approved.

Brad Blanch Page 2 of 2 February 28, 2022

This approval pertains to construction only. An Operating Permit must be obtained from the Director before Meter Vault and Backflow Assembly, Terakee Farms, The Barn & The Meadow Subdivisions (DS001) may be put in service. A checklist outlining the items required for operating permit issuance is enclosed for your information.

Approvals or permits from the local authority or the county may be necessary before beginning construction of this project. As the project proceeds, notice of any changes in the approved design, as well as any change affecting the quantity or quality of the delivered water, must be submitted to the Division. We may also conduct interim and final inspections of this project. Please notify us when actual construction begins so that these inspections can be scheduled.

This approval must be renewed if construction has not begun or if substantial equipment has not been ordered within one year of the date of this letter.

If you have any questions regarding this approval, please contact Brent Arns, of this office, at (385) 549-7420, or me at (385) 515-1464.

Sincerely,

Michael Newberry, P.E. Engineering Manager

BA/mrn/mdb

Enclosures - Operating Permit Checklist

cc: Michelle Cooke, Weber-Morgan Health Department, mcooke@co.weber.ut.us
Brad Blanch, Terakee Farms, bradblanch@gmail.com
Casey Potter, Weber Basin Water Conservancy District, cpotter@weberbasin.com
Andy Hubbard, Great Basin Engineering, andyh@greatbasineng.com
Brent Arns, Division of Drinking Water, barns@utah.gov

DDW-2022-004270

Utah Division of Drinking Water — Checklist for Issuing Operating Permits

Water System Name: Project Description:		System Number: File Number:	
placed	ibution lines (not including in-line booster pund into service prior to submitting all of the follwater system has received items 1 and 4 below	owing items and receipt of Operating Permit	
□ 1.	Certification of Rule Conformance by a professional engineer (P.E.) that all conditions of Plan Approval were accomplished, and if applicable, changes made during construction were in conformance with rules R309-500 through 550		
□ 2.	As-built or record drawings incorporating all changes to approved plans and specifications (unless no changes were made to the previously approved plans during construction)		
□ 3.	Confirmation that as-built or record drawings have been received by the water system		
□ 4.	Satisfactory bacteriological samples as evidence of proper disinfection and flushing in accordance with the appropriate ANSI/AWWA standards:		
	☐ ANSI/AWWA C651-14 AWWA Standar	d for Disinfecting Water Mains	
	Two consecutive sample sets at least 1,200 feet, end-of-line, each branch)	16 hours apart, none positive (e.g., every	
	☐ ANSI/AWWA C652-11 AWWA Standar	d for Disinfection of Water-Storage Facilities	
	One or more samples, none positive		
	☐ ANSI/AWWA C653-13 AWWA Standar Plants	d for Disinfection of Water Treatment	
	Two consecutive samples per unit, no	ne positive, no less than 30 minutes apart	
	☐ ANSI/AWWA C654-13 AWWA Standar	d for Disinfection of Wells	
	Two consecutive samples, none positive, no less than 30 minutes apart		
□ 5.	Water quality data, where appropriate [For example, include raw and finished water data that demonstrate satisfactory performance of the treatment facility; sample should be taken from a storage tank for residual volatile organic compounds after tank interior re-coating; etc.]		
□ 6.	If applicable, all other documentation that may have been required during the plan review process		
□ 7.	If applicable, confirmation that the water system owner has received the O&M manual for the new facility		
□ 8.	. If applicable, location data of new storage tar	ik, treatment facility, or source	