

Home	Help	Projects	Map	Rick Everson	Dashboard	Account Settings	Log Out
<input type="text"/>							Go

Engineering Review 9

Project: [Summit Eden Phase 1B](#)
User: [Dana Shuler](#)
Department: [Weber County Engineering Division](#)
Created: 2014-10-17 10:20:09
Modified: 2014-10-17 10:20:27

Notes

I have had a chance to review the plans submitted via email on 10/15/2014 and have the following comment(s):

1. Easements are required for dry utilities shown beyond the road right-of-way (recommend considering the future gas line location when analyzing need for PUE).
2. Sheet 1.02 - Recommend putting the communications line in the PUE rather than the drainage easement.
3. Sheet 1.04 - Please check elevation for drain pipe in cul-de-sac half section B-B.

I have tried to address all items of concern from the Engineering Department. However, this review does not forego other items of concern that may come to this department's attention during additional reviews or during construction of improvements. If you have any comments or questions concerning this review, feel free to contact me.

© 2010-2014 Weber County **Planning** and **Engineering** Divisions.

Images, drawings, plats, elevations, renderings, site plans, et cetera on this site may be protected by copyright law. They are provided for viewing as a public service. Permission from the copyright holder should be obtained prior to any uses other than personal viewing; any other uses of these files may be copyright infringement.