



2023 West 1300 North  
Farr West, Utah 84404  
(801) 782-3580  
Fax (801) 782-3582

**Board of Trustees**  
James Truett  
Val Heiner  
Blaine Holmes  
Michael Hancock  
Dennis Montgomery  
Kevin Ward  
Tim Shupe  
Annette Fielding  
Scott VanLeeuwen

---

## PLAN REVIEW

**Date:** November 19, 2013

**Project Name:** Summit at Powder Mountain Phase

**1D- Parcel D- Village Nest Condos- Review #2**

**Project Address:** Daybreak Ridge (New Road)

**Contractor/Contact:** Russ Watts/ NV5

**FEE NOTICE:**

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: **Weber Fire District.**

---

**Status: APPROVED**

**Specific Comments:**

1. All comments from the previous review have been addressed.
2. It is noted in the response letter from NV5 that all residences on lot 35 will be provided with fire suppression systems compliant with NFPA 13d or NFPA 13r.

Every effort has been made to provide a complete and thorough review of these plans. This review DOES NOT relieve the owner, contractor and/or developer from compliance with any and all applicable codes, and standards.

Any change or revision of this plan will render this review void and will require submittal of the new, or revised, layout for fire department review. If you have any questions, please contact me at 801-782-3580.

Brandon Thueson  
Fire Marshal

cc: File