



preliminary comments:

1. all meters to be adjacent to distribution line
2. show radius on curved sewer line and manufacturer's recommended max.
3. why are you providing water service to garages?
4. sewer service to unit 1
5. prefer junction manhole outside of wet well