

June 3, 2022

Tucker Weight Weber County Engineering

RE: TC Gailey Response to Comments 5/13/2022

Mr. Weight,

The following is in response to comments received from Engineering on the TC Gailey subdivision. Please let us know if you have any further questions.

- 1. The irrigation system is designed per TWWW standards.
- 2. A letter from TWWW will be provided.
- 3. A letter from TWWW will be provided for the secondary water plans.
- 4. The HOA will be responsible for maintaining the secondary water system.
- 5. A road cross section has been added to sheet 2 of the plans. The roadway will be widened to provide a minimum of 26'.
- 6. A fence has been called out around the irrigation basin.
- 7. The inlet screen is per the manufacturer of the pump system. A submittal can be provided if required.
- 8. The pump is designed to handle up to two lots at a time, scheduling of the irrigation will be handled by the HOA.
- 9. The number of shares and scheduling of water to the irrigation basin will be coordinated with the irrigation company.
- 10. The developer will enter into a deferral for curb, gutter and sidewalk.
- 11. An excavation permit will be applied for.
- 12. An escrow will be entered into.
- 13. An engineers estimate will be provided once the plans are approved.
- 14. A storm water construction permit will be applied for.
- 15. A SWPPP permit will be applied for.
- 16. Additional comments from the review have been addressed.

Please let us know if there are any additional questions.

Vereny Enger Jeremy Draper, PE, MBA Reeve and Associates

jeremy@reeve.co