



March 10, 2015

Dan White  
Weber County

***Project: Mallard Springs Subdivision***

***Re: Engineering Division***

Below please find our response to your Miradi posted comments dated March 3, 2015. Please note that our numbering reference system corresponds to your comment numbering system.

1. Noted
2. Connection to the 24" ductile iron pipe on 2550.
3. HIC sumps have been specified at the end of the irrigation lines.
4. An automatic air valve has been specified on plans.
5. The irrigation laterals for Lots 5, 14, and 15 have been shown 6' from the water meter.
6. Noted.
7. The fence has been specified to be a solid wall vinyl fence.
8. A sewer note is on the plans that call for 18" steel casing extending 4' beyond high bank both sides of canal.
9. The "no drainage" note was added to Sheet 2
10. General note 5 was updated to include Hooper Irrigation Company Standard.
11. The details have been removed.
12. The profiles have been updated.
13. The canal has been shown and noted on Sheet 12. The approval letter will be provided to the County.
14. A note on the SWPPP has been provided to include silt fencing for the length of the sewer extension.

We appreciate your review and trust we have changed and/or clarified all of your comments referenced herein.

If you have any questions, or we can be of further assistance, please let us know.

Sincerely,  
REEVE & ASSOCIATES, INC.

---

Nate Reeve, P.E.  
Principal Engineer  
nreeve@reeve-assoc.com

**Solutions You Can Build On™**

Civil Engineering • Land Planning • Structural Engineering • Landscape Architecture • Land Surveying • Construction Surveying  
920 Chambers St., Suite 14 • Ogden, Utah 84403 • Tel: 801-621-3100 • Fax: 801-621-2666  
ogden@reeve-assoc.com • reeve-assoc.com