BRIAN COWAN, MPH, LEHS Health Officer/Executive Director

July 7, 2022



Weber County Planning Commission 2380 Washington Blvd. Ogden, UT 84401

RE:

Michael and Jenny Pulsipher 9215 E 500 S, Huntsville UT Parcel #21-151-0002 Soil log #15385

Gentlemen:

The soil and percolation information for the above-referenced lot have been reviewed. Culinary water will be provided by a private well. The placement of the well is critical so as to provide the required 100 foot protection zone. The well will need to be dug, tested and the water supply approved prior to issuance of a wastewater disposal permit.

DESIGN REQUIREMENTS

Anticipated ground water tables not to exceed 48 inches, and soil classified as Type 1, fall within the range of acceptability for a Packed Bed Media Treatment System with non-chemical disinfection followed by a conventional trench with a maximum trench depth limited to 12 inches. The absorption system is to be designed using a maximum loading rate of 0.65 gal/sq. ft. /day as required for a sandy loam, granular. This is for the area of exploration pit located at UTM Zone 12 Nad 83 0438914 E 4567126 N.

Plans for the construction of any wastewater disposal system are to be prepared by a Utah State certified individual and submitted to this office for review prior to the issuance of a Wastewater Disposal permit.

The following items are required for a formal subdivision review; application, receipt of the appropriate fee, and a full sized copy of the subdivision plats showing the location of exploration pits and percolation tests as well as the documented soil horizons and percolation rates. A subdivision review will not occur until all items are submitted. Mylars submitted for signature without this information will be returned.

Each on-site individual wastewater disposal system must be installed in accordance with R317-4, Utah Administrative Code, Individual Wastewater Disposal Systems and Weber-Morgan District Health Department Rules. Final approval will be given only after an on-site inspection of the completed project and prior to the accomplishment of any backfilling.

Please be advised that the conditions of this letter are valid for a period of 18 months. At that time, the site will be re-evaluated in relation to rules in effect at that time.

any mandranes disposal system and 10 to the elected by a libd. Sind artifled

Sincerely,

Craig Jorgensen, LEHS

Environmental Health Division of Not 13 Mot 83 04350 for a substitution of the substit