

## Hawkins Creek - Lot 33

---

From: Mark Babbitt (markb@greatbasineng.com)

To: rhspendlove@yahoo.com

Date: Monday, August 8, 2022 at 04:53 PM MDT

---

Ryan,

Here's the topographical survey info we have on Lot 33.

I have marked the areas that have slopes greater than 25%.

The buildable area (75' by 100') needs to have an average slope of less than 25% so some slopes greater than 25% can be included in the buildable area as long as the average slope is less than 25%.

I have marked in blue a new buildable area that matched the north line of the existing buildable area.

We could also shift the buildable area south up to 25 feet or North up to 35-feet and east up to 30 feet and still make the buildable area work from an average slope stand-point.

Please review.

Thanks

Mark E Babbitt, PE / PLS

Principal

Great Basin Engineering, Inc

801-394-4515



HAWKINSCR\_.pdf  
7.8MB