

Bona Vista Water Improvement District

2020 West 1300 North, Farr West, Utah 84404 Phone (801) 621-0474 Fax (801) 621-0475

February 17, 2023

TO: Weber County

RE: WILL SERVE LETTER - Weber Industrial Park (Fox Run)

The project located at 2147 Rulon White Blvd is in the boundaries of the Bona Vista Water Improvement District. The commercial project utility plans have been reviewed by the District and changes, if any, have been made and corrected.

This letter serves as verification that the corrected plans have been approved for the above-named project. Only the phase in consideration is guaranteed service. The plan review is good for a period of one year from the date of this letter. If not constructed within that time frame, the review process will start again including additional fees.

Culinary water will be made available once the following criteria are met:

- All water mains, service lines, fire hydrants, etc. must be constructed according to the district's specifications. Those specifications can be found on the district's website: https://www.bonavistawater.com/construction-standards
- Fire line fees are paid, if applicable.
- Proof of secondary water will need to accompany the connection fee for <u>each</u> connection inside the development. The connection receipt will serve as verification from the district for building permit purposes.
 - Allowable proof of secondary water is a connection receipt from a pressurized secondary water provider or a letter clearly stating that there are 3-acre feet of water available for each acre of undeveloped property (water shares must be in owners name).

If you have any questions, please feel free to call me. I can be reached at 801-621-0474 ext. 207, Monday through Friday, 9am - 5pm.

Sincerely,

Matt Fox

Assistant Manager