

Weber Fire District

Plan Review

Date: November 14, 2013

Project Name: Silver Estates Subdivision

Project Address: 9096 East 1300 South, Huntsville Contractor/Contact:Mathew Lowe 801648-8229

Fees:

Plan Review				\$50.00
Residential	417.00 per residence or unit	N/A		\$0.00
Commercial	\$18.00 per 1000 square feet	0.018		\$0.00
Industrial	\$9.00 per 1000 square feet	0.009		\$0.00
			Total Due	\$50.00

FEE NOTICE:

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: **Weber Fire District**.

REVIEW STATUS: APPROVED

SPECIFIC COMMENTS:

- 1. Due to the fact that there is no permanent water supply in this area the Weber County ordinance does not require fire hydrants.
- 2. For single family dwellings, the minimum fire flow required is 1000 gallons per minute. The required water storage capacity for firefighting purposes is 120,000 gallons. All structures over 5000 sq. ft. which do not meet the fire flow requirements, shall be equipped with an NFPA 13D compliant fire sprinkler system.
- 3. Fire Access roads to any property shall have a minimum clear width of 20 feet (face of curb to face of curb) and a vertical clearance of 13 foot 6 inches and shall be capable of supporting a 75,000 pound load.
- 4. Roads shall have a maximum grade of 10% unless specifically approved as outlined by the International Fire Code.
- 5. Radius on all corners shall be a minimum of 28'-0".
- 6. 3. Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for height, width and imposed loads as permanent roads.

Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all applicable codes and standards. Any change or revision of this plan will render this review void and will require submittal of the new or revised layout for fire department review.



Reviewed by: Brandon Thueson Fire Marshal

cc: File