

**GENERAL NOTES:**  
 CONTRACTOR IS TO COORDINATE ALL UTILITIES WITH MECHANICAL AND ELECTRICAL DRAWINGS.  
 ALL NEW SANITARY SEWER CONSTRUCTION TO BE DONE IN ACCORDANCE WITH LOCAL GOVERNING AGENCIES AND WEBER COUNTY STANDARDS & SPECIFICATIONS.  
 ALL NEW WATER CONSTRUCTION TO BE DONE IN ACCORDANCE WITH LOCAL GOVERNING AGENCIES AND WEBER COUNTY STANDARDS & SPECIFICATIONS.  
 CONTRACTOR IS TO SUBMIT SITE PLAN TO QUESTAR GAS FOR DESIGN OF GAS LINE SERVICE TO BUILDINGS. CONTRACTOR TO COORDINATE WITH QUESTAR GAS FOR CONTRACTOR LIMITS OF WORK VERSUS QUESTAR GAS LIMITS.

EXISTING UNDERGROUND UTILITIES AND IMPROVEMENTS ARE SHOWN IN THEIR APPROXIMATE LOCATIONS BASED UPON RECORD INFORMATION AVAILABLE AT THE TIME OF PREPARATION OF PLANS. LOCATIONS MAY NOT HAVE BEEN VERIFIED IN THE FIELD AND NO GUARANTEE IS MADE AS TO ACCURACY OR COMPLETENESS OF THE INFORMATION SHOWN. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO DETERMINE THE EXISTENCE AND LOCATION OF THOSE UTILITIES SHOWN ON THESE PLANS OR INDICATED IN THE FIELD BY LOCATING SERVICES. ANY ADDITIONAL COSTS INCURRED AS A RESULT OF CONTRACTOR'S FAILURE TO VERIFY LOCATIONS OF EXISTING UTILITIES PRIOR TO BEGINNING OF CONSTRUCTION IN THEIR URGENCY SHALL BE BORNE BY THE CONTRACTOR AND ASSUMED INCLUDED IN THE CONTRACT.

LOCATION OF ALL UNDERGROUND UTILITIES SHOWN ARE APPROXIMATE. CONTRACTOR IS TO VERIFY CONNECTION POINTS WITH EXISTING UTILITIES. CONTRACTOR IS RESPONSIBLE FOR ANY DAMAGE CAUSED TO EXISTING UTILITIES AND UTILITY STRUCTURES THAT ARE TO REMAIN.

ALL SURFACE IMPROVEMENTS DISTURBED BY CONSTRUCTION SHALL BE RESTORED OR REPLACED, INCLUDING TREES, DECORATIVE SHRUBS, SOO, FENCES, WALLS AND STRUCTURES, WHETHER OR NOT THEY ARE SPECIFICALLY SHOWN ON THE CONTRACT DOCUMENTS.


DEFLECT WATER LINE TO AVOID CONFLICT WITH STORM DRAIN LINE PER WEBER COUNTY STANDARDS AND SPECIFICATIONS (MAINTAIN MINIMUM 18" CLEARANCE). DEFLECT IRRIGATION LINE TO AVOID CONFLICT WITH WATER LINE OR STORM DRAIN LINE PER WEBER COUNTY STANDARDS AND SPECIFICATIONS (MAINTAIN MINIMUM 18" CLEARANCE).

SEE ELECTRICAL PLANS FOR DRY UTILITY LOCATION, INSTALLATION AND DESIGN INFORMATION.  
 IRRIGATION SYSTEM TO BE MAINTAINED BY THE OWNER OR ITS DESIGNATED AGENT.

**SCOPE OF WORK:**  
 PROVIDE, INSTALL AND/OR CONSTRUCT THE FOLLOWING PER THE SPECIFICATIONS GIVEN OR REFERENCED, THE DETAILS NOTED, AND/OR AS SHOWN ON THE CONSTRUCTION DRAWINGS:

1. 6" PRIVATE SDR-35 PVC SANITARY SEWER LINE PER WEBER COUNTY STANDARDS AND SPECIFICATIONS. SEE DETAIL B/CE-601 & F/CE-602.
2. 4" PRIVATE SANITARY SEWER MANHOLE PER WEBER COUNTY STANDARDS AND SPECIFICATIONS. SEE DETAIL 2/CE-606.
3. CONNECT 8" PRIVATE PVC C-900 FIRE SERVICE LINE TO EXISTING 8" WATER MAIN WITH TEE AND THRUST BLOCKING PER WEBER COUNTY STANDARDS AND SPECIFICATIONS. SEE DETAIL E/CE-602 & 5/CE-607.
4. NOT USED
5. 8" X 8" TEE WITH 6" REDUCER AND 6" GATE VALVE WITH THRUST BLOCKING PER WEBER COUNTY STANDARDS AND SPECIFICATIONS. SEE DETAIL E/CE-602.
6. HOT TAP 3" CONNECTION TO EXISTING MAIN. INSTALL 3" CORP. STOP AND TAPPING SADDLE PER WEBER COUNTY STANDARDS AND SPECIFICATIONS.
7. STUB FOR IRRIGATION CONNECTION. SEE LANDSCAPE DRAWINGS FOR CONTINUATION.
8. INSTALL 3" WATER METER WITH 4" REDUCER AND 4" CONNECTION INTO ROADWAY PER WEBER COUNTY STANDARDS AND SPECIFICATIONS. SEE DETAIL A/CE-601.
9. PRIVATE 4" C-900 PVC WATER LATERAL. INSTALLATION AND TRENDING PER WEBER COUNTY STANDARDS AND SPECIFICATIONS. SEE DETAIL A/CE-601 AND B/CE-601.
10. 8" PRIVATE GATE VALVE WITH THRUST BLOCKING AND VALVE COVER PER WEBER COUNTY STANDARDS AND SPECIFICATIONS. SEE DETAIL E/CE-602.
11. 8" 90° BEND WITH THRUST BLOCKING PER WEBER COUNTY STANDARDS AND SPECIFICATIONS. SEE DETAIL E/CE-602.
12. 8" 45° BEND WITH THRUST BLOCKING PER WEBER COUNTY STANDARDS AND SPECIFICATIONS. SEE DETAIL E/CE-602.
13. INSTALL PRIVATE FIRE HYDRANT PER WEBER COUNTY STANDARDS AND SPECIFICATIONS. SEE DETAIL 1/CE-607 WITH THRUST RESTRAINTS PER DETAIL E/CE-602.
14. INSTALL 2" NATURAL GAS LATERAL PER QUESTAR GAS STANDARDS AND SPECIFICATIONS. NOTIFY QUESTAR GAS PRIOR TO CONNECTING TO EXISTING GAS LINE.
15. ELECTRICAL EQUIPMENT. SEE ELECTRICAL PLANS FOR MORE INFORMATION.
16. INSTALL TRAFFIC RATED CLEANOUT LID AND COLLAR PER WEBER COUNTY STANDARDS AND SPECIFICATIONS. SEE DETAIL Q/CE-602.
17. LOCATE & ABANDON EXISTING 2" WATERLINE STUB AT MAIN.
18. CONST. OIL/WATER SEPARATOR SEE MECHANICAL PLANS FOR DETAIL.
19. RELOCATE EXISTING HYDRANT PER WEBER COUNTY STANDARDS AND SPECIFICATIONS.
20. INSTALL 4" IRRIGATION WATER LATERAL FROM METER, ALONG PROPERTY LINE, AND BEHIND MAINTENANCE BUILDING. SEE LANDSCAPE PLANS.
21. FUTURE PRESSURE IRRIGATION SUPPLY LINE. INSTALL ADDITIONAL 4" IRRIGATION WATER LATERAL FROM RIGHT OF WAY, ALONG PROPERTY LINE, AND BEHIND MAINTENANCE BUILDING. SEE LANDSCAPE PLANS.

MHTN ARCHITECTS, INC.  
 Consulting, written material, and design concepts shall not be used or reproduced in whole or part in any form without prior written consent of MHTN Architects, Inc. All drawings are the property of MHTN Architects, Inc. and shall remain confidential. Use of any information or drawings without the written consent of MHTN Architects, Inc. is strictly prohibited. Contractor shall verify all dimensions and conditions at job site.



PROJECT NO. 2012545.00  
 DRAWN BY: BP  
 CHECKED BY: PF

ISSUED:

NO.	DATE	DESCRIPTION
1	1/28/21	CONSTRUCTION DOCUMENTS

CONTRACTOR TO VERIFY DRAWINGS IN FIELD USE REFLECT LAST REVISION DATE:

NO.	DATE	DESCRIPTION

DATE: 1/28/21 TIME: 8:34:44 AM DRAWING NO.: CE-401-1.DWG  
 SERVER: I:\projects\2021\12545\DWG\CE-401-1.dwg  
 PLOT DATE: 1/28/21 PLOT TIME: 8:34:44 AM  
 PLOTTER: HP DesignJet T1130e PLOTER  
 PLOTTER MODEL: HP DesignJet T1130e PLOTER  
 PLOTTER DRIVER: HP DesignJet T1130e PLOTER  
 PLOTTER STATUS: OK  
 PLOTTER PORT: \\server\shared\plotters\HP-DesignJet-T1130e-PLOTER